

TOWN OF BRAINTREE

IN COUNCIL

ORDER NO: **09-034**

DATE: MAY 27, 2009

ORDERED: NATIONAL GRID

PETITION OF NATIONAL GRID FOR GAS MAIN LOCATIONS

The National Grid hereby respectfully request your consent to the locations of mains as hereinafter described for the transmission and distribution of gas in and under the following public streets, lanes, highways, and places of the Town of Braintree and the pipes, valves, governors, manholes and other structures, fixtures and appurtenances designed or intended to protect or operate said mains and accomplish the objects of said Company; and the digging up and opening the ground to lay or place same:

To install and maintain approximately 255 feet, more or less of 2 inch gas main in Walnut Street, Braintree.

From the existing 2 inch gas main in Walnut Street @ Storrs Avenue Northerly to the existing 2 inch gas main at Parkside Avenue. All of which to replace and abandon the existing 2 inch gas main in Walnut Street, Braintree.

Petition #09-034 was unanimously approved by Council with the following conditions:

Petition #09- 034 Storrs Ave and Walnut St. have **(2) 115kv** oil filled lines and a 15kv duct bank. The contractor shall notify BELD 48 hours prior to start of excavation.

09-034 – **Walnut Street** has been reconstructed last year, but only to the binder as a repair after installation of the new water main. This relocation is being done to facilitate removal of two unsafe trees so curbing, sidewalks and another course of pavement can be constructed this year, so this petition **should be approved with our “standard” repair specifications.** We also remind Nationalgrid that the Town will have a sidewalk contractor on the street, so Nationalgrid will have to coordinate their work with our contractor to avoid interference or delays.

Passed in Council – June 16, 2009

