

SSO Location	Discharge Statement	Date Start	Time Start	Date End	Time End	Duration	Estimated Volume (gallons)	Description	ol u Mitigation Planned
C1-6 (94 Allen Street)	from overflow pipe directly to receiving water	5/22/2025	11:00 PM	5/24/2025	2:00 AM	27h	312,300	Heavy rain event causing surcharging sewer manholes	Continue with I&I correction in system.
C1-5 (50 Allen Street)	from SMH directly to receiving water	5/23/2025	12:15 AM	5/23/2025	7:00 PM	18h 44m	57,000	Heavy rain event causing surcharging sewer manholes	Continue with I&I correction in system.
S1-113 (Jay Street)	from SMH directly to receiving water	5/23/2025	1:15 AM	5/23/2025	12:00 PM	10h 47m	24,000	Heavy rain event causing surcharging sewer manholes	Continue with I&I correction in system.
C1-5 (50 Allen St)	from SMH directly to receiving water	7/10/2025	7:30 AM	7/10/2025	9:30 PM	14h	60,000	Heavy rain event causing surcharging sewer manholes	Continue with I&I correction in system.
C1-6 (94 Allen St)	from SMH directly to receiving water	7/10/2025	8:30 AM	7/10/2025	10:30 PM	14h	300,000	Heavy rain event causing surcharging sewer manholes	Continue with I&I correction in system.
S1-113 (Jay Street)	from SMH directly to receiving water	7/10/2025	9:00 AM	7/10/2025	3:00 PM	6h	72,000	Heavy rain event causing surcharging sewer manholes	Continue with I&I correction in system.
C1-4 (44 Allen St)	from SMH directly to receiving water	7/10/2025	11:00 AM	7/10/2025	5:30 PM	6h 30m	33,000	Heavy rain event causing surcharging sewer manholes	Continue with I&I correction in system.
S2-83 Trotter's Green	Pumped from SMH to catch basin	7/10/2025	11:00 AM	7/10/2025	4:30 PM	5h 30m	82,500	Heavy rain event causing surcharging sewer manholes	Continue with I&I correction in system.
							940,800		

SSO Location	Discharge Statement	Date Start	Time Start	Date End	Time End	Duration	Estimated Volume (gallons)	Description	Mitigation Completed	Mitigation Planned
Structure C1-5 (44/54 Allen St)	Discharge directly from pipe/structure	1/10/2024	6:30 AM	1/12/2024	5:30 AM	47hr	1,410,000	Heavy rain event causing surcharging sewer manholes		Continue with I&I corrections in system.
Structure C1-6 (54 Allen Street)	Discharge directly from pipe/structure	1/10/2024	6:30 AM	1/12/2024	5:30 AM	47hr	705,000	Heavy rain event causing surcharging sewer manholes		Continue with I&I corrections in system.
Structure S1-113 (Jay Street)	Discharge directly from pipe/structure	1/10/2024	6:30 AM	1/10/2024	12:30 PM	6hr	36,000	Heavy rain event causing surcharging sewer manholes		Continue with I&I corrections in system.
Structure S1-102 (Arnold Street)	Surcharging manhole, pumped from MH to river	1/10/2024	6:30 AM	1/10/2024	11:30 PM	17hr	858,000	Heavy rain event causing surcharging sewer manholes		Continue with I&I corrections in system.
Structure C1-5 (44/54 Allen St)	Discharge directly from pipe/structure	1/13/2024	8:00 AM	1/14/2024	11:30 PM	39hr 30min	81,000	Heavy rain event causing surcharging sewer manholes		Continue with I&I corrections in system.
Structure C1-6 (54 Allen Street)	Discharge directly from pipe/structure	1/13/2024	8:00 AM	1/14/2024	11:30 PM	39hr 30min	355,920	Heavy rain event causing surcharging sewer manholes		Continue with I&I corrections in system.
Structure S1-113 (Jay Street)	Discharge directly from pipe/structure	1/13/2024	9:30 AM	1/13/2024	12:30 PM	3hr	12,000	Heavy rain event causing surcharging sewer manholes		Continue with I&I corrections in system.
Structure S1-102 (Arnold Street)	Surcharging manhole, pumped from MH to river	1/13/2024	9:00 AM	1/13/2024	10:00 PM	13hr	535,200	Heavy rain event causing surcharging sewer manholes		Continue with I&I corrections in system.
Structure C1-5 (44/54 Allen St)	Discharge directly from pipe/structure	3/23/2024	11:00 PM	3/24/2024	11:00 PM	24hr	720,000	Heavy rain event causing surcharging sewer manholes		Continue with I&I corrections in system.
Structure C1-6 (54 Allen Street)	Discharge directly from pipe/structure	3/23/2024	11:00 PM	3/24/2024	11:00 PM	24hr	720,000	Heavy rain event causing surcharging sewer manholes		Continue with I&I corrections in system.
Structure S1-102 (Arnold Street)	Surcharging manhole, pumped from MH to river	3/23/2024	11:00 PM	3/24/2024	1:00 AM	2hr	90,000	Heavy rain event causing surcharging sewer manholes		Continue with I&I corrections in system.
Structure C1-5 (44/54 Allen St)	Discharge directly from pipe/structure	3/28/2024	9:00 PM	3/31/2024	1:00 AM	52hr	1,560,000	Heavy rain event causing surcharging sewer manholes		Continue with I&I corrections in system.
Structure C1-6 (54 Allen Street)	Discharge directly from pipe/structure	3/28/2024	9:00 PM	3/31/2024	2:00 AM	53hr	556,000	Heavy rain event causing surcharging sewer manholes		Continue with I&I corrections in system.
Structure S1-102 (Arnold Street)	Surcharging manhole, pumped from MH to river	3/29/2024	5:00 AM	3/31/2024	1:00 AM	44hr	900,000	Heavy rain event causing surcharging sewer manholes		Continue with I&I corrections in system.
Structure C1-5 (44/54 Allen St)	Discharge directly from pipe/structure	4/4/2024	7:30 AM	4/6/2024	3:00 AM	43hr 30min	1,224,000	Heavy rain event causing surcharging sewer manholes		Continue with I&I corrections in system.
Structure C1-6 (54 Allen Street)	Discharge directly from pipe/structure	4/4/2024	7:30 AM	4/6/2024	3:00 AM	43hr 30min	438,000	Heavy rain event causing surcharging sewer manholes		Continue with I&I corrections in system.
Structure G1-37 (Arnold Street)	Discharge directly from pipe/structure	4/4/2024	10:30 AM	4/4/2024	1:30 PM	3hr	9,000	Heavy rain event causing surcharging sewer manholes		Continue with I&I corrections in system.
							10,210,120			

SSO Location	Discharge Statement	Date Start	Time Start	Date End	Time End	Duration	Estimated Volume (gallons)	Description	Mitigation Completed	Mitigation Planned
Structure C1-5 (44/54 Allen St)	Discharge directly from pipe/structure	1/26/2023	3:00 AM	1/27/2023	3:00 PM	36 hr	2163000	Heavy rain event causing surcharging sewer manholes; potentially high groundwater from previous rain events		Continue with I&I corrections in system.
Structure C1-6 (54 Allen Street)	Discharge directly from pipe/structure	1/26/2023	4:30 AM	1/27/2023	11:00 AM	30 hr 30 min	1098000	Heavy rain event causing surcharging sewer manholes; potentially high groundwater from previous rain events		Continue with I&I corrections in system.
Structure S1-113 (Jay Street)	Discharge directly from pipe/structure	1/26/2023	5:45 AM	1/26/2023	12:00 PM	6 hr 15 min	3750	Heavy rain event causing surcharging sewer manholes; potentially high groundwater from previous rain events		Continue with I&I corrections in system.
Structure C1-5 (44/54 Allen St)	Discharge directly from pipe/structure	3/14/2023	10:30 AM	3/16/2023	2:00 PM	39hr 30 min	255000	Heavy rain event causing surcharging sewer manholes; potentially high groundwater from previous rain events		Continue with I&I corrections in system.
Structure C1-6 (54 Allen Street)	Discharge directly from pipe/structure	3/14/2023	10:30 AM	3/16/2023	11:00 AM	48hr 30 min	1093500	Heavy rain event causing surcharging sewer manholes; potentially high groundwater from previous rain events		Continue with I&I corrections in system.
Structure S1-113 (Jay Street)	Discharge directly from pipe/structure	3/14/2023	10:30 AM	3/15/2023	1:30 AM	15hr	25560	Heavy rain event causing surcharging sewer manholes; potentially high groundwater from previous rain events		Continue with I&I corrections in system.
Structure C1-5 (44/54 Allen St)	Discharge directly from pipe/structure	12/18/2023	1:00 PM	12/19/2023	2:00 AM	13hr	39000	Heavy rain event causing surcharging sewer manholes		Continue with I&I corrections in system.
Structure C1-6 (54/94 Allen Street)	Discharge directly from pipe/structure	12/18/2023	1:00 PM	12/19/2023	2:00 AM	13hr	74100	Heavy rain event causing surcharging sewer manholes		Continue with I&I corrections in system.

SSO Location	Discharge Statement	Date Start	Time Start	Date End	Time End	Estimated Volume (gallons)	Description	Mitigation Completed	Mitigation Planned
Storrs Avenue at Abbott Street	Pumped into catch basin	2022-02-18	6:00 PM	2022-02-19	4:00 AM	30000	Broken sewer required bypass pumping during repair	Broken sewer repaired	
Storrs Avenue at Abbott Street	Pumped into catch basin	2022-02-18	8:00 PM	2022-02-19	12:00 AM	10800	Broken sewer required bypass pumping during repair	Broken sewer repaired	

SSO Location	Discharge Statement	Date Start	Time Start	Date End	Time End	Estimated Volume (gallons)	Description	Mitigation Completed	Mitigation Planned
9 Jay Street	Pumped into swamp	2021-07-09	2:00 PM	2021-07-10	4:15 AM	609000	Heavy rain event causing surcharging sewer manholes as well as high groundwater from past rainfall		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
635 Union Street	Pumped into catch basin	2021-07-09	2:35 PM	2021-07-09	10:50 PM	148500	Heavy rain event causing surcharging sewer manholes as well as high groundwater from past rainfall		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
308 Pearl Street	Pumped into river	2021-07-09	3:00 PM	2021-07-10	1:00 AM	180000	Heavy rain event causing surcharging sewer manholes as well as high groundwater from past rainfall		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
54 Allen Street	Pumped into Monatiquot	2021-07-09	3:30 PM	2021-07-11	3:30 AM	864000	Heavy rain event causing surcharging sewer manholes as well as high groundwater from past rainfall		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
6 Arnold Street	Pumped into Monatiquot	2021-07-09	5:30 PM	2021-07-10	4:00 AM	441000	Heavy rain event causing surcharging sewer manholes as well as high groundwater from past rainfall		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
54 Allen Street	Pumped into Monatiquot	2021-09-02	7:00 AM	2021-09-03	9:00 PM	2736000	Heavy rain event causing surcharging sewer manholes as well as high groundwater from past rainfall		Partially I&I and MWRA capacity. Continue with I&I corrections in system.

SSO Location	Discharge Statement	Date Start	Time Start	Date End	Time End	Estimated Volume (gallons)	Description	Mitigation Completed	Mitigation Planned
54 Allen St.	Pumped from SMH directly to Monatiquot River	2020-04-05	6:00 AM		6:00 PM	840000	Heavy rain event causing surcharging sewer manholes as well as high groundwater from past rainfall		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Intersection of Frederick Rd and Hancock	effluent from joints in sanitary line leaking into drain line below	2020-11-03	NA	2021-05-28	7PM	unknown	effluent from joints in sanitary line leaking into drain line below	5/28/2021	Lining of sanitary sewer line
Commerce Park Sewer Pump Station	Broken force main directly to Smelt Brook	2020-11-06	7:15 AM	2020-11-06	4:00 PM	59063	Force main break	Immediate repair planned	Contractor to fix main. Vactor trucks pumping wet well and disposing of waste at offsite facility
54 Allen St.	Pumped from SMH directly to Monatiquot River	2020-12-05	9:30 PM	2020-12-06	3:30 AM	432000	rain event		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Commerce Park Sewer Pump Station	Force main leaking to wetlands upstream of Pond Meadow	2020-12-10	8:30 AM			negligible	Force main leak	Repaired	
54 Allen St.		2020-12-25	2:30 PM	2020-12-26	11:30 AM	1512000	Heavy rain event causing surcharging sewer manholes as well as high groundwater from past rainfall		Partially I&I and MWRA capacity. Continue with I&I corrections in system.

SSO Location	Discharge Statement	Date Start	Time Start	Date End	Time End	Estimated Volume (gallons)	Description	Mitigation Completed	Mitigation Planned
44 Allen St. at rear of building	Pumped from SMH direc	2019-04-23	12:30 AM	2019-04-24	4:30 AM	2016000	Heavy rain event causing surcharging sewer ma .		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Jay St. - easement at end of cul-de-sac	Pumped from SMH into	2019-04-23	12:45 AM	2019-04-23	11:45 AM	213000	Heavy rain event causing surcharging sewer ma .		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Commerce Park Sewer Pump Station	Force Main break - pumj	2019-11-16	12:30 AM	2019-11-16	5:30 AM	112500	Broken force main	Repaired sewer force main as soon as possible	.
Lenox Farms - 550 Liberty St.	From SMH to ground sur	2019-11-29	1:00 PM	2019-11-29		unknown	Broken pipeline	Private contractor repaired broken pipe as soon as possible	.

SSO Location	Discharge Statement	Date Start	Time Start	Date End	Time End	Estimated Volume (gallons)	Description	Mitigation Completed	Mitigation Planned
Nickerson Rd. between #29 & #35	Pumped from SMH to CB (MS4) eventually to the Monatiquot River	2018-01-13	9:00 AM	2018-01-13	6:00 PM	162000	Heavy rain and snowmelt causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Jay St. - easement at end of cul-de-sac	Pumped from SMH into wetland resource area upstream of Monatiquot River	2018-01-13	2:00 AM	2018-01-13	7:00 PM	306000	Heavy rain event and snowmelt causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
44 Allen St. at rear of building	Pumped from SMH directly to Monatiquot River	2018-01-13	1:00AM	2018-01-14	6:00 AM	2610000	Heavy rain event and snowmelt causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
660 Union St., Trotters Green residential complex	Pumped from SMH to CB that discharges to Monatiquot River	2018-01-13	2:00 AM	2018-01-14	1:00AM	414000	Heavy rain event and snowmelt causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Arnold St. at Adams St., SE corner	Directly to Monatiquot River	2018-01-13	10:30 AM	2018-01-13	2:00 PM	288000	Heavy rain event and snowmelt causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
44 Allen St. at rear of building	Pumped from SMH directly to Monatiquot River	2018-03-02	3:00 PM	2018-03-04	6:00 AM	3510000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Jay St. - easement at end of cul-de-sac	Pumped from SMH into wetland resource area upstream of Monatiquot River	2018-03-02	2:00 PM	2018-03-03	6:00 AM	336000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Arnold St. at Adams St., SE corner	Directly to Monatiquot River	2018-03-02	3:00 PM	2018-03-03	1:00 AM	720000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
660 Union St., Trotters Green residential complex	Pumped from SMH to CB that discharges to Monatiquot River	2018-03-02	4:30 PM	2018-03-03	4:30 AM	216000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
167 Howard St., pump station	Force main break - direct discharge to Hayward Creek	2018-11-03	2:30 PM	2018-11-04	12:30 AM	210000	Emergency by-pass pumping, heavy storm event	Force main replaced	
Farm River Pump Station between #80 & #90 Barstow Dr.	Directly to the Farm River	2018-11-10	3:45 AM	2018-11-10	4:45 AM	1800	Heavy rain event causing surcharging sewer manholes		By-pass pumped with 3" pump @ 300 GPM in order to reduce residential backups
44 Allen St. at rear of building	Pumped from SMH directly to Monatiquot River	2018-11-10	7:00 AM	2018-11-11	6:00 AM	1035000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Jay St. - easement at end of cul-de-sac	Pumped from SMH into wetland resource area upstream of Monatiquot River	2018-11-10	5:30 AM	2018-11-10	9:30 PM	288000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
44 Allen St. at rear of building	Pumped from SMH directly to Monatiquot River	2018-11-16	11:00 AM	2018-11-17	7:00 AM	360000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.

SSO Location	Discharge Statement	Date Start	Time Start	Date end	Time End	Estimated Volume (gallons)	Description	Mitigation Completed	Mitigation Planned
44 Allen St. at rear of building	Pumped from SMH direc	2017-04-01	12:00 PM	2017-04-03	7:00 AM	3870000	Heavy rain event causing surcharging sev	Partially I&I and MWRA capacity.	Continue with I&I corrections in system.
Arnold St. at Adams St., SE corner	Directly to Monatiquot R	2017-04-01	1:00 PM	2017-04-02	1:00 AM	720000	Heavy rain and snowmelt causing surcha	Partially I&I and MWRA capacity.	Continue with I&I corrections in system.
Jay St. - easement at end of cul-de-sac	Pumped from SMH into \	2017-04-01	2:00 PM	2017-04-02	2:00 AM	270000	Heavy rain and snowmelt causing surcha	Partially I&I and MWRA capacity.	Continue with I&I corrections in system.
660 Union St., Trotters Green residential	Pumped from SMH to CE	2017-04-01	12:00 PM	2017-04-02	12:00 AM	396000	Heavy rain and snowmelt causing surcha	Partially I&I and MWRA capacity.	Continue with I&I corrections in system.
80 Common St. pump station	Pumped directly to Towr	2017-04-01	5:00 PM	2017-04-01	10:00 PM	112500	Heavy rain and snowmelt causing surcha	Partially I&I and MWRA capacity.	Continue with I&I corrections in system.

SSO Location

Discharge Date Start Time Start Date end Time End Estimated Description Mitigation Mitigation Planned

no SSO incidents reported in 2016

SSO Location	Discharge Statement	Date	Time Start	Date end	Time End	Estimated Volume (gallons)	Description	Mitigation Completed	Mitigation Planned
44 Allen St. at rear of building	Pumped from SMH directly to Monatiquot River	2015-03-27	3:00 AM	2015-03-28	11:00 PM	3168000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Jay St. - easement at end of cul-de-sac	Pumped from SMH into wetland resource area upstream of Monatiquot River	2015-03-27	4:00 AM	2015-03-28	4:00 PM	504000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
660 Union St., Trotters Green residential complex	Pumped from SMH to CB that discharges to Monatiquot River	2015-03-26	11:00 PM	2015-03-28	6:00 AM	651000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.

SSO Location	Discharge Statement	Date Start	Time Start	Date End	Time End	Estimated Volume (gallons)	Description	Mitigation Completed	Mitigation Planned
44 Allen Street, at rear of building	Pumped from SMH directly to Monatiquot River	2014-03-30	11:30 AM	2014-04-01	9:30 AM	3312000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Jay St. - easement at end of cul-de-sac	Pumped from SMH into wetland resource area upstream of Monatiquot River	2014-03-30	12:00 PM	2014-04-01	8:00 PM	720000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
660 Union St., Trotters Green residential complex	Pumped from SMH to CB that discharges to Monatiquot River	2014-03-30	11:00 AM	2014-04-01	9:00 AM	759000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
44 Allen Street at rear of building	Pumped from SMH directly to Monatiquot River	2014-12-09	3:15 PM	2014-12-12	12:15 PM	4968000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Arnold St. at Adams St., SE corner	Pumped directly to Monatiquot River	2019-12-09	4:00 PM	2014-12-11	12:00 AM	1536000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Jay St. - easement at end of cul-de-sac	Pumped from SMH into wetland resource area upstream of Monatiquot River	2014-12-09	3:00 PM	2014-12-11	9:00 AM	945000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
660 Union St., Trotters Green residential complex	Pumped from SMH to CB that discharges to Monatiquot River	2014-12-09	3:30 PM	2014-12-11	9:30 AM	630000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.

SSO Location	Discharge Statement	Date Start	Time Start	Date End	Time End	Estimated Volume (gallons)	Description	Mitigation Completed	Mitigation Planned
44 Allen Street, at rear of building	Pumped from SMH directly to Monatiquot River	2013-02-27	4:30 PM	2013-03-01	11:30 PM	4644000	Heavy rain event and snow melt causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Arnold St. at Adams St., SE corner	Pumped directly to Monatiquot River	2013-02-27	7:00 PM	2013-02-28	12:00 PM	1224000	Heavy rain event and snow melt causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
660 Union St., Trotters Green residential complex	Pumped from SMH to CB that discharges to Monatiquot River	2013-02-27	4:00 PM	2013-03-01	2:00 AM	510000	Heavy rain event and snow melt causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Jay St. - easement at end of cul-de-sac	Pumped from SMH into wetland resource area upstream of Monatiquot River	2013-02-27	5:00 PM	2013-02-28	5:00 AM	324000	Heavy rain event and snow melt causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
44 Allen Street, at rear of building	Pumped from SMH directly to Monatiquot River	2013-03-12	5:00 PM	2013-03-14	8:00 PM	5508000	Heavy rain event and snow melt causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Arnold St. at Adams St., SE corner	Pumped directly to Monatiquot River	2013-03-12	10:30 PM	2013-03-13	2:30 AM	1656000	Heavy rain event and snow melt causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Arnold St. at Adams St., SE corner	Pumped directly to Monatiquot River	2013-03-13	8:00 AM	2013-03-14	3:00 AM (total of both periods)		Heavy rain event and snow melt causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Jay St. - easement at end of cul-de-sac	Pumped from SMH into wetland resource area upstream of Monatiquot River	2013-03-12	8:30 PM	2013-03-14	12:30 AM	630000	Heavy rain event and snow melt causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
660 Union St., Trotters Green residential complex	Pumped from SMH to CB that discharges to Monatiquot River	2013-03-12	5:00 PM	2013-03-14	4:00 AM	577500	Heavy rain event and snow melt causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
660 Union St., Trotters Green residential complex	Pumped from SMH to CB that discharges to Monatiquot River	2013-06-07	11:30 PM	2013-06-08	6:30 PM	399000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
44 Allen Street, at rear of building	Pumped from SMH directly to Monatiquot River	2013-06-07	11:00 PM	2013-06-08	11:00 PM	1728000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Jay St. - easement at end of cul-de-sac	Pumped from SMH into wetland resource area upstream of Monatiquot River	2013-06-08	12:00 AM	2013-06-09	3:00 AM	81000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
44 Allen Street, at rear of building	Pumped from SMH directly to Monatiquot River	2013-06-14	8:00 AM	2013-06-15	12:00 PM	2016000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Arnold St. at Adams St., SE corner	Pumped directly to Monatiquot River	2013-06-14	7:30 AM	2013-06-15	11:00 PM	2844000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
Jay St. - easement at end of cul-de-sac	Pumped from SMH into wetland resource area upstream of Monatiquot River	2013-06-14	7:45 AM	2013-06-15	11:45 PM	1080000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.
660 Union St., Trotters Green residential complex	Pumped from SMH to CB that discharges to Monatiquot River	2013-06-14	8:00 AM	2013-06-16	2:00 AM	882000	Heavy rain event causing surcharging sewer manholes		Partially I&I and MWRA capacity. Continue with I&I corrections in system.