


# Town of Braintree



## Americans with Disabilities Act



## Self-Assessment and Transition Plan

*DRAFT*

April 26, 2019

Kristen Zechello

A.D.A. Coordinator

kzechello@braintreema.gov

## Table of Contents

<b>I.</b>	<b>Description and Introduction.....</b>	<b>1</b>
<b>II.</b>	<b>Legislative Mandates.....</b>	<b>3</b>
	<b><i>A. Five Administrative Requirements of for Public Entities.....</i></b>	<b><i>4</i></b>
	<b><i>B. ADA Self-Evaluation and Transition Plan</i></b>	
	1. Requirements and Process.....	6
	2. Discrimination and Accessibility.....	7
	3. Undue Burden.....	8
<b>III.</b>	<b>Self-Evaluation.....</b>	<b>9</b>
	<b><i>A. Inventory of Town Realty Holdings and Property Assessment.....</i></b>	<b><i>9</i></b>
	1. Braintree Electric Light Department.....	13
	2. Department of Elder Affairs.....	15
	3. Department of Public Works.....	16
	a) Cemetery Division.....	16
	b) Municipal Golf Course / Clubhouse / Offices.....	17
	c) Harbor Master / Yacht Club.....	18
	d) Highway & Grounds Division.....	19
	e) Engineering and Water & Sewer Divisions.....	20
	f) Recreation & Community Events Division.....	22
	4. Fire Department.....	44
	5. General Government.....	46
	6. Thayer Public Library.....	52

7. Police Department.....	53
8. School Department.....	55

**B. Town Policies, Programs and Services by Department.....75**

1. Town Policies
2. \*Department Programs and Services Questionnaire

*\*Remainder of Data Collection by Department to be completed by May 2018*

**C. Public Right of Way (Pedestrian Access, Roadways and Municipal Parking).....77**

1. Engineering Division – \*P.R.O.W. Standards
  - a) Standard Operating Practices for ADA Compliance in the 100 Roads Program
  - b) Standard Operating Practices for ADA Compliance on Town Roadway Construction Projects

*\*Remainder of Data Collection to be completed by June 2018 (complete sidewalk assessment by StreetScan Development currently being procured – see proposal for the Town of Braintree)*

2. Municipal Parking Lots

*\*Self-Assessment Data Collection of these areas to be completed by June 2018*

**D. Transition Plan.....77**

*\*To be completed once all Self-Assessment requirements and recommendations have been satisfied.*

**E. Public Outreach.....77**

*\*To be completed once all Self-Assessment and Transition Plan requirements and recommendations have been satisfied.*

## **I. Description and Introduction**

The American with Disabilities Act (ADA) is a comprehensive civil rights law for persons with disabilities in both employment and the provision of goods and services. The ADA states that its purpose is to provide a "clear and comprehensive national mandate for the elimination of discrimination against individuals with disabilities." Congress emphasized that the ADA seeks to dispel stereotypes and assumptions about disabilities and to assure quality of opportunity, full participation, independent living, and economic self-sufficiency for people with disabilities.

This ADA Self-Evaluation and Transition Plan are being prepared to partially fulfill the requirements set forth in Title II of the Americans with Disabilities Act, "Non-Discrimination on the Basis of Disability in State and Local Government Services.

The ADA states that a public entity must reasonably modify its policies, practices, or procedures to avoid discrimination against people with disabilities. This report will assist the Town of Braintree to identify policy, program, and physical barriers to accessibility and to develop barrier removal solutions that will facilitate the opportunity of access to all individuals.

This report reflects an evaluation of the relative state of municipal buildings, structures and properties open to and for employment by the general public from the perspective of accessibility. Its purpose is to identify any deficiencies and/or impediments which would otherwise compromise public access to municipal buildings, access to programs offered by the Town to area residents and employment opportunities within the established limitations of specific job titles developed by the Human Resources Department.

Remaining to be assessed are the balance of Town policies, services and programs by Department as well as the Public Right of Way (or PROW).

As an addendum to this report, site photos, locus plans and additional plan information relating to any deficiencies or impediments are attached.

## II. Legislative Mandates

The development of a Transition Plan is a requirement of the federal regulations implementing the Rehabilitation Act of 1973, which requires that all organizations receiving federal funds make their programs available without discrimination toward people with disabilities. The Act, which has become known as the "civil rights act" of persons with disabilities, states that:

*No otherwise qualified handicapped individual in the United States shall, solely by reason of handicap, be excluded from the participation in, be denied the benefits of, or be subjected to discrimination under any program or activity receiving federal financial assistance. (Section 504)*

Subsequent to the enactment of the Rehabilitation Act, Congress passed the Americans with Disabilities Act on July 26, 1990. Title II of the ADA covers programs, activities, and services of public entities. The Department of Justice's Title II regulation adopts the general prohibitions of discrimination established under Section 504 and incorporates specific prohibitions of discrimination for the ADA. Title II provides protections to individuals with disabilities that are at least equal to those provided by the nondiscrimination provisions of Title V of the Rehabilitation Act. Specifically, a public entity may not, either directly or through contractual arrangements, do any of the following:

- Deny persons with disabilities the opportunity to participate as members of advisory boards and commissions.
- Deny persons with disabilities the opportunity to participate in services, programs, or activities that are not separate or different from those offered others, even if the Town offers permissibly separate or different activities.
- In determining the location of facilities, make selections that have the effect of excluding or discriminating against persons with disabilities.

Title II of the ADA provides that public entities must identify and evaluate all programs, activities and services and review all policies, practices, and procedures that govern administration of the entity's programs, activities, and services. This report and certain documents incorporated by reference, partially establishes the Town of Braintree's ADA Self-Evaluation and recommendations to achieve compliance. Upon completion of Self-Assessment, the Transition Plan phase to include public comment, completion timeline establishments, responsible staff and designation of funding sources can begin.

***A. The Five (5) Administrative Requirements of the Americans with Disabilities Act, ADA, for public entities***

The Americans with Disabilities Act, ADA, is federal civil rights law. The ADA outlines obligations for Title II, state & local governments, and chief among these are a municipalities duty to provide access and opportunity to their facilities, programs, services, and activities for all members of the public. Further, Title II of the ADA requires that state and local government entities do not discriminate against people with disabilities in their facilities, programs, services, and activities. ADA, Title II implementing regulations require that state and local governments take the following five steps to bring a "public entity" (aka "municipality" and/or City & Town) into compliance with the law:

**1. Designate a Responsible Employee:**

Any municipality with fifty or more employees must designate at least one employee to coordinate ADA compliance (i.e. the "ADA Coordinator"). 28 CFR §35.107(a).

- ***(See Exhibit #1, ADA Coordinator Job Description and press release)***

**2. Provide Notice of ADA Requirements:**

All municipalities regardless of size must provide information to employees, participants, applicants and other interested parties regarding the rights and protections afforded by Title II, including

information about how the Title II requirements apply to its particular programs, services, and activities. 28 CFR §35.106.

- *(See Exhibit #2, Public Notice)*

### **3. Establish a Grievance Procedure:**

All municipalities with fifty or more employees must adopt and publish grievance procedures providing for prompt and equitable resolution of grievances arising under Title II, and municipalities with fewer than fifty employees must still resolve complaints. 28 CFR §35.107(b).

- *(See Exhibit #3, Grievance Procedure)*

### **4. Conduct a Self-Evaluation:**

All municipalities-regardless of size-must conduct a comprehensive review of the entity’s buildings and properties, current policies and practices, including communications and employment through a “self-evaluation.” 28 CFR §35.105.

- *This self- evaluation is partially complete. Facilities and property and some policies have been evaluated however, the Public Right of Way (i.e. sidewalks, curb ramps and crosswalks) must still be assessed. The 100 Roads Program is an ongoing means of addressing barrier removal as our roadways are reconstructed.*

### **5. Develop a Transition Plan:**

Municipalities with fifty or more employees must develop a transition plan when structural changes to existing facilities are necessary in order to make a program, service, or activity accessible to people with disabilities. 28 CFR §35.150(d).

- *The transition plan component is not complete.*

## ***B. ADA Self-Evaluation and Transition Plan***

### **1. Requirements and Process**

The Self-Evaluation is the Municipality's assessment of its current property and facilities, policies, practices, and procedures. The Self-Evaluation identifies and makes recommendations to correct physical barriers and those policies and practices that are inconsistent with Title II requirements. As part of the Self-Evaluation, the Town of Braintree:

- Will identify the Town's properties and facilities, programs, activities, and services; and
- Will review the policies, practices, and procedures that govern the administration and management of the Town's properties and facilities, programs, activities, and services.

The ADA sets forth specific requirements for preparation of an acceptable Transition Plan. This plan must include:

- A list of the physical barriers in the Town's facilities that limit the accessibility of its programs, activities, or services to individuals with disabilities.
- A list of programmatic limitations that must be revised in order to comply with ADA.
- A detailed outline of the methods to be used to remove these physical and programmatic barriers and make the facilities and services accessible.
- Planning level cost estimates for changes and identification of funding sources.
- A schedule for taking the steps necessary to achieve compliance with the ADA, Title II.
- The name of the individual responsible for each component of plan's implementation.

## 2. Discrimination and Accessibility

There are two kinds of accessibility:

- Program accessibility
- Physical accessibility

Absence of discrimination requires that both types of accessibility be provided. Programmatic accessibility includes physical accessibility, but also entails all of the policies, practices, and procedures that permit people with disabilities to participate in programs and to access important information. Physical accessibility requires that a facility be barrier-free. Barriers include any obstacles that prevent or restrict the entrance to or use of a facility. Program accessibility requires that individuals with disabilities be provided an equally effective opportunity to participate in or benefit from a public entity's programs and services. Program accessibility may be achieved by either structural or non-structural methods. Non-structural methods include acquisition or redesign of equipment, assignment of aides to beneficiaries, and provision of services at alternate sites. Programs offered by the Town to the public must be accessible. Accessibility includes advertisement, orientation, eligibility, participation, testing or evaluation, physical access, provision of auxiliary aids, transportation, policies, and communication. The Town may achieve program accessibility by a number of methods:

- Structural methods such as altering an existing facility
- Acquisition or redesign of equipment
- Assignment of aides
- Providing services at alternate accessible sites

When choosing a method of providing program access, the Town will give priority to the one that results in the most integrated setting appropriate to encourage interaction among all users, including

individuals with disabilities. In compliance with the requirements of the ADA, the Town must provide equality of opportunity.

### **3. Undue Burden**

The Town is not required to take any action that it can demonstrate would result in a fundamental alteration in the nature of its program or activity, would create a hazardous condition resulting in a direct threat to the participant or others, or would represent an undue financial and administrative burden. The determination that an undue burden would result must be based on an evaluation of all resources available for use in the Town. For example, if a barrier removal action is judged unduly burdensome, the Town must consider other options for providing access to the benefits and services of the program or activity by individuals with disabilities.

## II. Self-Evaluation

### *A. Inventory of Town Realty Holdings and Property Assessment*

This portion of the Transition Plan's Self-Evaluation report reflects the relative state of the facilities owned and operated by the Town of Braintree. This report includes assessment and recommendations for improvement in municipal buildings, structures and properties open to and for employment by the general public from the perspective of accessibility. Its purpose is to identify any deficiencies and/or impediments which would otherwise compromise public access to municipal buildings, access to programs offered by the Town to area residents and employment opportunities within the established limitations of specific job titles developed by the Human Resources Department.

As an addendum to this report, site photos, locus plans and additional plan information relating to any deficiencies or impediments are attached.

---

### **Braintree Electric Light Department**

Offices, Warehouses & Power Plant – 150 Potter Drive  
Former Offices, Warehouse – 44 Allen Street (**Currently Archived**)  
Electrical Sub Stations – 319 Plain Street, 250 Granite Street, 521  
Grove Street, 41 Adams Street, 161 Edgehill Road, 125 Union Street.

### **Department of Elder Affairs**

Offices & Community Center – 91 Cleveland Avenue

### **Department of Public Works**

## **Cemetery Division**

Offices – 319 Plain Street

Cemeteries – Plain Street, Elm Street, Pond Street

## **Municipal Golf Course**

Club House, Offices & Repair Garage – 101 Jefferson Street

## **Harbor Master/Yacht Club**

Club House & Offices – 9 Gordon Road

## **Highway & Grounds Division**

Offices & Repair Garage - 245 Union Street

## **Engineering Division**

Offices – 85 Quincy Avenue

## **Water & Sewer Division**

Offices – 85 Quincy Avenue

Repair Garage – 277 Union Street

Sub Stations – Plain Street, Common Street, Washington Street, King Hill Road

Water Towers – West Street, Water Street, Lincoln Street, Penn's Hill

## **Recreation & Community Events Division**

Offices – 85 Quincy Avenue

Sunset Lake Gazebo, Boat House & Bathrooms – 30 Safford Street

Repair Garage – 247 Union Street

Daughraty Gym – 546 Washington Street

Parks / Playgrounds –

*Abraham Lincoln Park (Across from 179 Hobart Street)*

*Berwick Park (Berwick Street)*

*Davis Playground (Faxon Street)*

*Dyer Hill Playground (Adjacent to 1251 Washington Street)*

*French's Common (1 JFK Memorial Drive)*

*Furlong Park (Intersection of Pond & Washington Streets)*  
*Leon Harris Playground (Adjacent to 14 Perry Street)*  
*Highlands Park (2001 Washington Street), Sunset Lake (30 Safford Street)*  
*Hollingsworth Park (382 Pond Street)*  
*Hollis Playground (482 Washington Street)*  
*Jonas Perkins Park (Intersection of Liberty & Commercial)*  
*Smith's Beach (Vinedale Road)*  
*Mattulina Park (Kendall Avenue)*  
*Noah Torrey Park (90 Pond Street)*  
*Penniman Park (71 Cleveland Ave)*  
*Watson Park (9 Gordon Road)*  
*Windfield Adams Playground (Across from 479 Commercial St.)*

## **Fire Department**

Head Quarters & Station – 1 Union Place  
Fire Station – 1 Hayward Street  
Fire Station – 1625 Washington Street

## **General Government**

Town Hall – 1 J.F.K. Memorial Drive  
Old Thayer Library – 2 J.F. K. Memorial Drive (**Currently Archived**)  
Art Center – 2001 Washington Street  
Social Service Center – 74 Pond Street  
American Legion Hall – 435 Washington Street  
Vacant Building – 90 Pond Street

## **Thayer Public Library**


Main Library Building – 798 Washington Street

## **Police Department**


Head Quarters – 282 Union Street  
Dog Pound – 247A Union Street

### **School Department**


Administration - 348 Pond Street  
Braintree High School – 128 Town Street  
East Middle Street – 305 River Street  
Elderidge Elementary School – 46 Lincoln Street  
Flaherty Elementary School – 99 Lakeside Drive  
Foster Elementary School – Foster Road  
Highlands Elementary School – 144 Wildwood Street  
Hollis Elementary School – 482 Washington Street  
Liberty Elementary School – 49 Proctor Road  
Maintenance Building – 300 River Street  
Monatiquot Elementary School – 25 Brow Avenue  
Morrison Elementary School – 260 Liberty Street  
Ross Elementary School – 20 Hayward Street  
South Middle School – 232 Peach Street



**Braintree Electric Light Department (Former) Offices**  
44 Allen Street



Braintree Electric Light Department (Former) Offices  
44 Allen Street



**Braintree Electric Light Department Offices**  
150 Potter Drive



## 1. Braintree Electric Light Department

The Public realty holdings for Braintree Electric Light Department (B.E.L.D.) which qualify for consideration in meeting the standards of public accessibility consist of their Office Building located at 150 Potter Drive and their former Offices located at 44 Allen Street.

The balance of properties in the care and custody of B.E.L.D. take the form of the Power Plant, Warehouses and Electric Sub Stations. These properties by virtue of the fact that they do not permit public access and whose employees, by the nature of the required work, as contained within the established job descriptions are exempted from review under this transition plan.

**44 Allen Street** – Since the creation of the current office facilities located at 150 Potter Drive in 1996, the Offices located at 44 Allen Street have been dormant and sealed. It is unclear at this time as to what future use this property will have, however in that access, at present is limited to emergency first response personnel, no evaluation of this property was conducted, at this time. However it should be made clear that if the Town were to sell or otherwise re-commission this property and whose subsequent use was that of a “Public” nature, full accessibility would be required.


**150 Potter Drive** – The current B.E.L.D. offices/customer service center is located in a two story structure located at the end of Potter Drive adjacent to the main power plant and accessory warehouse structures. The parking lot contains a total of 79 Parking spaces with one public and one employee entry. Both entries are at grade with doorways providing accessible door opening hardware operating within allowable pressures. Accessible parking spaces take the form of two van accessible and two regular accessible parking spaces which are split between the two entries. The building is equipped with an elevator providing access to both floor levels. Handicapped bathrooms for both men and women are

provided and all interior doorways and corridors meet accessibility standards.

**Recommendations:** No required improvements to this facility have been deemed necessary at this time.



Department of Elder Affairs Offices & Community Center  
91 Cleveland Avenue




## **2. Department of Elder Affairs**

The Public realty holdings for the Department of Elder Affairs are in the form of their offices and community center located at 91 Cleveland Avenue.


**91 Cleveland Avenue** – The Department of Elder Affairs is contained within a single story building which was formerly the annex to the Penniman Elementary School. The entry to this building is at grade with the door hardware, width and opening pressure meeting accessibility standards. There are men's and women's accessible bathrooms provided and all interior corridors and doorways are compliant. Off street parking facilities consist of a paved parking lot containing 25 dedicated spaces with one van and one regular accessible parking space provide adjacent to the main entry.


### **Recommendations:**

- Paved accessible route to parking lot and park/open space areas is in disrepair and uneven. Should be re-paved to meet MAAB requirements for accessible route (1:20 slope and a cross-slope no greater than 2%).
- No proposed modifications to this facility are necessary.




Cemetery Office  
319 Plain Street









Plain Street Cemetery




Plain Street Cemetery



Elm Street Cemetery





Pond Street Cemetery



## **Department of Public Works**

### **a) Cemetery Division**

The public realty holdings for the Cemetery Division of the Department of Public Works (D.P.W.) take the form of the Cemetery Offices located at 319 Plain Street along with three public cemeteries located on Plain, Elm and Pond Streets.

**319 Plain Street** – The Cemetery Division offices located within the Plain Street Cemetery consist of an elevated office trailer which is adjacent to an equipment repair garage. Access for a person with disabilities is currently not available and as such the following recommendations to provide accessibility are hereby made.

#### **Recommended Improvements:**

- Creation of entry ramp and platform to office trailer along with the establishment of a van accessible parking space.


**Plain Street, Elm Street, Pond Street Cemeteries** – All three sites provide paved vehicular travel paths without dedicated parking. The topography for most of these properties is level.

#### **Recommendations:**

- Provide portable accessible walkway as needed



**Braintree Municipal Golf Clubhouse & Offices**  
101 Jefferson Street



**Braintree Municipal Golf Clubhouse & Offices**  
101 Jefferson Street

## **Municipal Golf Course / Clubhouse / Offices**


The public realty holdings for the Municipal Golf Course consists of the Clubhouse and Office building located at 101 Jefferson Street along with a repair garage facility

The repair facility, by virtue of the fact that it does not permit public access and whose employees by the nature of the required work as contained within their establish job descriptions exempts this structure from review under this transition plan

**101 Jefferson Street** – The Municipal Golf Course Clubhouse and Offices are located in a grade level single story structure. With separate entries to the Clubhouse and Offices, both provide accessible hardware with acceptable opening pressures. The interior corridors and doors within the Clubhouse facilities meet accessibility requirements and an accessible men’s and women’s bathroom is provided. Off street parking for this facility consist of a paved parking lot in front and to the right side of the Clubhouse structure with a total capacity of 115 spaces. Within these parking areas are currently six designated accessible spaces adjacent to the pedestrian travel path. However in that no access aisle, as prescribed by 521 CMR (Massachusetts Architectural Access Code) are provided at present the following recommendation is made.


### **Recommendations:**

- It is recommended that a re-designation of accessible parking providing the required access aisle be made inclusive of one van accessible space and four regular accessible spaces.



Harbor Master/Yacht Club  
9 Gordon Road

B.




### **C) Harbor Master / Yacht Club**

The public realty holdings for the Harbor Master and Braintree Municipal Yacht Club consist of the Club House/Offices located at 9 Gordon Road along with associated boat slips.

**9 Gordon Road** – The building containing both Harbor Master and Municipal Yacht Club is a two story building with partial basement level used for storage. Entry to the structure is at grade with accessible door width and operating hardware provided allowing the door to open within the opening pressure limitations. Accessible parking is provided immediately adjacent to entry. Access between upper and lower levels is provided by way of an elevator and accessible bathrooms for men and women are provided. There is also a dock/slip area located in the lower parking lot which is provided with an accessible parking space.

**Recommendations:** No proposed alterations are deemed necessary at this time.



**Highway Division Offices & Repair Garage**  
245 Union Street



Highway Division Offices & Repair Garage  
245 Union Street

## **D) Highway & Grounds Division**


The public realty holdings for the Highway Division consist of the Offices and repair/storage garage located at 245 Union Street along with the sand/salt storage building located on the same property.

The sand/salt storage building and repair/storage portion of the main Highway building, by virtue of the fact that it does not permit public access and whose employee's by the nature of the required work as contained within their established job descriptions exempt these structures from review under this transition plan.

**245 Union Street** – The building containing the Highway Division offices is a single story block structure. At present an elevated entry is provided leading to a counter area to which the public is allowed access. The office area also is where clerical support staff is located.

### **Recommendations:**


- Create van accessible parking space adjacent to public entry. Remove existing weather vestibule and create expanded weather vestibule accessed by a ramp with level platform.
- Indent and lower portion of service counter to allow access and maneuverability.
- Remove existing bathroom and use as access way to rear offices.
- Create unisex handicapped bathroom.





Engineering Division  
Water & Sewer Division  
Recreation & Community Events Division

Offices located at 85 Quincy Avenue



## **E) Engineering and Water & Sewer Division Offices**

The public realty holdings for the Engineering and Water & Sewer Division Offices consist of the Main offices located at 85 Quincy Avenue.

Water & Sewer Division property also consists of repair facilities at 277 Union Street, water towers on West Street, Water Street, Lincoln Street and Penn's Hill, sewer lift stations at Plain Street, Common Street, Washington Street and King Hill Road and a water treatment facility on King Hill Road.

The repair facility, water towers, sewer lift stations and water treatment facility by virtue of the fact that they do not permit public access and whose employees by the nature of the required work as contained within their established job descriptions, exempt these structures from review under this transition plan.

**85 Quincy Avenue** – A single story building with finished basement level, the office functions and public access are located on the first floor level with accessible parking, and entry with door hardware, width and opening pressure meeting accessibility standards. Bathrooms facilities for both men and women are provided. Formerly the Watson Public Library, since the re-commissioning of this facility a number of years ago, the lower level has served a separate function, most recently archival storage for the Braintree Historic Commission and now serves as material storage for this division. The lower level is served by a separate parking facility providing accessible parking and also provides an accessible entry. Employees having need to access this level by the nature of the required work as contained within their established job descriptions exempt this portion of the structure from review under this transition plan.

### **Recommendations for 85 Quincy Avenue Offices:**

- Removal of equipment closet located between men's and women's room and reconfiguration of existing fixtures to improve accessibility.

## a) Recreation & Community Events Division


The public realty holdings for the Recreation & Community Events division consists of the Main offices located at 85 Quincy Avenue, Sunset Lake Boat/Bath House located at 30 Safford Street, Repair Garage located at 247 Union Street, Doherty Gym located at 546 Washington Street , Smith's Beach Bathrooms and eighteen parks/playgrounds located throughout the community.

The repair facility building located at 247 Union Street by virtue of the fact that it does not permit public access and whose employee's by the nature of the required work as contained within their established job descriptions exempt this structure from review under this transition plan.

**85 Quincy Avenue** – A single story building with finished basement level, the office functions and public access are located on the first floor level with accessible parking, and entry with door hardware, width and opening pressure meeting accessibility standards. Bathrooms facilities for both men and women are provided. Formerly the Watson Public Library, since the re-commissioning of this facility a number of years ago, the lower level has served a separate function, most recently archival storage for the Braintree Historic Commission and now serves as material storage for this division. The lower level is served by a separate parking facility providing accessible parking and also provides an accessible entry. Employees having need to access this level by the nature of the required work as contained within their established job descriptions exempt this portion of the structure from review under this transition plan.

### **Recommendations for 85 Quincy Avenue Offices:**

- Removal of equipment closet located between men's and women's room and reconfiguration of existing fixtures to improve accessibility.



**Recreation & Community Events Division Office**  
 Remove existing Janitor's closet and extend plumbing wall. Relocate plumbing fixtures and add grab bars. Increase door widths and reverse swing to provide a greater level of accessibility.

Address: 85 QUINCY AVENUE


Scale: 1/4" = 1'-0"

Project: RECREATION & COMMUNITY EVENTS DIVISION OFFICES

Rev.




**Sunset Lake Boat House & Bathrooms**  
30 Safford Street





Sunset Lake / Playground  
30 Safford Street



### **30 Safford Street - Sunset Lake Boat/Bath**

**House/Playground/Gazebo** – The property is irregular in shape but level. The primary surface is a mixture of grass and sand and concrete access paths. Facilities include playground equipment, public bathrooms, beach access and a gazebo. Off street parking is provided by a paved lot containing one hundred and thirteen parking spaces with one van and two regular accessible parking spaces. Property contains a single story block building public access is limited to the bathroom portions of the building. The balance of the building is used for boat storage relating to life guard duties and the instruction in sailing. Employees accessing the boat storage portion of the building by the nature of the required work as contained within their established job descriptions exempt this portion of the structure from review under this transition plan. Bathroom portions of this building provide accessible toilets, sinks and door widths. Door opening pressure and hardware meet accessibility standards.


#### **Recommendations:**

- Relocate paper towel dispenser to accessible height limit.
- Install permanent soap dispenser.
- Provide lever action handles for hot and cold water supply.
- It is recommended that an accessible travel path (compacted stone dust or asphalt) to the playground equipment area be created.
- Accessible play equipment should be added after an analysis to assess minimum number of required ground level play components vs. elevated play components is completed (using 2010 Standards).
- Accessible play surfacing under and around play equipment must be added.
- Multi-sensory play components added for a variety of experiences for users with disabilities.
- Add two additional accessible spaces adjacent to playground area.
- Add striping to left parking space near garage/bathroom structure to ensure accessible route to building from parking lot.

- Because of its close proximity to both a parking lot and a body of water a fence around the playground area is recommended for safety with ADA compliant gate and hardware.



Doherty Gym  
546 Washington Street



Doherty Gym  
546 Washington Street


**546 Washington Street – Daughraty Gym** – A single story gymnasium structure with a finished basement. The basement is designated to be utilized by the Braintree Emergency Management Association and is currently undergoing evaluation for renovations to this area. As such no evaluation of this portion of the building was performed at this time.

**Recommendations:**


- \*Rebuild ramp entry to front doors (*complete*).
- Replace one set of doors with accessible entry.
- \*\*Reconfigure men’s and women’s rooms to provide accessible water closets and sinks (*upgrade complete*).

*\*It should be noted that this rebuild has been completed November 30, 2017.*

*\*\* It should be noted that a unisex accessible single use bathroom facility was added to this building in April 2018.*



Abraham Lincoln Park  
Across from 179 Hayward Street



**Abraham Lincoln Park**  
Across from 179 Hayward Street

*Temporary accessible surfacing is available for use at all outdoor events held on Town properties. The ADA Coordinator facilitates the use and appropriate placement of the temporary access path material and it is installed by Highway Department staff.*

---

*Following lists recommendations for permanent access improvements for all Beaches, Parks and Playgrounds:*

1. **Abraham Lincoln Park (Across from 179 Hobart St.)** – The property is irregularly shaped but level with the back third of the property sloping downward. The primary surface is grass. Facilities at this location include playground equipment along with a basketball court. Parking is limited to on street only.

### **Recommendations:**

- It is recommended that an accessible travel path (compacted stone dust or asphalt) to both the playground equipment area and basketball court be created.
- Accessible play equipment should be added after an analysis to assess minimum number of required ground level play components vs. elevated play components is completed (using 2010 Standards).
- Accessible play surfacing under and around play equipment must be added.
- Multi-sensory play components added for a variety of experiences for users with disabilities.
- Given the topography of the portion of Hobart Street on which the playground fronts, no accessible parking designations are recommended.



Berwick Park  
Berwick Street



Berwick Park  
Berwick Street

**Berwick Park – Berwick Street** – Located at the end of Berwick Street off of Shaw Street, Berwick Park is fairly rectangular in shape but slopes downward from right to left and in the immediate front portion of the lot. The primary surface is grass. Facilities at this location are limited to a basketball court. Parking is limited to on street only.

**Recommendations:**

- It is recommended that an accessible travel path (compacted stone dust or asphalt) to the playground equipment and basketball court be created.
- Accessible play equipment should be added after an analysis to assess minimum number of required ground level play components vs. elevated play components is completed (using 2010 Standards).
- Accessible play surfacing under and around play equipment must be added.
- Multi-sensory play components added for a variety of experiences for users with disabilities.
- Given the narrowness of Berwick Street and the close proximity of residential driveways to the entrance to the park, no accessible parking designations are recommended.



Davis Playground  
Intersection of Faxon & Commercial Streets



Davis Playground  
Intersection of Faxon & Commercial Streets

## **Davis Playground (Intersection of Faxon & Commercial Streets)**


– The property is irregularly shaped but level. The primary surface is grass. Facilities at this location include playground equipments and a basketball court. Parking is limited to on street only.

### **Recommendations:**

- It is recommended that an accessible travel path (compacted stone dust or asphalt) to the basketball court and playground equipment be created.
- Accessible play equipment should be added after an analysis to assess minimum number of required ground level play components vs. elevated play components is completed (using 2010 Standards).
- Accessible play surfacing under and around play equipment must be added.
- Multi-sensory play components added for a variety of experiences for users with disabilities.
- Accessible seating should be added at picnic tables.
- It is also recommended that accessible parking designation along the park side of Faxon Street adjacent to the park entry be established given the relative level topography and width of the roadway.



Dyer Hill Playground  
Adj. to 1251 Washington Street



Dyer Hill Playground  
Adjacent to 1251 Washington Street


**Dyer Hill Playground (Adjacent to 1251 Washington Street)** – The property is irregularly shaped but level. The primary surface is grass with a compacted travel path leading from the park entry to playground equipment. Facilities at this location include playground equipment, and a basketball court. There is room between the play structures for easy movement and access. The picnic tables are located in the grass and do not have a hard surface path leading up to them. Parking is limited to on street only.

### **Recommendations:**

- It is recommended that routine compaction and grading of travel path occur. Given the narrowness of the entry to the park, no accessible parking designations are recommended.
- It is recommended that an accessible travel path (compacted stone dust or asphalt) to the basketball court be created.
- Accessible play equipment should be added after an analysis to assess minimum number of required ground level play components vs. elevated play components is completed (using 2010 Standards).
- Accessible play surfacing under and around play equipment must be added.
- Multi-sensory play components added for a variety of experiences for users with disabilities.



French's Common  
1 J.F.K. Memorial Drive



French's Common  
1 J.F.K. Memorial Drive

**French's Common – 1 J.F.K. Memorial Drive** – The property is irregularly shaped but level. The park has two primary entries on both Tremont Street and JFK Memorial Drive. The primary surface is grass with asphalt access paths leading from Tremont Street to courts and playground equipment. Facilities at this location include playground equipment, basketball and tennis courts, and a baseball field. Parking on the Tremont Street access is limited to on street only with off street parking in the form of the Town Hall parking lot provided at the JFK Memorial Drive entry.

### **Recommendations:**

- It is recommended that an accessible travel path (compacted stone dust or asphalt) to the playground equipment, baseball field, tennis and basketball courts be created.
- It is recommended that an accessible parking space adjacent to the park entry on JFK Memorial Drive be established.
- Accessible play equipment should be added after an analysis to assess minimum number of required ground level play components vs. elevated play components is completed (using 2010 Standards).
- Accessible play surfacing under and around play equipment must be added.
- Multi-sensory play components added for a variety of experiences for users with disabilities.
- Accessible seating should be provided at picnic table area.



Furlong Park  
Intersection of Pond & Washington Streets




**Furlong Park**  
Intersection of Pond & Washington Street

**Furlong Park – 1 Pond Street** – The Park is fairly rectangular in shape but slopes downward at its entry off of both Washington and Pond Street. The primary surface is grass with established pedestrian travel paths. Facilities include benches. No off street parking is provided and given the location of this park at the intersection of Pond and Washington Streets and the established traffic patterns and street width, on street parking is not advised.

**Recommendations:** No recommendations are made at this time.



Highlands Park  
2001 Washington Street



Highlands Park  
2001 Washington Street


**Highlands Park – 2001 Washington Street** – The property is triangular in shape and level. The primary surface is grass with established travel paths. Facilities include playground equipment. The playground is served by an off street parking lot containing 114 spaces with one van accessible and one regular accessible parking space.

**Recommendations:**

- It is recommended that three additional accessible parking spaces and access aisle be created adjacent to park entry.



Hollis Playground  
482 Washington Street



Hollis Playground  
482 Washington Street


**Hollis Playground – 482 Washington Street** – The Park is rectangular in shape and level. The park surface is a mixture of grass, fall safe material and brick pavers. Facilities include playground equipment, basketball and tennis courts. The playground is served by an off street parking lot containing forty parking spaces with one van accessible and two regular accessible parking spaces.

**Recommendations:**

- Accessible play surfacing under and around play equipment must be added.
- It is recommended that accessible travel paths (compacted stone dust or asphalt) to the basketball and tennis courts be created.



Hollingsworth Park  
382 Pond Street




Hollingsworth Park  
382 Pond Street

**Hollingsworth Park – 382 Pond Street** – The Park is irregularly shaped but level. The primary surface is grass. Facilities include baseball fields, accessible bathrooms and a concession stand and a playground area. Artificial turf is the surface at this playground area and some of the play equipment is accessible. The park is served by an off street parking lot containing seventy-five parking spaces with two accessible parking spaces.

### **Recommendations:**

- Create van accessible parking space with access aisle.
- Create compacted stone dust access path to each dugout for players and each “home and visitor” bleachers for spectators at all fields.
- In addition to access path to bleachers, a 5ft. radius HC area adjacent to bleachers is recommended.
- It is recommended that routine compaction and grading of access paths occur.
- Widen all openings to dugout structures to ensure accessible route (36 inch minimum) allowing 18 inches on latch pull side of gates with accessible gate hardware.
- Increase dugout depth to allow for accessible route and turn radius.
- Regrade all dugouts and access paths to ensure flush with grass areas.
- Cut speed humps and add striping to ensure a clearly marked pedestrian passage along drive path.



Jonas Perkins Park  
Intersection of Liberty & Commercial Streets




Jonas Perkins Park  
Intersection of Liberty & Commercial Streets


**Jonas Perkins Park (Intersection of Liberty & Commercial Streets)** – The park is irregularly shaped and slopes upward from Commercial Street to the back of the property. The primary surface is grass. Facilities include benches. The park is served by a small parking lot which does not have striped parking.

**Recommendations:**

- Establish van accessible parking space and access aisle in parking lot and create a travel path from parking lot to benches.
- It is recommended that accessible travel paths (compacted stone dust or asphalt) from parking area to benches be created.



Leon Harris Playground  
Adj. to 14 Perry Street



Leon Harris Playground  
Adj. to 14 Perry Street

**Leon Harris Playground (Adjacent to 14 Perry Street)** – The lot is irregularly shaped and slopes upward toward the back of the property. The primary surface is grass. Facilities include playground equipment and a basketball court. Parking is limited to on street only.


**Recommendations:**

- Accessible routes from the street, grading of the area to include accessible route to proposed equipment and basketball court will be part of the plan.

*It should be noted that there have been capital funds allocated to rebuild this playground and it will comply with ADA Standards for Parks and Playground design (completion expected FY 2018).*



Mattulina Park  
Kendall Avenue



Mattulina Park  
Kendall Avenue


**Mattulina Park – Kendall Avenue** – The Park is rectangular in shape and fairly level. The primary surface is grass. Facilities include benches and picnic tables, baseball field and playground equipment. Parking is limited to on street only. There are openings on both E. Boscobel St. and Kendall Ave. sides of the park that are inaccessible due to a pole in the middle of each opening.

### **Recommendations:**

- It is recommended that an accessible travel path (compacted stone dust or asphalt) to both the playground equipment area and baseball field be created from a barrier-free, compliant gate opening at each side of the park.
- Accessible play equipment should be added after an analysis to assess minimum number of required ground level play components vs. elevated play components is completed (using 2010 Standards).
- Accessible seating at picnic tables should be added.
- Accessible play surfacing under and around play equipment must be added.
- Multi-sensory play components added for a variety of experiences for users with disabilities.
- Establish an accessible on street parking space adjacent to park entry.



Noah Torrey Park  
90 Pond Street




Noah Torrey Park  
90 Pond Street

**Noah Torrey Park – 90 Pond Street** – The Park is irregularly shaped but level. The primary surface is grass. Facilities include a basketball court and playground equipment. Parking for the park is served by a municipal off street parking with accessible parking spaces lot serving Town buildings on the same property.

**Recommendations:**

- It is recommended that an accessible travel path (compacted stone dust or asphalt) to both the playground equipment area and baseball field be created.
- Accessible play equipment should be added after an analysis to assess minimum number of required ground level play components vs. elevated play components is completed (using 2010 Standards).
- Accessible play surfacing under and around play equipment must be added.
- Multi-sensory play components added for a variety of experiences for users with disabilities.
- Establish accessible parking space on street adjacent to playground.



Penniman Park  
71 Cleveland Avenue




Penniman Park  
71 Cleveland Avenue


**Penniman Park – 71 Cleveland Avenue** – The playground is rectangular in shape and has a gradual slope downward from front to back leveling off half way through property. The primary surface is grass. There are benches and picnic tables provided. Facilities include playground equipment, a basketball court and baseball field. Although a portion of the park has an accessible route, this is not connected to the different areas. Parking for the park is served by an off street parking lot containing fifty spaces with one van accessible space and two regular accessible spaces.

### **Recommendations:**

- Designate a parallel parking space adjacent to mid-way point between baseball field and playground equipment as an accessible space.
- Accessible seating at picnic tables should be added.
- Provide accessible travel path (compacted stone dust or asphalt) from parking space to playground equipment, baseball field and basketball court.
- Accessible play equipment should be added after an analysis to assess minimum number of required ground level play components vs. elevated play components is completed (using 2010 Standards).
- Accessible play surfacing under and around play equipment must be added.
- Multi-sensory play components added for a variety of experiences for users with disabilities.




Smith's Beach  
Vinedale Road



**Smith's Beach – Vinedale Road** – The beach property is rectangular in shape and slopes downward from Vinedale Road to median high-tide line. The primary surface is sand. Parking is served by an ancillary parking lot across from the beach entry containing seventy-nine parking spaces. The property also contains a single story block structure providing accessible sink and toilet for both men and women.

**Recommendations:**

- Create accessible “causeway” to median high-tide line.
- Designate one van accessible and two regular accessible parking spaces with access aisle in ancillary parking lot.
- Re-grade access ramp to bathroom entry to eliminate threshold.
- Install portable access walkway seasonally.



Watson Park  
9 Gordon Road




Watson Park  
9 Gordon Road


**Watson Park – 9 Gordon Road** – The property is fairly rectangular in shape and level. The primary surface is grass. Facilities include baseball fields, playground equipment, walking paths and a splash pad. Off street parking is provided by a lot containing thirty-nine parking spaces with one accessible parking space provided. The public can access the park by entering narrow openings in the fence which are not wide enough for a wheelchair to enter. There is an asphalt path leading to several of the baseball seating areas and snack bar/bathroom building however, the seating areas are not accessible. Most of the dugout structures are inaccessible. Inside the park there are no hard surfaces for access to the playing fields and bleachers. There is a path accessing the picnic areas of the park. There is an accessible route from the street to the play area however, no access path around the playground area and there are also no accessible play components.

### **Recommendations:**

- Create one additional accessible parking space and one van accessible parking space with access aisles within the parking lot.
- It is recommended that an accessible travel path (compacted stone dust or asphalt) to both the baseball fields and the splash pad be created.
- Accessible play equipment should be added after an analysis to assess minimum number of required ground level play components vs. elevated play components is completed (using 2010 Standards).
- Accessible play surfacing under and around play equipment must be added.
- Multi-sensory play components added for a variety of experiences for users with disabilities.
- Establish accessible parking space on street adjacent to playground.



Winfield Adams Playground  
Adj. to 479 Commercial Street



Winfield Adams Playground  
Adj. to 479 Commercial Street

## **Winfield/Adams Playground (Adjacent to 479 Commercial Street)**

– The property is fairly rectangular and level. The primary surface is grass. Facilities include a baseball field, playground equipment and a basketball court. Only on street parking exists at this location.

### **Recommendations:**

- Given the width and traffic on Commercial Street no on street accessible parking designation is recommended.
- A pedestrian crosswalk and corresponding curb ramps should be provided at park entrance on Commercial Street.
- It is recommended that an accessible travel path (compacted stone dust or asphalt) to the playground equipment, basketball court and baseball field areas be created through compliant fence openings on Commercial Street.
- Accessible play equipment should be added after an analysis to assess minimum number of required ground level play components vs. elevated play components is completed (using 2010 Standards).
- Accessible play surfacing under and around play equipment must be added.
- Multi-sensory play components added for a variety of experiences for users with disabilities.
- Accessible seating should be provided at picnic tables.

**Pond Meadow Park** - The public can access the park by either foot or vehicle. The parking lot has several accessible spaces. A person with disabilities can access the paved trails easily from the parking lot. The trails and paths are paved with asphalt, except in a few areas where the trails are packed gravel and dirt. The picnic area has one table accessible by wheelchair.

**Conservation Land** - The Town's three main areas of conservation land have very limited parking and no designated accessible spots. Terrain is unimproved and uneven dirt trails.


**Trail & Forest Areas** - Cranberry Pond, Cochato River, Eaton's Pond and Town Forest have unsurfaced trail networks with varying degrees of signage and mapping. These areas have, if any, very limited and unimproved parking. The only accessible nature trails are provided at Pond Meadow Park and parking is accessible.

### **Recommendations for Pond Meadow, Conservation and Trail/Forest Areas:**

- Goals of this plan should be to improve access on these trails by creating firm stable and unobstructed accessible routes as well as provide better parking opportunities at trailheads.
- Every effort to incorporate ADA compliant parking spaces will be made over the course of the plan implementation.
- If bathroom facilities are added, they shall be compliant as well as any portable toilets that are placed seasonally in these areas, shall be HC accessible.





**Braintree Fire Department Headquarters**  
1 Union Place






**Braintree Fire Station**  
1 Hayward Street





**Braintree Fire Station**  
1625 Washington Street



**Braintree Fire Station**  
1625 Washington Street

## **2. Fire Department**

The public realty holdings for the Braintree Fire Department include the Fire Department Headquarters/Central Fire Station located at 1 Union Place, East Braintree Fire Station located at 1 Hayward Street and Highlands Fire Station located at 1625 Washington Street.

Only the office portions of the Fire Department headquarters and fire stations were considered for the purposes of this report. Non-public portions of all fire stations whose employee's by virtue of the nature of the required work as contained within their established job descriptions, exempt portions of these structures from review under this transition plan.

**Fire Department Headquarters – 1 Union Place** – A two story building with permitted public access to the fire alarm/dispatch area on the first floor and civilian staff positions located on the second floor. The balance of the building is used for the storage of equipment and fire fighting personnel.

### **Recommendations:**

- Create van accessible parking space and entrance.
- Install new employee entry and accessible parking space.
- Install limited service elevator to serve first and second floor levels.

**East Braintree Fire Station – 1 Hayward Street** - A two story building with permitted public access to a first floor reception lobby by way of an exterior door bell.

### **Recommendations:**


- Create van accessible parking space in rear parking lot.
- Clear travel path by trimming back bushes along route.

- Elevate travel path and create elevated entry platform in front of reception lobby entrance.

**Highlands Fire Station – 1625 Washington Street** – A two story building with permitted public access to reception lobby on first floor by way of an exterior door bell.


**Recommendations:**

- Create van accessible parking space in parking lot.
- Re-set brick pavers for continuous level pathway, lower portion of counter in reception lobby.




**Fire Department H.Q.(Employee Entry)** – Convert existing garage door to accessible entry door. Install limited service elevator, serving basement, first and Second floor.

Address:	1 UNION PLACE	Scale:	1/8" = 1'-0"
Project:	FIRE DEPARTMENT HEADQUARTERS	Rev.	




Fire Department H.Q.(Public Entry) – Create van accessible parking space

Address:	1 UNION PLACE	Scale:	1/8" = 1'-0"
Project:	FIRE DEPARTMENT HEADQUARTERS	Rev.	



**Braintree Town Hall**  
1 J.F.K. Memorial Drive




**Braintree Town Hall**  
1 J.F.K. Memorial Drive

## **General Government**


The public realty holdings for the General Government include Town Hall at 1 JFK Memorial Drive, Old Thayer Public Library at 2 JFK Memorial Drive, Arts Center at 1969 Washington Street, Social Service Center at 74 Pond Street and American Legion Hall at 435 Washington Street

**Braintree Town Hall\* – 1 JFK Memorial Drive** – A two story building with finished basement allowing for public access to all three levels. Access to two of the four public entrances is provided by way of ramps. A combination of an elevator and ramp provide access to all portions of Town Hall. Accessible bathroom facilities are provided.

**Recommendations:** No changes are deemed necessary and as such no recommendations are made at this time.



Old Thayer Public Library  
2 J. F. K. Memorial Drive



**Old Thayer Public Library\* – 2 JFK Memorial Drive** – A two story structure with partial finished basement.


**Recommendations:** In that the property is currently archived and no public or employee access is provided. No recommendations for improvements are made at this time. However upon re-commission of this facility, full accessibility will be required.

*\*It should be noted that currently both the Town Hall and Old Thayer Library are being analyzed and an architectural firm is under contract to develop a plan which will improve accessibility and connectivity to both buildings. Under the proposed plan, Old Thayer Library will be made fully accessible and is intended be used as public meeting space. The Braintree Historic Commission and Community Preservation Committee are both participating in this project.*



Braintree Community Arts Center

2001 Washington Street




**Art Center – 1969 Washington Street** – A two story building in which public access is intended to be provided to both levels. There is access to the building by way of a ramped entryway, there are accessible bathrooms and access to both levels by way of a limited service elevator.

**Recommendations:** There are no improvements recommended at this time.



Social Service Center  
74 Pond Street




Social Service Center  
74 Pond Street

**Social Service Center – 74 Pond Street** – A two story building with partial basement. The first story is occupied by a private social service center “Marge Crispin” with the second floor occupied by Braintree Youth Center, DeVanna Center, and Braintree Retirement Board. The Basement serves as space for building utilities only with no public access. Accessible parking in the paved parking lot adjacent to the building is provided. Ramp access to a level platform is provided at main entry with entry door meeting opening pressure, width and hardware as required under accessibility standards. Elevator service provides access to both public levels which are also served by accessible men’s and women’s bathrooms.

**Recommendations:** No changes are deemed necessary and as such no recommendations are made at this time.



American Legion Hall  
435 Washington Street




American Legion Post  
435 Washington Street

**American Legion Hall – 435 Washington Street** – A two story building with first floor occupied by the Braintree American Legion (Post 86). This level provides offices and a meeting hall with a commercial kitchen and unisex bathroom. The second floor is leased to a Dance School and presently only accessible by way of the existing stairway.

**Recommendations:**

- Create van and regular accessible parking space adjacent to accessible entry.
- Create entry ramp and install limited service elevator to second floor.


*\*It should be noted that American Legion Hall is being analyzed and an architectural firm is under contract to develop a plan which will improve accessibility. The Braintree Historic Commission and Community Preservation Committee are both participating in this project.*




**American Legion (Post 86)** – Construct access ramp and platform. Install limited service elevator in lobby to provide access to second floor.

Address: 435 WASHINGTON STREET  
 Project: AMERICAN LEGION (POST 86)

Scale: 1/8" = 1'-0"  
 Rev.




**Vacant Building**  
**90 Pond Street**




**Vacant Building – 90 Pond Street** – The building is a two story, wood frame structure with finished basement, formerly utilized by both private industry (John Hancock Insurance) and Noah Torrey Elementary School. Accessibility is provided by way of an accessible side entry and elevator accessing all public levels (Basement, First and Second Floors). Each floor provides hallways, doors and bathroom facilities which are accessible in terms of surface, width and opening pressure. Off street parking is provided in the front, rear and side of the property along with proportionate accessible parking.

**Recommendations:** While no outstanding deficiencies exist at this facility it should be noted that the Town intends on investigating the possible sale of this property.




**Thayer Public Library**  
798 Washington Street




### 3. Thayer Public Library

The public realty holding for Thayer Public Library consists of a two story structure with a finished basement located at 798 Washington Street. Public access is allowed to all three levels and is provided by way of an elevator. Accessible men's and women's bathrooms are provided and accessible parking is provided.


**Recommendations:** In that the building is compliant with accessibility regulations, no alterations recommendations are proposed at this time.




**Braintree Police Department Headquarters**  
282 Union Street



**Braintree Police Department Headquarters**  
282 Union Street



Dog Pound  
247A Union Street



#### **4. Braintree Police Department**

The public realty holdings for the Braintree Police Department consist of Police headquarters located at 282 Union Street and the Dog Pound located at 247A Union Street. Portions of the Police Headquarters which are limited to Police Officials, who by the nature of the required work as contained within their establish job descriptions exempts those portions of this structure from review under this transition plan.

**Police Headquarters – 282 Union Street** – A single story building with a finished basement, public access and civilian employment is limited to the first floor of the structure. This level is provided with accessible parking along with an entry door with accessible hardware, width and opening pressure. The balance of the building is used for training/ housing of police and ambulance personnel. Public and civilian employee areas are serviced by corridors and doorways meeting accessibility requirements along with accessible restrooms for both men and women.

#### **Recommendations:**

- Convert parking spaces currently reserved for “Watch Commander” & “Street Supervisor” to van and regular accessible parking spaces.
- Re-grade entry walkway and entry platform.
- Replace all internal door knobs with accessible lever action handles.


**Dog Pound – 247A Union Street** – A single story building with accessory chain link holding pens. Public access to the holding pens is permitted and provided by existing walkways.

**Recommendations:**

- Create van accessible parking space adjacent to entry to holding pens.



**Braintree School Administration Offices**  
348 Pond Street



**Braintree School Administration Offices**  
348 Pond Street

## 5. School Department

The public realty holdings for the School Department consist of the school Administrative Building located at 348 Pond Street, Maintenance Building located at 300 River Street, Braintree High School located at 128 Town Street, East Middle School located at 305 River Street, Elderidge Elementary School located at 46 Lincoln Street, Flaherty Elementary School located at 99 Lakeside Drive, Foster Elementary School located at Foster Road, Highlands Elementary School located at 144 Wildwood Street, Hollis Elementary School located at 482 Washington Street, Liberty Elementary School located at 49 Proctor Road, Monatiquot Elementary School located at 25 Brow Avenue, Morrison Elementary School located at 260 Liberty Street, Ross Elementary School located at 20 Hayward Street and South Middle School located at 232 Peach Street.

The School Department Maintenance Facility by virtue of the fact that it does not permit public access and whose employee's by the nature of the required work as contained within their established job descriptions, exempt this structure from review under this transition plan.

**School Administration Building – 348 Pond Street** – A single story building, with an off street parking lot containing 31 parking spaces and providing an accessible parking space adjacent to ramped entry.


### **Recommendations:**

- Create van accessible parking space adjacent to existing accessible parking space and widen access aisle in between.
- Provide signage to both accessible spaces.
- Add access bell at entry.
- Change all existing door knobs to lever action handles.
- Add rear grab bar to both Men's and Women's accessible toilet stalls.

***Preface:*** Please note that the Braintree Public School system does possess a portable lift device that can accommodate all raised platforms in all of the school buildings.



Braintree High School  
128 Town Street




**Braintree High School**  
128 Town Street

**Braintree High School – 128 Town Street** – A three story building with a partial finished basement level. The facility provides accessible front and rear main entries and elevator service to all levels. Paved parking lots existing at the front, rear and left side provide a total of 511 parking spaces. At present, two van accessible and four accessible parking spaces are provided.


### **Recommendations:**

- Create four additional accessible spaces to be located in the rear parking lot.
- Create ramp access or lift for stage in auditorium.
- Change all door knobs to lever action handles.
- Create accessible toilet stall in Men’s and Women’s room adjacent to auditorium (see plan).
- Add grab bar in Men’s and Women’s core bathroom accessible stall on 1<sup>st</sup>, 2<sup>nd</sup> and 3<sup>rd</sup> floors.
- Create accessible Nurse’s toilets (see plan).
- Add grab bar in accessible stall in boys and girls core bathrooms on 1<sup>st</sup>, 2<sup>nd</sup> and 3<sup>rd</sup> floors.
- Remove toilet partition and add grab bar in pre-school, unisex accessible bathroom.
- “Project Prove” Garden must be relocated from raised platform.
- Field Snack Bar counter & entry must be made accessible.
- Accessible Gym entry needs signage.
- Accessible pathways around all athletic fields required.
- All bleachers must have accessible pathway and accessible seating areas.
- Entrance 23 need slope entry instead of step.
- Accessible route from rear parking lot, through island to back door required.
- Auditorium stage must be made accessible along with accessible route from seating.

- Auditorium men's room: Door opening pressure must be adjusted, paddle controls on one sink must be installed, accessible stall must be created and the mirror must be lowered.
- Auditorium women's room: Mirror must be lowered, accessible stall created, paddle controls on one sink provided, lever action door hardware installed, product dispensers lowered.
- Nurse's bathrooms must be made accessible.
- Women's Core Bathroom (1<sup>st</sup> Floor): Create accessible stall, adjust door opening pressure.
- Girls Core Bathroom (1<sup>st</sup> Floor): Accessible stall needs grab bars, paddle controls on one sink need to be provided, mirror and sink heights need to be adjusted.
- Pre-School Girl's Bathroom: Create accessible stall, paddle controls on one sink need to be provided, mirror and soap dispenser need to be adjusted, opening pressure on door needs to be adjusted.
- Boy's Locker Room Bath – (See Plan)
- Girl's Locker Room Bath – (See Plan)
- Men's & Women's Gym Staff Baths – (See Plan)
- Kitchen Bath – (See Plan)
- Girl's Locker Room: Accessible changing area required.
- Boy's Locker Room: Accessible changing area required.



Boy's Bathroom - Remove Urinals and create accessible stall




Girl's Bathroom - Install accessible stall

Address: 128 Town Street


Scale: 1/4" = 1'-0"

Project: BHS Kindergarten Bathrooms

Rev.



Men's Bathroom - Remove one sink create accessible stall




Women's Bathroom - Remove one sink and one stall and create accessible stall.

Address: 128 Town Street

Scale: 1/4" = 1'-0"

Project: BHS Men's & Women's Auditorium Bathrooms

Rev.




**Bathroom** – Relocate sink to exterior wall  
increase width of bathroom to five (5') feet

Address: 128 Town Street

Scale: 1/4" = 1'-0"

Project: BHS Nurse's Bathrooms

Rev.




Girls Locker Room Bath - Create H.C. Stall.

Address: 128 Town Street


Scale: 1/2" = 1'-0"

Project: BHS Girls Locker Room Bath

Rev.



Women's Gym Staff Bath - Eliminate One Shower, Create H.C. Stall.




Men's Gym Staff Bath - Eliminate One Shower, Create H.C. Stall

Address: 128 Town Street


Scale: 1/2" = 1'-0"

Project: BHS Women's Gym Staff Bath & Men's Gym Staff Bath

Rev.



**Kitchen Bathroom** – Create H.C. Stall, Reposition Sinks.




**Boy's Locker Room Bath** – Create H.C. Stall with Sink.

Address: 128 Town Street

Scale: 1/4" = 1'-0"

Project: BHS | Kitchen Bathroom, Boy's Locker Room Bath


Rev.




East Middle School  
305 River Street



**East Middle School – 305 Middle Street** – This facility will undergo a comprehensive renovation project beginning in June 2018 and during this time period all access deficiencies will be addressed.



Elderidge Elementary School  
46 Lincoln Street




Elderidge Elementary School  
46 Lincoln Street

**Elderidge Elementary School – 46 Lincoln Street** – A single story building. Paved parking across from main building containing eighteen parking spaces. Main and right side entries accessible

**Recommendations:**

- Create van and regular accessible parking spaces with access aisle and signage.
- Create accessible egress on left side of building (see plan).
- Change all door knobs to lever action handles.
- Modify Boy's and Girls Bathrooms (see plan).
- Modify Faculty Bathroom (see plan).




Side Entry Ramp – Utilizing existing platform  
create access ramp towards front of property.

Address: 46 Lincoln Street


Scale: 1/4" = 1'-0"

Project: Eldridge – Side Entry Ramp

Rev.



**Boys & Girls Bathroom** – Remove toilet partitions, add grab rails to create single service bathrooms



**Faculty Bathroom** – Relocate sink, widen door to 36" inches and add grab rails.

Address: 46 Lincoln Street


Scale: 1/4" = 1'-0"

Project: Elderidge – Girls, Boys & Faculty Bathrooms

Rev.



Flaherty Elementary School  
99 Lakeside Drive




**Flaherty Elementary School – 99 Lakeside Drive** – A single story school building. Exterior parking consists of parking area's located in the front, left side and rear of the building totaling forty-eight (48) spaces including two regular accessible spaces and one van accessible space in conformity with the Access Code. Both of the buildings front entries are accessible along with five rear entries. Within the building, all corridors and doorways provide an appropriate width and opening pressure and all levels are accessible by ramps.


### **Recommendations:**

- Replace all door knobs with lever action handles.
- Provide lift or ramp to access stage area.
- Install grab bars in both boy's and girl's accessible toilet stall. Increase access width to administrative office space.
- Remove cabinet/sink and replace with wall mounted sink and counter in Teacher break room.
- Expand student bathroom in Nurse's Office (see plan).
- Modify Women's bathroom facility (see plan).
- Remove toilet enclosure in Men's bathroom, replace existing toilet with accessible fixture, install grab bars and self closure on doorway along with locking mechanism to create single use accessible bathroom.
- Install signage adjacent to accessible spaces.
- Nurses Bath – (See Plan)
- Class Room #20 Bath – (See Plan)
- Left wing girl's room: Install grab bars, install push paper towel dispenser.
- Left wing boy's room: Install grab bars, Install push paper towel dispenser, install lever action handles on one sink.
- Right wing women's room: Install grab bars, install lever action handles on one sink, modify partitions to allow for 18" clear area on pull side to door, remove bench.
- Right wing girls room: Install grab bars
- Right wing boys room: Install grab bars

- Relocate accessible parking one to infield lawn area, one van and one conventional.
- Exit from gym/auditorium requires ramp and accessible route to street.
- Relocate accessible drop off closer to accessible entry and add curb cut.
- Any class room with exterior stairway must be replaced with ramp or otherwise be removed with door walled up.
- Lower door bell and fire alarm master box at main entry to 54” inches above finished grade.
- Regrade ramp at side entry create concrete ramp.
- All existing exterior ramps to be verified as to pitch and handrails as required.
- All recess areas must have stable ground cover.
- Faculty entrance at in rear parking lot must be accessible.
- Faculty right side parking lot requires additional car and van accessible space provided.
- Girl’s bath used for recess requires paddle control for door opening.
- Teacher’s room exit requires accessible ramp.
- Parking lot on left side requires signage in front of accessible spaces.



Women's Bathroom - Relocate sink and stalls and create accessible stall.




Nurse's Bathroom - Relocate sink and add grab rails.

Address: Lakeside Drive


Scale: 1/4" = 1'-0"

Project: Floherty- Women's & Nurse's Bathrooms

Rev.



**Nurses Bathroom** – Enlarge room, install sink, widen door.




**Classroom #20** – Reposition toilet & Sink.

Address: Lakeside Drive


Scale: 1/4" = 1'-0"

Project: Flaherty– Nurses Bath, Class Room #20 Bath

Rev.



Foster Elementary School  
Foster Road




**Foster Elementary School – Foster Road** – A single story building. Paved parking in front of building provides 16 parking spaces. All entries including main front entry are accessible. Building is currently occupied by “Habilitation Assistance Corp.”.

**Recommendations:**

- Replace door knobs with lever action handles.
- Provide ramp or lift for raised stage access.
- Provide grab bars to either side wall of Nurse’s bathroom.
- Relocate sink in accessible bath to provide wheelchair access and install rear grab bar.
- Create van and regular accessible parking space, access aisle and signage.



Highlands Elementary School  
144 Wildwood Street




Highlands Elementary School  
144 Wildwood Street

**Highlands Elementary School – 144 Wildwood Street** – A two story building with a partial finished basement. A paved parking lot to the right of the main building contains forty parking spaces inclusive of one van and one regular accessible parking space.

Recommendations:

- Provide ramp or lift access to raised stage area.
- Replace all door knobs with lever action handles.
- Modify Kindergarten bathroom (see plan).
- Modify Boy's and Girl's Second Floor bathrooms (see plan).
- Modify Boy's and Girl's Second Floor, Main Building bathrooms (see plan).
- Modify Boy's and Girl's Basement, annex bathrooms (see plan).
- Install limited service elevator in annex serving first and basement levels (see plan).
- Install limited service elevator in main building serving first and second levels (see plan).
- Modify Nurse's bathroom, lower sink outside of bath and remove cabinet (see plan)
- Modify Principal's bathroom (see plan).
- Create accessible route to upper level of rear portion of building – (See Plan)
- Main entry platform must be increased to five feet in depth.
- Front annex entry must be made accessible.
- Lower level side exit in annex must have accessible route to playground and to street.
- Accessible pedestrian route from tennis court to street required.
- Side entry door to play ground must be made accessible.
- Playground must be provided with accessible equipment.
- Guard/handrails required at rear exit of annex building.
- Ramp to modular classrooms requires upper and lower handrails on both sides.
- Exterior door leading from rear stairway in main building requires platform and sloping sidewalk.

- Bathrooms used for recess require accessible route to street, playground and tennis court.
- Girl's bath second floor main building remove cabinet under sink.
- Fill in depressions under swings.
- Left gym door and rear right gym door needs to be sloped down.
- Rear alcove doorway main building needs platform and sloping surface.
- Rear exit from stairway in Kindergarten area needs platform and sloping surface to be tight to side of building.
- Main building center stairway requires platform and sloping walkway.




Kindergarten Bathroom – Eliminate one toilet, add grab bars, sink and widen entry doors to 36 inches

Address: 144 Wildwood Street


Scale: 1/4" = 1'-0"

Project: Highland's Kindergarten Bathroom

Rev.



Girls 2<sup>nd</sup> Floor Bathroom - Eliminate one toilet, create accessible stall




Boys 2<sup>nd</sup> Floor Bathroom - Eliminate one urinal, create accessible stall.

Address: 144 Wildwood Street


Scale:  $\frac{1}{4}" = 1'-0"$

Project: Highland's Boys & Girls 2<sup>nd</sup> Fl. Bathroom

Rev.



Girls 2<sup>nd</sup> Floor Main Bathroom – Eliminate two toilets, create accessible stall.




Boys 2<sup>nd</sup> Floor Main Bathroom – Create accessible stall

Address: 144 Wildwood Street


Scale: 1/4" = 1'-0"

Project: Highland's Boys & Girls 2<sup>nd</sup> Fl. Main Bathroom

Rev.



Girl's Rm. - Annex - Relocate sinks and water closets, create accessible stall




Boy's Rm. - Annex - Eliminate urinals, relocate sinks, create accessible stall.


Address: 144 Wildwood Street

Scale: 1/4" = 1'-0"

Project: Highland's Girl's & Boy's Rm. - Annex

Rev.






Main Building Elevator Location - Utilize Counseling/  
Guidance Office space to provide limited service elevator  
serving first and second floors.

Address: 144 Wildwood Street


Scale: 1/4" = 1'-0"

Project: Highland's Main Building Elevator Location

Rev.



Nurses Bath - Expand bathroom, relocate toilet.  
add grab bars & widen door to 36" inches.




Principals Bath - Expand bathroom, relocate toilet.  
add grab bars & widen door to 36" inches.

Address: 144 Wildwood Street

Scale: 1/4" = 1'-0"


Project: Highland's Principal & Nurses Bathroom

Rev.





Hollis Elementary School  
482 Washington Street




**Hollis Elementary School – 482 Washington Street** – This structure is a multi-level building comprised of an original school structure and subsequent addition. Parking for this building is located at the rear of the building and contains sixty (60) spaces inclusive of one van accessible and one accessible parking space. The primary front entry is accessible as well as two rear entries. All doors and corridors provide adequate width and acceptable opening pressures. Accessible student bathrooms for boys and girls are provided in the basement level of the original school building.

### **Recommendations:**

- Replace all door knobs with lever action handles.
- Provide lift or ramp to access stage area.
- Create an additional accessible parking space.
- Gym Floor Level (Addition)– Modify both Men’s bathroom facilities (see plan).
- Second Floor Level (Main) – Modify both Boy’s and Girl’s bathroom facilities (see plan).
- First Floor (Right Wing) – Modify Boy’s and Girl’s bathroom facilities.
- Main Entry Lobby (Addition) - Install limited service elevator (see plan)
- Gym Entry Lobby (Addition) - Install limited service elevator and area of refuge (see plan).
- Girl’s Bath Main Building (1<sup>st</sup> floor) – (See Plan)
- Boy’s Bath Main Building (1<sup>st</sup> Fl.) – (See Plan)
- Gym Basement Bath near gym – (See Plan)
- Lobby lift needs to be installed, discontinue use of back stairs for all students.
- Create area of refuge in main building, lower level adjacent to stairway.
- Right wing Women’s bath remove platform in front of sink.
- Right wing Men’s bath remove platform under sink and create accessible stall.

- Install a curb cut at both ends of crosswalk outside school in drop off circular driveway leading to playground.




Men's Room Gym Level – Remove one stall and one urinal; relocate sink and create accessible stall.

Address: 482 Washington Street


Scale:  $\frac{1}{4}'' = 1'-0''$

Project: Hollis Men's Room Gym Level

Rev.



**Main Bldg. 2<sup>nd</sup> Floor Girl's Room** - Remove one stall, add one sink and accessible stall.




**Main Bldg. 2<sup>nd</sup> Floor Boy's Room** - Remove one sink, one urinal, and one stall, create accessible stall.

Address: 482 Washinton Street

Scale: 1/4" = 1'-0"

Project: Hollis Main Bldg. 2<sup>nd</sup> Fl. Boy's & Girl's Room

Rev.



**Right Side 1<sup>st</sup> Floor Girl's Room** – Remove platform under sinks. create accessible stall.


**Right Side 1<sup>st</sup> Floor Boy's Room**– Remove one stall, create accessible stall


Address: 482 Washington Street

Scale: 1/4" = 1'-0"

Project: Hollis Boy's & Girl's Right Side 1<sup>st</sup> Fl. Bathrooms

Rev.






Gym Basement Bathroom - Create single stall bathroom, reposition toilet & sink.

Address: 482 Washington Street

Scale: 1/4" = 1'-0"

Project: Hollis Gym Basement Bathroom

Rev.




Girl's Bathroom - Eliminate stalls, create H.C. Stall

Address: 482 Washington Street

Scale: 1/4" = 1'-0"

Project: Hollis Main Building, First Floor Girl's Room

Rev.




**Boy's Bathroom** – Eliminate stalls, create H.C. Stall.

Address: 482 Washington Street

Scale: 1/4" = 1'-0"

Project: Hollis Main Building, First Floor Boy's Room

Rev.



Gym Lobby Elevator – Install elevator to serve basement  
Gym level, 1<sup>st</sup> and 2<sup>nd</sup> floors.

Address: 482 Washington Street


Scale: 1/4" = 1'-0"

Project: Hollis Gym Lobby Elevator Location

Rev.




Liberty Elementary School  
49 Proctor Road



**Liberty Elementary School – 49 Proctor Road** – A single story building with paved parking in front and left side of building containing 41 parking spaces inclusive of two van and one regular accessible parking space. The main entry and two front egresses are accessible along with a rear egress.

### **Recommendations:**

- Modify Nurse’s bathroom with sink outside of bath (see plan).
- Provide lift/ramp to raised stage platform.
- Change door knobs to lever action handles.
- Lower portion of office counter.
- Create accessible route to rear basketball court from paved access aisle.
- Exits on left of building need platform and sloping walkway.
- Speech & Language classroom exit need platform and sloping walkway.
- Cafeteria exit requires sloping sidewalk from platform.
- Rear hallway exit, enlarge and extend ramp.
- Center rear exit, add sloping walkway.
- Adjust gym exit and add rails to ramp.
- Right side hallway exit at rear, enlarge platform and add sloping walkway.
- Right side recess bathrooms require platform, sloping walkway and make entry door thirty-six inches wide, remove one toilet in girl’s and boy’s bath. Interior doors leading to these baths must be widened with the door swing reversed.
- Add accessible space near cafeteria exit.
- Ensure that unisex, handicapped bathroom is available to students with signage.
- Kitchen staff bathroom, remove partitions to make accessible.



**Nurses Bathroom** - Expand bathroom & add grab rails

Address: 49 Proctor Road


Scale: 1/4" = 1'-0"

Project: Liberty - Nurses Bathroom

Rev.



Monatiquot Elementary School  
25 Brow Avenue




**Monatiquot Elementary School**  
25 Brow Avenue

**Monatiquot Elementary School – 25 Brow Avenue** – A single story building with accessible main front and rear entries. Off street parking facilities to right of main building provide ten off street parking spaces.

### **Recommendations:**

- Create a van accessible and accessible parking space along with designated signage.
- Replace all door knobs with lever action handles.
- Install ramp access to right wing portion of classrooms (see plan).
- Install ramp access at rear egress of right wing portion of building (see plan).
- Remove urinal in Men’s bath, rename unisex accessible bathroom and adjust grab rails to conform to accessibility standards.
- Install ramp access or lift to auditorium stage.
- Modify bathroom outside of classroom “K” – (See Plan).
- Faculty room exit must have ramp replace stairs.
- Access walkway to main entry too steep and must be corrected.
- Exterior classroom exits must be provided with ramps or otherwise removed with the doors walled up.
- Need ramp to depressed area of side entrance.
- Need ramp to rear gym entrance.
- Create accessible ramp/lift to front and rear of stage in auditorium.
- Girl’s bath (Weston Ave. side) remove partition, widen door, and remove one toilet to create accessible bath.
- Boy’s bath (Weston Ave. side) remove one urinal to create accessible bath, and remove privacy screen to widen opening.
- Girl’s bath (Brow Ave.) reduce privacy partition to thirty-two inches, remove one toilet to create accessible bath.
- Boy’s bath (Brow Ave.) remove privacy screen, widen door and install new door to swing out on accessible stall.




Interior Access Ramp - Create access ramp leading from left of main entry lobby to lower level classroom corridor.

Address: 25 Brow Avenue

Scale: 1/4" = 1'-0"


Project: Monatiquot - Interior Access Ramp

Rev.



Bathroom Outside Room "K" - Enlarge room, widen door, install sink.

Address: 25 Brow Avenue	Scale: 1/4" = 1'-0"
Project: Monaquot - Bathroom outside entrance to Room "K"	Rev.




**Rear Exterior Access Ramp** - Create access ramp leading from existing rear stair landing to paved access leading to playground area. 1

Address: 25 Brow Avenue


Scale: 1/4" = 1'-0"

Project: Monatiquot - Rear Exterior Access Ramp

Rev.



**Morrison Elementary School**  
260 Liberty Street



Morrison Elementary School  
260 Liberty Street


**Morrison Elementary School – 260 Liberty Street** – A single story building with a partial basement which is finished. There is paved parking along the right side and across from the school providing a total of 42 parking spaces including two van accessible and one regular accessible parking space. The main and lower level entries are accessible.

*\* Please note the main entry level is referred to as the second floor in terms of room numbering.*

### **Recommendations:**

- Provide ramp or lift for access to stage.
- Change all door knobs to lever action handles.
- Modify Principal office bathroom, reverse swing of door, raise toilet to nineteen inches (see plan)
- Modify Nurse's bathroom reverse swing of door, remove counter and install compliant wall mount sink (see plan)
- Modify Kindergarten Room 212 bathroom, remove cabinet under sink, widen door to thirty-six inches and reverse swing (see plan)
- Modify Kindergarten Room 211 bathroom (see plan).
- Modify Kindergarten Room 210, remove cabinet under sink (see plan).
- Women's Bathroom, second floor – Eliminate sink in accessible stall and add grab bar behind toilet.
- Men's Bathroom, second floor – Eliminate urinal and add grab bar behind toilet.
- Modify boys bathroom, first and basement floor, eliminate one toilet, reverse door swing (see plan).
- Modify girls bathroom, first and basement floor, eliminate one toilet, reverse door swing (see plan).
- Modify Men's bathroom, first floor and basement, remove partitions and remove one urinal, centerline and height of toilet needs adjustment (see plan).

- Modify Women's bathroom, first floor and basement, remove partitions and one sink, centerline and height of toilet need adjustment (see plan).
- Modify Playground bathroom, eliminate urinal and create accessible stall, reverse swing, widen door and rename unisex bath, provide call button and lock. (see plan)
- Install Limited Service Elevator to service second & first floor (see plan).
- Kitchen bath (See Plan).
- Rear gym exit needs sloping walkway from platform.




Kitchen Bathroom – Create single stall bath, widen door.

Address: 260 Liberty Street


Scale: 1/4" = 1'-0"

Project: Morrison – Kitchen Bathroom

Rev.



Nurse's Bathroom - Relocate sink, widen doors to 36" inches and add grab bars.




Principal's Bathroom - Relocate sink, widen doors to 36" inches and add grab bars

Address: 260 Liberty Street


Scale: 1/4" = 1'-0"

Project: Morrison - Nurse's & Principal's Bathroom

Rev.



Nurse's Bathroom – Relocate sink, widen doors to 36" inches and add grab bars.




Principal's Bathroom – Relocate sink, widen doors to 36" inches and add grab bars

Address: 260 Liberty Street

Scale: 1/4" = 1'-0"

Project: Morrison – Nurse's & Principal's Bathroom

Rev.




Room 210 Bathroom - Relocate sink, widen doors to 36" inches and add grab bars.

Address 260 Liberty Street


Scale: 1/4" = 1'-0"

Project: Morrison - Kindergarten Room 210 Bathroom

Rev.



Girl's 2<sup>nd</sup> Fl. Bathroom – Eliminate one toilet and create accessible stall




Boy's 2<sup>nd</sup> Fl. Bathroom – Eliminate one toilet and create accessible stall

Address: 260 Liberty Street


Scale: 1/4" = 1'-0"

Project: Morrison – Boy's & Girl's 2<sup>nd</sup> Fl. Bathrooms

Rev.



Women's 1<sup>st</sup> Fl. Bathroom – Create accessible stall.




Men's 1<sup>st</sup> Fl. Bathroom – Eliminate one sink and create accessible stall.

Address: 260 Liberty Street


Scale: 1/4" = 1'-0"

Project: Morrison – Men's & Women's Room 1<sup>st</sup> Floor

Rev.



**Playground Bathroom** - Eliminate urinal and create accessible stall.



**Elevator Location** - Create elevator to serve 2<sup>nd</sup> and 1<sup>st</sup> floor to be located in Room 209A.

Address: 260 Liberty Street


Scale: 1/4" = 1'-0"

Project: Morrison - Playground Bathroom & Elevator Location

Rev.




Ross Elementary School  
20 Hayward Street




**Ross Elementary School – 20 Hayward Street** – A two story structure with a partial finished basement. Off street parking is located to the right of the building along with parallel parking along the front totaling thirty-six (36) spaces including a van and conventional accessible space. An accessible entry adjacent to the accessible parking is provided. All interior doors and hallways provide adequate width and opening pressures.

### **Recommendations:**

- Replace all door knobs with lever action handles.
- Provide a lift or ramp access to the stage area front and rear.
- Provide ramp access to primary, main, front entry (see plan)
- Provide ramp access to rear playground area (see plan).
- Install limited service elevator to serve basement, main, first and second floor levels create area of refuge. (see plan)
- First Floor (Right Wing) – Modify Boy’s and Girl’s restrooms, remove fixture, widen door (see plan).
- Second Floor (Right Wing) – Modify Boy’s and Girl’s restrooms, remove fixture, widen door (see plan)
- First Floor (Main Building) – Modify Men’s and Women’s restrooms (see plan).
- Nurses bath (see plan)
- Class Room #2 bath (see plan)
- Class Room#1 bath (see plan)
- All class room exterior exits must be provided with ramps or otherwise discontinued and the doors serving these exits walled up.
- Lower level rear egress requires platform and ramp.
- Cafeteria exit needs platform and ramp.
- If fields at rear of property are utilized by students then accessible route must be provided.
- Teacher’s room, remove cabinet under sink.



MAIN ENTRY LOBBY




Rear Entry Ramp - Utilizing existing main entry lobby create access ramp to playground in rear of building

Address: 20 Hayward Street

Scale: 1/4" = 1'-0"

Project: Ross - Rear Entry Ramp

Rev.




Elevator Location— Utilizing existing corridor are between main entry lobby create and right wing of school, create limited service elevator to serve basement, first floor, main level and second floor of school

Address: 20 Hayward Street


Scale: 1/4" = 1'-0"

Project: Ross – Elevator Location


Rev.



Nurse's Bathroom – Widen room, widen door, install sink.



Room #2 – Convert to single use bath widen door.




Room #1 – Convert to single use bath, close off one door, widen door.

Address: 20 Hayward Street


Scale: 1/4" = 1'-0"

Project: Ross – Nurses Bath, Room #1 & #2

Rev.



Girls 1<sup>st</sup> Floor Right Wing Bathroom - Remove one stall and create accessible stall.




Boys 1<sup>st</sup> Floor Right Wing Bathroom - Remove one urinals and create accessible stall

Address: 20 Hayward Street


Scale: 1/4" = 1'-0"

Project: Ross - Girls, Boys 1<sup>st</sup> Floor Right Wing Bathrooms

Rev.



Girls 2<sup>nd</sup> Floor Right Wing Bathroom – Remove one stall and create accessible stall




Boys 2<sup>nd</sup> Floor Right Wing Bathroom – Remove two urinals and two stalls, create accessible stall.

Address: 20 Hayward Street


Scale: 1/4" = 1'-0"

Project: Ross – Girls, Boys 2<sup>nd</sup> Floor Right Wing Bathrooms

Rev.



**Men's Bathroom** - Remove one stall and one urinal and create accessible stall.



**Women's Bathroom** - Remove one stall and create accessible stall.

Address: 20 Hayward Street

Scale: 1/4" = 1'-0"

Project: Ross - Men's & Women's Bathrooms

Rev.



South Middle School  
232 Peach Street





**South Middle School**  
232 Peach Street

**South Middle School – 232 Peach Street** – A two story building with a partial finished basement. Paved parking located in front and to the right of the main building containing 106 parking spaces inclusive of two accessible parking spaces. The left side of the school is serviced by an elevator providing access to first and second floors. The main entry along with rear and lower level egress are accessible.


## **Recommendations:**

- Lower portion of main counter in office
- Create one van and two additional accessible spaces with access aisles and signage. .
- Change door knobs to lever action handles.
- Install rear grab bars in Boy's and Girl's accessible stalls.
- Modify Nurse's bathroom (see plan)
- Modify Men's faculty bathroom (see plan).
- Install limited service elevator to serve first and basement level floors (see plan).
- Guidance class room (see plan)
- Men's & Women's Gym Teach Bath (see plan)
- Girl's Locker Room Bath (see plan)
- Boy's Locker Room Bath, remove urinal, relocate toilet and remove mop sink. Reinstall urinal with privacy screen.
- First and Second floor Men's Bath (Left wing) to be renamed unisex, reverse door swing.
- First and Second floor Girl's Bath (Left wing) adjust partition to allow for greater access.
- Girl's and Boy's Locker Room rear exits require platform and sloping walkway.
- Class room #91, add walkway.
- Right side exit, make level platform and sloping walkway to parking lot.
- Faculty parking lot, create two accessible spaces.
- Lower level exit from gym in rear of building requires platform and sloping walkway.

- Create ramp/lift to stage in auditorium.
- Men's bath adjacent to auditorium, relocate toilet, remove partition, widen door to thirty-six inches, change this restroom to a single service use with lock.
- Women's bath adjacent to auditorium, relocate toilet, move sink, relocate and widen door to thirty-six inches, relocate radiator by raising the same.
- Remove doors adjacent to proposed elevator location.



Guidance Bathroom – Enlarge room, widen door. Men's & Women's Gym Teacher Bath – Widen Room, Create single stall bath.




Girls Locker Room Bath – Create H.C. Stall, Block off one entry.


Address: 232 Peach Street

Scale: 1/4" = 1'-0"

Project: South Middle – Guidance Office Bath, Girls Locker Room Bath, Men's & Women's Gym Teacher Bath



Nurse's Bathroom – Relocate sink, widen bathroom and add grab rails.




Men's Bathroom – Relocate sink, re-orient toilet, add Grab bars, widen door to 36" inches.

Address: 232 Peach Street

Scale: 1/4" = 1'-0"

Project: South Middle – Men's & Nurse's Bathrooms

Rev.



Elevator Location – Install limited service elevator in location of Dumb waiter to serve main floor and basement levels.

Address: 232 Peach Street

Scale: 1/4" = 1'-0"

Project: South Middle – Limited Service Elevator Location

Rev.

### ***C. Town Policies, Programs and Services by Department***

As part of the Self-Evaluation process Policies, Programs and Services must be analyzed to ensure full access to persons with disabilities. It is the intent of the Town to address any programmatic accessibility barriers including the following areas:

- **Customer Service** – Policies and practices that ensure individuals with disabilities can participate in the programs, activities and services provided by the Town of Braintree including: procedures for program modifications and not charging additional fees for reasonable accommodation to the person with a disability for modification required to make a program accessible.
- **Outreach Information and Communication** – Notices, printed information, televised and audiovisual information, all Town and departmental websites and social media platforms, public telephones and communication devices.
- **Training and Staffing** – The current level of training and experience of Town employees with policies and procedures regarding providing services to individuals with disabilities.
- **Programs and Activities** – Program eligibility and admission, public meetings, tours and trips, transportation services, the use of consultants or contractors to provide services, emergency evacuation procedures, special events and private events on Town properties, maintenance of accessible programs and ongoing accessibility improvements.
- **Accessible/Adaptive Equipment** – The use of automated electronic equipment and auxiliary aids to assist individuals with disabilities participate in Town programs.

Within the next year, the Town of Braintree will be evaluating its policies, programs, and procedures to determine current levels of service and the extent to which these may create barriers to accessibility for persons with disabilities. This evaluation will include meetings with department staff to provide information on the nature of the program, forms and methods to advertise the program's services and activities, a profile of participants, the types of equipment and materials to be used, testing and entrance requirements, the level of staff training, and any special modifications that will be needed. Meetings will be conducted with the following departments and divisions:

- Braintree Electric Light Department (BELD)
- Braintree Public Schools
- Department of Elder Affairs
- Human Resources Department
- Municipal Licenses and Inspections
- Planning and Community Development
- Department of Public Safety
- Department of Public Works
- Retirement
- Legal Department
- Thayer Public Library
- Town Clerk
- Braintree Community Access Television (BCAM)

Information will be collected in the meetings with Town employees to see if some of the existing policies, programs, and procedures may present barriers to accessibility for people with disabilities. See **Exhibit # 4** for an example of the questionnaire to be distributed to all departments listed. Some policies have already been reviewed and the remainder of Data Collection by Department to be completed by January 2018. Currently included in this Self-Evaluation are:

1. Employment Policy – **Exhibit # 5**
2. Travel to Community Sponsored Events – **Exhibit # 6**

#### ***D. Public Right of Way (Pedestrian Access, Roadways and Municipal Parking)***

One of the major components of a public entity's Self-Assessment is the evaluation and recommended actions to ensure barrier removal in all areas of public right of way including streets, sidewalks and all public parking in the City or Town. Attached as exhibits please find several components used as the Town of Braintree continues to gather data in these three critical areas.

1. Engineering Division – \*P.R.O.W. Standards
  - a) Standard Operating Practices for ADA Compliance in the 100 Roads Program – **Exhibit # 7**
  - b) Standard Operating Practices for ADA Compliance on Town Roadway Construction Projects – **Exhibit # 8**

*\*Remainder of Data Collection to be completed by June 2018 (complete sidewalk assessment by StreetScan Development is currently being procured – see proposal for the Town of Braintree) - **Exhibit #9***

2. Municipal Parking Lots

*\*Self-Assessment Data Collection of these areas to be completed by June 2018*

#### ***E. Transition Plan***

*\*To be completed once all Self-Assessment requirements and recommendations have been satisfied.*

#### ***F. Public Outreach***

This plan is a baseline for bring the Town of Braintree into full ADA compliance. Part of the development process of this Self-Assessment and Transition Plan must include public input. These input meetings shall be scheduled once the draft plan is completed. They will be open to

the public at least one seat should be filled by a member of the public and one by a member of the Commission on Disabilities. The Final Self-Assessment and Transition Plan will be presented to the Town Council for adoption.

Once the plan is final, it is recommended that the ADA Coordinator present quarterly, at a minimum, to Department Directors to discuss this plan. Policy issues should be discussed and solutions vetted in these meetings.

# Town Policies

---

- **Employment**
- **Travel to Community Sponsored Events**



TOWN OF BRAINTREE  
 PERSONNEL POLICY & PROCEDURES  
EQUAL EMPLOYMENT OPPORTUNITY  
AFFIRMATIVE ACTION PLAN

<b>POLICY</b>	The Town of Braintree's policy is to ensure equal employment opportunity for all without regard to race, sex, color, religion, age, national origin, sexual orientation, genetic information, gender identity, veteran's status, disability (where it does not fundamentally alter the job, program, or activity) or on the basis of other non-job related characteristics. In establishing the affirmative action plan, the Town of Braintree has committed to the Massachusetts Commission Against Discrimination goal setting procedure to correct deficiencies over a reasonable period of time.
<b>SCOPE</b>	This policy and procedure is applicable to all Town of Braintree employees and employment applicants.
<b>DEFINITIONS</b>	<p>The Town of Braintree is committed to complying with all applicable Federal and State legislation, executive orders and rules and regulations including the following:</p> <ol style="list-style-type: none"> <li>1. Title II of the Civil Rights Act of 1964 (42 USC s2000e <u>et seq</u>), which prohibits discrimination in employment on the basis of race, color, religion, sex, or national origin; and</li> <li>2. The Age Discrimination in Employment Act of 1967 (29 USC s621 <u>et seq.</u>), which prohibits discrimination in employment on the basis of age with regard to those individuals who are at least 40 years of age, but less than 65 years of age; and</li> <li>3. Section 504 of the Rehabilitation Act of 1973 (29 USC s794), and the regulations promulgated pursuant thereto (45 CFR Part 84), which prohibit discrimination against qualified handicapped individuals on the basis of handicap and requires employers to make reasonable accommodations to known physical or mental limitations of otherwise qualified handicapped applications and employees; and</li> <li>4. M.G.L. c. 151B s4 (1), as amended by Chapter 533, 1983, which prohibits discrimination in employment on the basis of race, color, sex, religious creed, national origin, ancestry, age or handicap,</li> </ol>

	<p>In addition, the Provider agrees to be familiar with and abide by:</p> <ul style="list-style-type: none"><li>• Massachusetts Executive Order 524</li><li>• Massachusetts Executive Order 526</li><li>• Equal Pay Act of 1963</li><li>• Massachusetts Architectural Barriers Board Act</li><li>• Federal Executive Orders 11246 and 11375 as amended.</li></ul> <p>All employees, unions, sub contractors and vendors must make genuine consistent efforts:</p> <ol style="list-style-type: none"><li>1. To ensure equal employment opportunities for present and future employees, and</li><li>2. To implement affirmative action, as legally required, to remedy the effects of past employment discrimination and social inequalities.</li></ol> <p>This policy prohibits that any employee, or applicant, be subjected to coercion, intimidation, interference or discrimination for filing a complaint or assisting in an investigation under this program. No portion of this <u>Equal Employment Opportunity/Affirmative Action Policy</u> shall be construed as conflicting with any existing or future judicial or legislative mandate where a constriction consistent with that mandate is reasonable.</p> <p>This policy applies to all employment related functions, including but not limited to recruiting, hiring, training, compensation, promotion, benefits, transfers, layoffs, return from layoffs, and social/recreational programs.</p>
<p><b>PROCEDURE</b></p>	<p>The Human Resources Department is responsible for the preparation of a written Equal Employment Opportunity/Affirmative Action Program and for the coordination of efforts to implement this program. Such efforts include:</p> <ul style="list-style-type: none"><li>• Recruitment: all advertisements and job postings will identify the Town as an "Equal Opportunity Employer." Efforts will be made to include help wanted advertisements that serve minority populations and females.</li><li>• Promotions and Demotion: The Town will work toward providing qualified minorities, persons with disabilities, veterans and females the opportunity for promotion.</li><li>• Layoffs and terminations: Reduction of force, when necessary, shall be done with an objective criterion and without unlawful discrimination. Layoffs will be conducted according to seniority within the various Town Unions. Bumping rights will apply.</li></ul>

	<ul style="list-style-type: none"><li>• <b>Compensation and Benefits:</b> The town will pay all personnel fairly according to their job classification. Merit increases will be granted according to the individual Union contracts to qualifying employees where a performance evaluation was conducted, in writing.</li><li>• <b>Facilities and activities:</b> shall be accessible to the disabled to the fullest extent possible and shall be offered on a non-segregated, non discriminatory basis. Reasonable accommodation will be provided.</li></ul>
--	---

**Approved:**

**Date:**

---

**CONTRACT BETWEEN THE TOWN OF BRAINTREE**  
**AND**  
**CELEBRATION TOURS, INC.**

**IV. SERVICES**

The Vendor will provide tour company services for day and overnight trips coordinated with the Town through December 2013 with Town option to extend for 2014 and 2015. The Vendor agrees to provide deluxe motor coach transportation with licensed and appropriately insured companies equipped at a minimum with a lavatory and VCR & DVD and shall contain a minimum seating capacity of forty-five (45) passengers. The Vendor agrees to do all things necessary to provide, based on availability, for wheelchair accessible buses for any trip, provided the Town is able to notify the Vendor sufficiently in advance to order the same to accommodate handicapped individuals willing and able to participate on any trip. It is agreed that there are no guarantees that wheelchair accessible buses will be available for any/all trips as they are obtainable on a first come basis. The Town agrees to absorb any additional costs for the use of wheelchair accessible buses on any particular trip. In advance of any overnight trips, the Vendor shall forward a written itinerary, pertinent telephone numbers and departure and arrival times for said trips. The Vendor shall offer a trip cancellation waiver as an optional cost item for each overnight trip and made available to overnight trip registrants, who must cancel their trip up until time of departure, at their own cost. The Vendor shall provide an acceptable and experienced trip escort for all trips arranged with the Town. This contract is processed in accordance with the Town's bid specifications and as bid by the Vendor.

**V. QUALITY OF WORK**

The Vendor represents that it will perform services for the Town using that degree of care and skill ordinarily exercised by and consistent with the standards applicable to persons performing similar services under similar conditions in the same locality. The Vendor shall be liable for its services rendered under this Contract.

**VI. COMPENSATION**

Upon completion of each respective trip, the Vendor shall submit an invoice to the Town with any reasonable supporting documentation requested by the Town, reflecting the services performed. The Town agrees to pay the Vendor the gross trip registration fees collected from each trip less six percent (6%), seven percent (7%) or eight percent (8%) of gross trip registration fees collected from each trip. The Vendor agrees that it will deduct the six percent (6%), seven percent (7%) or eight percent (8%) of gross trip registration fees as payment to the Town to promote and register all participants for each individual trip, i.e. 6% for 1 to 30 full paying passengers, 7% for 40 full paying passengers and 8% for 50 full paying passengers.



Joseph C. Sullivan, Mayor

## BRAINTREE DEPARTMENT OF PUBLIC WORKS

### Engineering Division

Robert P. Campbell, PE, PTOE, Town Engineer

[rcampbell@braintreema.gov](mailto:rcampbell@braintreema.gov)

John J. Morse, Assistant Town Engineer

[jmorse@braintreema.gov](mailto:jmorse@braintreema.gov)

To: Jim Arsenault  
From: Bob Campbell  
Date: August 14, 2017  
CC: Kristen Zechello, John Morse

RE: Standard Operating Practices for ADA Compliance in the 100 Roads Programs and in other work along the roadways

Jim,

Without a town wide sidewalk master plan and given wide spectrum of abutters' wishes with regard to sidewalks I have prepared this written description of how we approach sidewalks and ADA compliance in our "100 Roads Programs" and other work we do along the Town's roadways.

Our initial approach had been that at least on one side, sidewalks should be provided on any street where there is room for them and shared use of the roadway pavement by pedestrians, bicyclists and motor vehicle operators would not be practical. But with this approach applied in practice, the feedback was generally in-consistent and negative. Abutters variously proclaimed that they don't want the sidewalk, they want the grass to remain, they want a grass strip, they don't want a grass strip, they want granite curbing, they don't want granite curbing, they don't want ANY curbing because they park there, they don't want the asphalt berm, we can't remove the tree, we can't remove the encroaching fence, they want the sidewalk on the other side, they don't want it to look like a "city", and on and on. Pending a Council-voted master plan it was decided to do the minimum required by the Americans with Disabilities Act (ADA) and the Architectural Access Board (AAB.)

From Merriam-Webster's dictionary, a sidewalk is "a usually paved walk for pedestrians at the side of a street." This definition must be expanded to address applicability of the "Americans with Disabilities Act." Sidewalks must provide connectivity. Since we don't want intermittent parking aprons considered "sidewalks", we add that a sidewalk must be continuous for the full length of the block and that parking is not permitted on sidewalks. That way the sidewalk does connect from point A to point B and the curb ramps required at every end-of-sidewalk would correspond to street crossing locations and not discharge pedestrians into traffic lanes mid-block.

To further differentiate sidewalks from parking aprons, sidewalks should be separated by a change in construction material from the adjacent roadways. The preferred separation is a

85 Quincy Ave., Braintree, MA 02184 Telephone: 781-794-8010 Fax: 781-356-6803

Exhibit # 7

vegetated strip (which can also accommodate mailboxes, street signs, utility poles, and trash/recycling bins on trash day.) Along the street side of the strip a monolithic berm should be used to control roadway runoff and set an edge for the vegetated strip. If the street is used as a thoroughfare with higher operating speeds, a vertical granite curb would be substituted for the bituminous concrete berm. Granite curbing can also be used without the vegetated strip to provide the change in construction material in areas where there is insufficient layout to accommodate the vegetated strip. Granite curbing is also used along sidewalks that are walking routes to adjacent public schools.

Where parking aprons are prevalent along a street it is important to differentiate them from sidewalks in other ways as well. The minimum width of an accessible sidewalk is prescribed as 4 feet. Therefore, the maximum width of a bituminous-concrete-paved parking apron should be 3 feet. If parking aprons are continuous along a street they must be interrupted by full width landscaped gaps in the pavement. A paved way along the roadside that is only interrupted by utility poles, posts or other items often found in sidewalks might look like a non-compliant sidewalk and result in the requirement that the obstructions be removed (and ending its use for parking.)

So our approach to sidewalks and ADA / AAB compliance follows on the appended "Standard Operating Practice – ADA Compliance on Town Roadway Construction Projects", dependent upon the street rehabilitation work done.

Bob

## “Standard Operating Practice – ADA Compliance on Town Roadway Construction Projects”

**Street Maintenance** (includes chip seals, crack filling and sealing, fog seals, pavement patching, slurry seals, crosswalk high friction surface applications, surface sealing and similar treatments):

- No sidewalk improvements / upgrades at the time of the treatment (but future upgrades are not precluded.)

**Alterations-minor** (includes cape seal, mill-and-overlay, shim-and slurry seal, simple overlays, thin-lift overlays):

- Sidewalk improvements limited to removing barriers and if the curb ramps do not comply with the standards applicable to 1991 standards (or later if they were constructed later) update the curb ramps to current standards.

**Alterations-major** (includes cold in-place recycling, full-depth construction or reconstruction, hot in-place recycling, reclamation-and-paving):

- Where there is an existing non-conforming sidewalk, remove it and construct a new sidewalk using monolithic cape cod berm, 2' minimum grass strip and 5' "flat" cross-slope asphalt sidewalk<sup>1</sup>, and curb ramps to current standards;
- Where there is an existing conforming sidewalk *that is suitable to remain* leave it. Otherwise treat it as a non-conforming sidewalk as above;
- Where there is an existing parking apron that can remain, match into it;
- Where there is an existing parking apron that would be left too high or too low to match into, remove it and construct a 3 foot wide parking apron making sure it does not appear to be a sidewalk.

<sup>1</sup> Treatment varies to most-closely match what had existed before the work began.

**Traffic Signal minimal or emergency repairs** (re-lamping, adjust timing, repair knock-down, replace detector loops / push-buttons or similar):

- No upgrade to audible and count-down pedestrian signals required.

**Traffic Signal equipment upgrade** (new mast arms, replace multiple signal heads, new controller or cabinet, change of detection types, add opticom or other preemption):

- Upgrade to audible and count-down pedestrian signals.

These operating practices should be considered to be our "Transition Plan" while the formal plan is being devised.

Robert P. Campbell, P.E., Town Engineer

85 Quincy Ave., Braintree, MA 02184 Telephone: 781-794-8010 Fax: 781-356-6803

Exhibit #8

4

Date Approved: 10/1/15  
Grade: Schedule G  
Non Union  
Apptg. Authority:

**ADA COORDINATOR**

**NATURE OF WORK:**

Administrative and technical work related to the enforcement and interpretation of the Americans with Disabilities Act. The ADA Coordinator is responsible for advising the Town on policies and procedures in conjunction with the Commission on Disabilities relating to ADA issues and is the contact person for disability related questions from employees and residents. Employee is required to perform all similar or related duties.

**SUPERVISION:**

Works under the administrative direction the Department of Municipal Licenses and Inspections and the Division of Engineering; works in accordance with federal, state and local laws and regulations. Employee functions independently but confers regularly with the Inspector of Buildings, the Planning and Community Development Department and the Engineering Division only where clarification or interpretation of policy or procedures is required.

The work requires examining, analyzing and evaluating facts and circumstances surrounding individual problems, situations or transactions, and determining actions to be taken within the limits of standard or accepted practices. Guidelines include a large body of policies, practices and precedents which may be complex or conflicting, at times. Judgment is used in analyzing specific situations to determine appropriate actions. Employee is expected to weigh efficiency and relative priorities in conjunction with procedural concerns in decision making. Requires understanding, interpreting and applying federal, state and local regulations.

**JOB ENVIRONMENT:**

Some work is performed under typical office conditions and some work is performed in field. Fifteen hours per week. Some night meetings are required.

The employee operates standard office equipment and must be able to drive an automobile.

The employee has constant contact with the general public, property and business owner/operators, contractors, design professionals, and other Town Departments. Contact is in person, by telephone and in writing.

The nature of the professional or technical work means that errors in analysis, techniques or recommendations would probably be difficult to detect. Consequences of errors, missed deadlines or poor judgment could result in excessive costs, delay of service delivery, or legal repercussions to the municipality.

**ESSENTIAL FUNCTIONS:**

*(The essential functions or duties listed below are intended only as illustrations of the various types of work that may be performed. The omission of specific statements of duties does not exclude them from the position if the work is similar, related, or a logical assignment to the position. Duties are not necessarily in order of importance or frequency of performance.)*

- Serves as a resource for the Town and residents regarding ADA
- Serves as liaison for Mayor's office regarding questions, concerns, complaints related to ADA issues
- Provides technical assistance to the Town regarding ADA issues and activities
- Performs duties developing the Town's transition plan in conjunction with the Department of Municipal Licenses and Inspections and other Town departments as required
- Works with the Commission on Disabilities to develop policies and procedures
- Researches and assists with programs to enhance ADA awareness townwide
- Maintains current information regarding State, Local & Federal laws and regulations
- Develops written and web-based materials to disseminate information regarding ADA
- Attends public meetings as necessary to represent the Town's interests
- Generates reports as needed
- Performs outreach in the community regarding available resources and to gather information about needs
- Interfaces with local community, other city department, and state/federal agencies
- Serves as liaison between the Commission on Disabilities and the Mayor's Office
- Prepares reports for the Commission on Disabilities

- Shall work with Town Grant Writer in seeking financial support from governmental and private sources
- Presents case information at Commission on Disabilities meetings
- Coordinates community outreach and participation processes

**KNOWLEDGE, SKILLS, AND ABILITY:**

**Knowledge:** Knowledge of laws related to affirmative action, equal opportunity and disability issues. Knowledge of community, action groups, politics (local), neighborhoods and business concerns. Knowledge of various alternative formats and technologies that enable people with disabilities to communicate, participate and perform tasks.

**Abilities:** Ability to organize and direct the preparation of comprehensive reports, analyze problems, prepare technical reports and formulate recommendations; ability to communicate effectively in a concise and convincing manner. Ability to foster partnership and relationship with the Executive Branch that will result in better and more complete access for people with disabilities.

**Skills:** Skill in community involvement in an suburban environment; excellent customer service, planning and design skills. Skills and training in negotiation and mediation. Highly developed interpersonal skills for dealing with sensitive, emotional and potentially controversial situations. Ability to exercise discretion in handling confidential information and know how to work with individuals to overcome resistance and motivate others.

**REQUIRED QUALIFICATIONS:**

College Degree in a related field and five (5) years experience; or any equivalent combination of education, training and experience which provides the required knowledge, skills and abilities to perform the essential functions of the job.

**Physical Requirements:**

Few physical demands are required to perform the work. Work effort principally involves sitting to perform work tasks, with intermittent periods of stooping, walking, and standing. May also be some occasional lifting of objects such as office equipment and computer paper (up to 30 lbs.) May occasionally require moving objects, operating a telephone, personal computer and/or most other office equipment including word processing, filing and sorting of papers. Requires daily reading of documents for general understanding and analytical purposes.

Requires motor vehicle and valid driver's license.



# Department of Municipal Licenses and Inspections

Mary E. McGrath, R.S., Director

1 JFK Memorial Drive – Braintree, Massachusetts 02184

Building Division Telephone: 781-794-8070

Fax: 781-794-8022

Health Division Telephone: 781-794-8090

Fax: 781-794-8098

Joseph C. Sullivan  
Mayor

## Town of Braintree

### Grievance Procedure under the Americans with Disabilities Act

This Grievance Procedure is established to meet the requirements of the Americans with Disabilities Act of 1990 ("ADA"). It may be used by anyone who wishes to file a complaint alleging discrimination on the basis of disability in the provision of services, activities, programs, or benefits by the Town of Braintree. The Town's Personnel Policy governs employment-related complaints of disability discrimination.

The complaint should be in writing and contain information about the alleged discrimination such as name, address, phone number of complainant and location, date, and description of the problem. Alternative means of filing complaints, such as personal interviews or a tape recording of the complaint will be made available for persons with disabilities upon request.

The complaint should be submitted by the grievant and/or his/her designee as soon as possible but no later than 60 calendar days after the alleged violation to:

Kristen Zechello, A.D.A. Coordinator

Tel. 781.794.8327

[kzechello@braintreema.gov](mailto:kzechello@braintreema.gov)

Within 15 calendar days after receipt of the complaint, Kristen Zechello, ADA Coordinator, or her designee will meet with the complainant to discuss the complaint and the possible resolutions. Within 15 calendar days of the meeting, Kristen Zechello, ADA Coordinator, or her designee will respond in writing, and where appropriate, in a format accessible to the complainant, such as large print, Braille, or audio tape. The response will explain the position of the Town of Braintree and offer options for substantive resolution of the complaint.

If the response by Kristen Zechello, ADA Coordinator, or her designee does not satisfactorily resolve the issue, the complainant and/or his/her designee may appeal the decision within 15 calendar days after receipt of the response to the Mayor, Joseph C. Sullivan or his designee.

Within 15 calendar days after receipt of the appeal, Mayor, Joseph C. Sullivan or his designee will meet with the complainant to discuss the complaint and possible resolutions. Within 15 calendar days after the meeting, the Mayor, Joseph C. Sullivan or his designee will respond in writing, and, where appropriate, in a format accessible to the complainant, with a final resolution of the complaint.

All written complaints received by Kristen Zechello, ADA Coordinator, or her designee, appeals to the Mayor, Joseph C. Sullivan or his designee, and responses from these two offices will be retained by the Town of Braintree for at least three years.



# Department of Municipal Licenses and Inspections

Mary E. McGrath, R.S., Director

1 JFK Memorial Drive – Braintree, Massachusetts 02184

Building Division Telephone: 781-794-8070

Fax: 781-794-8022

Health Division Telephone: 781-794-8090

Fax: 781-794-8098

Joseph C. Sullivan  
Mayor

## NOTICE UNDER THE AMERICANS WITH DISABILITIES ACT

In accordance with the requirements of title II of the Americans with Disabilities Act of 1990 ("ADA"), the Town of Braintree will not discriminate against qualified individuals with disabilities on the basis of disability in its services, programs, or activities.

**Employment:** The Town of Braintree does not discriminate on the basis of disability in its hiring or employment practices and complies with all regulations promulgated by the U.S. Equal Employment Opportunity Commission under title I of the ADA.

**Effective Communication:** The Town of Braintree will generally, upon request, provide appropriate aids and services leading to effective communication for qualified persons with disabilities so they can participate equally in The Town of Braintree's programs, services, and activities, including qualified sign language interpreters, documents in Braille, and other ways of making information and communications accessible to people who have speech, hearing, or vision impairments.

**Modifications to Policies and Procedures:** The Town of Braintree will make all reasonable modifications to policies and programs to ensure that people with disabilities have an equal opportunity to enjoy all of its programs, services, and activities. For example, individuals with service animals are welcomed in The Town of Braintree offices, even where pets are generally prohibited.

Anyone who requires an auxiliary aid or service for effective communication, or a modification of policies or procedures to participate in a program, service, or activity of The Town of Braintree, should contact the office of **Kristen Zechello, ADA Coordinator at 781-794-8327** as soon as possible but no later than 48 hours before the scheduled event.

The ADA does not require the Town of Braintree to take any action that would fundamentally alter the nature of its programs or services, or impose an undue financial or administrative burden.

Complaints that a program, service, or activity of the Town of Braintree is not accessible to persons with disabilities should be directed to **Kristen Zechello, ADA Coordinator at 781-794-8327**. The Town of Braintree will not place a surcharge on a particular individual with a disability or any group of individuals with disabilities to cover the cost of providing auxiliary aids/services or reasonable modifications of policy, such as retrieving items from locations that are open to the public but are not accessible to persons who use wheelchairs.



# **STREETSCAN**

---

Sidewalk Condition Survey Proposal

Town of Braintree, MA

July 25<sup>th</sup> 2017



---

## Development Partner Proposal

PHASE 1 - ScanCart Technology Development (Oct. 2017)

PHASE 2 – Sidewalk Survey (Oct.-Dec. 2017)

PHASE 3 - Data Processing & delivery (Jan-Feb 2018)


PRICING – Survey Pricing with Development Partner  
Discount



ScanCart



+



Sensors



Tablet & Data Storage



Batteries

Development Timeframe: 2-Months

StreetScan will outfit a 4-wheel cart with similar sensing solution as we have on our ScanVan. The importance in selecting a vehicle was to ensure the width was adequate to fit on the majority of sidewalks. A standard golf cart was not sufficient to meet this requirement.


## PHASE 2 – Sidewalk Survey

Survey Timeframe: 10 Days

ScanCart will have the ability to survey roughly 25 Miles of Sidewalks per day for one 2-man crew.

Sidewalk Attributes	Description
Condition Rating	Overall condition rating of sidewalk, rated from 0 – 10 (excellent)
Tripping Hazard	Geo-referenced tripping hazard with identifying photograph
Uneven Area	Geo-referenced areas with non-level/uneven surfaces
Surface Material	Identification of surface material type, e.g. pavement, asphalt, brick, etc...
ADA Ramp Locations	Geo-referenced ADA ramp locations
Curb Cut Locations	Geo-referenced curb cut locations
Sidewalk Imagery	Geo-referenced imagery of all sidewalks scanned

## PHASE 3 – Data Processing & Delivery



### Data Processing & Delivery: 2-3 Months

Imagery & condition data will be uploaded into your web-based Pavemon portal following the data processing component.

Within Pavemon you will have the ability to run budgetary simulations similar to your current Pavement Management module.

A separate detailed report will also be provided

## PRICING

Assets	Unit	QTY (est.)	Price (\$/Unit)	Cost (est.)
Sidewalk Data Collection	Miles	200	\$150	\$30,000
Sidewalk Data Processing	Miles	200	\$100	\$20,000
Sidewalk Report & Capital Plan	Fixed	1	\$5,000	\$5,000
Software Fees (Sidewalk Module)	Fixed	1	\$5,000	\$1,500
Data Hosting (Imagery & Condition)	Miles	200	\$25	\$5,000
<b>Total</b>				
Total Project Cost				\$61,500
StreetScan Development Partner Discount (20%)				<b>(\$12,300)</b>
Net Project Cost				<b><u>\$49,200</u></b>

**Braintree, MA - ADA Ramp Assessment  
2018**

Address	Ramp ID	ADA Pass/Fail	Num. of Failures	Sidewalk Surface Quality	DWS	DWS Quality	Ramp Width (width > 36")	Landing Compliance (landing > 36"x36")	Ramp Slope	Ramp Cross Slope	Left Flare Slope	Right Flare Slope	Road Slope	Obstruction Violation (no major obstruction)	Longitude	Latitude	Notes
398 TILDEN COMMONS LN	rmp_1	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	2.9	0.8	0.5	1	2.1	Compliant	-70.98422	42.17994	
151 WALNUT ST	rmp_2	Fail	2	Fair	Present	Fair	Compliant	Compliant	0.9	2.9	0.2	4	5	Compliant	-71.012969	42.22	
360 WOOD RD	rmp_3	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	0.5	0.5	0	0	0.9	Compliant	-71.042599	42.21627	
5 HAVEN RD	rmp_4	Pass	0	Good	Present	Good	Compliant	Compliant	3.1	0.2	2.1	3	1.4	Compliant	-70.998805	42.22485	
234 ELM ST	rmp_5	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	1.2	3.7	8.4	2	2.8	Compliant	-70.999366	42.22344	
4 HAVEN RD	rmp_6	Pass	0	Good	Present	Good	Compliant	Compliant	2.6	0.4	1.7	4	0.8	Compliant	-70.998657	42.2247	
6 CEDAR ST	rmp_7	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	1.9	0.6	3.9	0	0.6	Compliant	-70.997925	42.22402	
78 PROSPECT ST NORTH	rmp_8	Pass	0	Good	Present	Good	Compliant	Compliant	1.7	0.6	2	4	0	Compliant	-71.007765	42.22093	
35 ABBOTT ST	rmp_9	Fail	2	Good	Present	Good	Compliant	Not Compliant	0.4	1.6	4.7	0	1.1	Compliant	-71.00782	42.22104	
71 STORRS AV	rmp_10	Fail	1	Good	Present	Good	Compliant	Compliant	1.7	0.4	3.9	1	4.5	Compliant	-71.00737	42.22019	
88 PROSPECT ST NORTH	rmp_11	Fail	1	Good	Present	Good	Compliant	Compliant	1.3	0.5	3.1	4	3.2	Compliant	-71.007937	42.22087	
79 STORRS AV	rmp_12	Fail	2	Fair	Present	Good	Compliant	Compliant	3.5	2.4	5.8	1	2.9	Compliant	-71.007554	42.22018	
87 PROSPECT ST NORTH	rmp_13	Fail	1	Good	Present	Good	Compliant	Compliant	0.3	0.7	3.2	2	3.5	Compliant	-71.007979	42.221	
469 QUINCY AV	rmp_14	Pass	0	Good	Present	Good	Compliant	Compliant	1.6	0.5	0	0	0.1	Compliant	-70.977968	42.23479	
45 CEDAR ST	rmp_15	Pass	0	Good	Present	Good	Compliant	Compliant	3.3	0.3	0.7	4	2.7	Compliant	-70.99907	42.22536	
55 CEDAR ST	rmp_16	Fail	1	Good	Present	Good	Compliant	Compliant	3.4	1.7	5.5	0	2.4	Compliant	-70.999208	42.22542	
87 CEDAR ST	rmp_17	Pass	0	Good	Present	Good	Compliant	Compliant	1.6	0.8	3.3	1	1.4	Compliant	-71.000443	42.22652	
99 CEDAR ST	rmp_18	Fail	1	Good	Present	Good	Compliant	Compliant	4.6	3	0	2	0.6	Compliant	-71.000472	42.22655	
81 CEDAR ST	rmp_19	Pass	0	Good	Present	Good	Compliant	Compliant	3.1	0.1	4.8	4	0.6	Compliant	-70.999962	42.22609	
132 PARK ST	rmp_20	Fail	1	Good	Present	Good	Compliant	Compliant	2.9	0.4	2.4	4	3.2	Compliant	-70.999404	42.22538	
102 PARK ST	rmp_21	Fail	1	Good	Present	Good	Compliant	Compliant	3	0.4	0.3	4	3.1	Compliant	-71.00073	42.22455	
38 LOWELL ST	rmp_22	Pass	0	Good	Present	Good	Compliant	Compliant	4.4	0.2	3.1	0	2.6	Compliant	-71.000655	42.22442	
99 CEDAR ST	rmp_23	Pass	0	Good	Present	Good	Compliant	Compliant	2.9	0.3	4.7	4	2.5	Compliant	-71.000729	42.22677	
2 ELM ST	rmp_24	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	4.7	0.6	1.3	4	2	Compliant	-71.003953	42.22112	
78 PARK ST	rmp_25	Fail	1	Good	Present	Good	Compliant	Compliant	3.2	0.1	3	4	3.1	Compliant	-71.001415	42.22416	
78 PARK ST	rmp_26	Fail	1	Good	Present	Fair	Compliant	Compliant	1.3	0.8	0	3	3.4	Compliant	-71.001457	42.22414	
131 CEDAR ST	rmp_27	Pass	0	Good	Present	Good	Compliant	Compliant	1	0.9	3.6	2	0.5	Compliant	-71.001271	42.22725	
115 CEDAR ST	rmp_28	Pass	0	Good	Present	Good	Compliant	Compliant	1.9	0.2	3.3	1	0.9	Compliant	-71.001214	42.2272	
347 WASHINGTON ST	rmp_29	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	5.2	0.5	3.3	4	2	Not Compliant	-71.004076	42.22065	
1 ELM ST	rmp_30	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	4	0.3	2.8	3	0.5	Compliant	-71.003931	42.22067	
1 ELM ST	rmp_31	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3	0.3	3.8	1	0.8	Compliant	-71.003895	42.22085	
104 WASHINGTON ST	rmp_32	Pass	0	Good	Present	Good	Compliant	Compliant	3	0.5	0	0	0.2	Compliant	-71.003397	42.22875	
1 RUSSELL RD	rmp_33	Pass	0	Good	Present	Good	Compliant	Compliant	3.7	0.5	3.5	4	1	Compliant	-71.003032	42.22931	
8 RUSSELL RD	rmp_34	Pass	0	Good	Present	Good	Compliant	Compliant	3.4	0.2	3.5	5	0.9	Compliant	-71.002951	42.22941	
335 WASHINGTON ST	rmp_35	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4.4	1.5	3.6	2	1	Compliant	-71.004214	42.22113	
339 WASHINGTON ST	rmp_36	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	2.1	3.4	0.6	5	0.7	Not Compliant	-71.00412	42.22076	
347 WASHINGTON ST	rmp_37	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3.3	3.2	4.9	0	0.1	Compliant	-71.004107	42.22068	
2 ELM ST	rmp_38	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	4.3	0.2	2.9	6	2.3	Compliant	-71.004026	42.22116	
196 HAWTHORN RD	rmp_39	Pass	0	Good	Present	Good	Compliant	Compliant	4	0.2	4	1	1.5	Compliant	-71.002588	42.22991	
196 HAWTHORN RD	rmp_40	Pass	0	Good	Present	Good	Compliant	Compliant	3.3	0.3	0.8	4	2.2	Compliant	-71.002618	42.22994	
199 HAWTHORN RD	rmp_41	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	0.3	3.7	2	1.9	Compliant	-71.002568	42.23	
21 SCHOOL ST WEST	rmp_42	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	1.1	0.5	3.6	4	4.9	Compliant	-71.003496	42.22322	
21 SCHOOL ST WEST	rmp_43	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	2.8	0.6	2.4	3	1.5	Compliant	-71.003594	42.22315	
286 WASHINGTON ST	rmp_44	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	3.5	3.2	6.1	1	2.2	Compliant	-71.00459	42.22289	
145 HAWTHORN RD	rmp_45	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	0.5	0	0	0.6	Compliant	-71.000884	42.22857	
155 HAWTHORN RD	rmp_46	Pass	0	Good	Present	Good	Compliant	Compliant	1.2	0.8	0	0	0.6	Compliant	-71.000977	42.22865	
249 WASHINGTON ST	rmp_47	Pass	0	Good	Present	Good	Compliant	Compliant	2.9	0.1	3.6	0	2.5	Compliant	-71.005233	42.22399	
249 WASHINGTON ST	rmp_48	Fail	1	Good	Present	Good	Not Compliant	Compliant	2.7	0.1	1.9	3	0.2	Compliant	-71.005184	42.22393	
249 WASHINGTON ST	rmp_49	Fail	1	Good	Present	Good	Not Compliant	Compliant	2.7	0.1	1.9	3	0.2	Compliant	-71.005184	42.22393	
5 CAVANAUGH RD	rmp_50	Fail	1	Good	Present	Good	Compliant	Compliant	2.5	1.1	2.5	4	5.2	Compliant	-71.005184	42.22426	
246 WASHINGTON ST	rmp_51	Pass	0	Good	Present	Good	Compliant	Compliant	0.3	0.4	4.2	5	2.7	Compliant	-71.004932	42.22402	Brand new pad. Plastic cover.
246 WASHINGTON ST	rmp_52	Fail	1	Good	Present	Good	Compliant	Compliant	3.6	1	4.2	1	3.8	Compliant	-71.004926	42.22416	
10 COMMON ST	rmp_53	Pass	0	Good	Present	Good	Compliant	Compliant	2.9	0.8	3.9	4	2.5	Compliant	-71.005688	42.22419	
111 PRESIDENT RD	rmp_54	Pass	0	Good	Present	Good	Compliant	Compliant	4.2	1.2	4.5	3	0.4	Compliant	-71.004886	42.22436	
115 HAWTHORN RD	rmp_55	Pass	0	Good	Present	Good	Compliant	Compliant	3.7	0.1	0	0	2.5	Compliant	-71.00011	42.2279	
116 HAWTHORN RD	rmp_56	Fail	1	Good	Present	Good	Compliant	Compliant	2	1.3	0	0	1	Compliant	-71.000211	42.22782	
130 HAWTHORN RD	rmp_57	Pass	0	Good	Present	Good	Compliant	Compliant	3.6	0.3	0	0	0.1	Compliant	-71.000294	42.22788	
125 HAWTHORN RD	rmp_58	Pass	0	Good	Present	Good	Compliant	Compliant	3.3	0.1	0	0	1.9	Compliant	-71.000197	42.22793	
97 HAWTHORN RD	rmp_59	Pass	0	Good	Present	Good	Compliant	Compliant	3.6	0.1	0	0	1.2	Compliant	-70.999491	42.22729	
100 HAWTHORN RD	rmp_60	Pass	0	Good	Present	Good	Compliant	Compliant	3.4	0.1	0	0	2	Compliant	-70.999618	42.22724	
100 HAWTHORN RD	rmp_61	Pass	0	Good	Present	Good	Compliant	Compliant	2.2	1.1	0	0	0.6	Compliant	-70.999532	42.22718	
88 HAWTHORN RD	rmp_62	Pass	0	Good	Present	Good	Compliant	Compliant	2.4	0.8	0	0	1.1	Compliant	-70.99945	42.22708	

**Braintree, MA - ADA Ramp Assessment  
2018**

51 STATEN RD	rmp_63	Pass	0	Good	Present	Good	Compliant	Compliant	1.4	0.1	1.8	2	1.7	Compliant	-71.007857	42.2228	
162 PARK ST	rmp_64	Pass	0	Good	Present	Good	Compliant	Compliant	3.2	0.2	4.1	3	1.6	Compliant	-70.998286	42.22601	
52 STATEN RD	rmp_65	Pass	0	Good	Present	Good	Compliant	Compliant	1.4	0.4	3.4	4	2.7	Compliant	-71.00778	42.22268	
70 BESTICK RD	rmp_66	Pass	0	Good	Present	Good	Compliant	Compliant	2.1	0.9	3.5	3	0.2	Compliant	-71.007952	42.22263	
61 STATEN RD	rmp_67	Fail	1	Good	Present	Good	Compliant	Compliant	0.8	0.2	3.4	3	3.5	Compliant	-71.008002	42.22273	
46 PARTRIDGE HILL RD	rmp_68	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	1.9	0.7	2	2	3.4	Compliant	-71.028947	42.2183	
14 HAWTHORN RD	rmp_69	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	2	1.5	5	2	3.7	Compliant	-70.997013	42.22501	
8 HAWTHORN RD	rmp_70	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	0.2	1.2	3.2	5	3	Compliant	-70.996763	42.22466	
8 HAWTHORN RD	rmp_71	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	2.4	0.9	4	4	0.1	Compliant	-70.996755	42.2246	
68 PROSPECT ST NORTH	rmp_72	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	5.4	0.6	0	0	2.3	Compliant	-71.00717	42.22116	
59 BESTICK RD	rmp_73	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	3.6	0.5	0	0	1	Compliant	-71.007544	42.22213	
8 HAWTHORN RD	rmp_74	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	1	2.4	6	0	1.9	Compliant	-70.996639	42.22483	
25 ADAMS ST	rmp_75	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	0.5	2.5	6	1	0.5	Compliant	-70.996592	42.22486	lip at street
30 CHURCH ST	rmp_76	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	1.7	0.1	0.5	4	0.7	Compliant	-71.001876	42.22346	no landing
196 ELM ST	rmp_77	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	1	0.5	2.6	3	0.4	Compliant	-71.000908	42.2229	
196 ELM ST	rmp_78	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	1.8	0.1	4.9	4	1	Compliant	-71.000749	42.22284	
173 ELM ST	rmp_79	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	0.2	0.1	0.5	3	0.2	Compliant	-71.000859	42.22257	
160 ELM ST	rmp_80	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	1	2.5	5.9	0	0.7	Compliant	-71.000996	42.22271	
160 ELM ST	rmp_81	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	0.3	0.4	3.7	3	2.6	Compliant	-71.001763	42.2234	
160 ELM ST	rmp_82	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	0.8	1.7	3.5	4	0.3	Compliant	-71.001069	42.22285	
179 ELM ST	rmp_83	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	0	0.1	2.6	3	0.6	Compliant	-71.000628	42.22269	
216 ELM ST	rmp_84	Fail	4	Poor	Not Present	Not Present	Compliant	Not Compliant	1.2	1.4	3.2	4	2	Compliant	-71.000161	42.22307	
196 ELM ST	rmp_85	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	0.5	1.2	1.9	5	0.2	Compliant	-71.000332	42.22306	
4 PARKSIDE AV	rmp_86	Pass	0	Good	Present	Good	Compliant	Compliant	1.6	0.9	3.7	4	2.7	Compliant	-71.008665	42.22226	
59 ABBOTT ST	rmp_87	Pass	0	Good	Present	Good	Compliant	Compliant	1.6	0.1	3.9	3	1.4	Compliant	-71.008509	42.22234	
69 STATEN RD	rmp_88	Pass	0	Good	Present	Good	Compliant	Compliant	1.1	0.5	3	4	2.6	Compliant	-71.008573	42.22246	
7 PARKSIDE AV	rmp_89	Fail	2	Good	Present	Good	Compliant	Compliant	5.3	1.4	0	0	1.8	Compliant	-71.008734	42.2224	
216 ELM ST	rmp_90	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	2.1	1.6	5.7	6	1.2	Compliant	-70.999534	42.22338	
12 ADAMS ST	rmp_91	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	0.2	0.7	2.4	3	2.8	Compliant	-70.996005	42.22489	
12 ADAMS ST	rmp_92	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	1.6	2.9	6.2	0	3.1	Compliant	-70.995957	42.22481	lip at street
321 ELM ST	rmp_93	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	1.8	0.4	0	2	0.6	Not Compliant	-70.996321	42.22495	Bush on ramp
36 PARKSIDE AV	rmp_94	Fail	1	Fair	Present	Fair	Compliant	Compliant	5.7	0.6	4.7	3	1.8	Compliant	-71.010041	42.22168	
23 PARKSIDE AV	rmp_95	Pass	0	Good	Present	Good	Compliant	Compliant	1.3	0.2	2.6	4	2.5	Compliant	-71.009993	42.22182	
28 PARKSIDE AV	rmp_96	Pass	0	Good	Present	Good	Compliant	Compliant	4.7	0.3	4.1	4	0.6	Compliant	-71.009918	42.22173	
46 ACORN ST	rmp_97	Pass	0	Good	Present	Good	Compliant	Compliant	1.7	1.1	4.1	1	0.5	Compliant	-71.010111	42.22176	
16 SELWYN RD	rmp_98	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	6.3	1.5	4.8	3	1	Compliant	-71.009743	42.17453	
6 SELWYN RD	rmp_99	Fail	5	Good	Not Present	Not Present	Compliant	Not Compliant	8.6	2.3	2.3	7	0.6	Compliant	-71.010312	42.17515	
3 SELWYN RD	rmp_100	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	7.6	0.8	4.9	7	5.3	Compliant	-71.010445	42.1751	
91 SELWYN RD	rmp_101	Fail	6	Fair	Not Present	Not Present	Compliant	Not Compliant	8.9	3.9	17.8	9	0.8	Compliant	-71.007723	42.17323	
147 OLD COUNTRY WY	rmp_102	Fail	2	Poor	Not Present	Not Present	Compliant	Compliant	1.7	0.9	2.6	0	0.2	Compliant	-71.019199	42.17451	
175 OLD COUNTRY WY	rmp_103	Fail	2	Poor	Not Present	Not Present	Compliant	Compliant	2.4	0.6	4.6	2	0.7	Compliant	-71.019145	42.17462	
3 WOODEDGE CR	rmp_104	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	4	2.5	5.7	1	2	Compliant	-71.015192	42.17382	
109 SOUTH ST	rmp_105	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	1.3	2	1.6	7	1	Compliant	-71.015598	42.17229	
3 WOODEDGE CR	rmp_106	Fail	3	Poor	Not Present	Not Present	Compliant	Compliant	1.7	2.2	4.1	2	2.5	Compliant	-71.015076	42.17381	
50 WOODEDGE AV	rmp_107	Fail	3	Poor	Not Present	Not Present	Compliant	Compliant	3	2.1	4.6	0	2.3	Compliant	-71.015853	42.17383	
168 OLD COUNTRY WY	rmp_108	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	2.7	0.6	2.2	4	0.7	Compliant	-71.019287	42.17467	
1969 WASHINGTON ST	rmp_109	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	3.9	0.1	7.3	5	0	Compliant	-71.013393	42.17357	
15 OLD COUNTRY WY	rmp_110	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	2.8	0.8	1.7	5	1.5	Compliant	-71.016496	42.17239	
35 WOODSIDE AV	rmp_111	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.8	1	3.7	4	0.3	Compliant	-71.01649	42.17381	
115 SOUTH ST	rmp_112	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	2.2	1.8	0.7	5	3.6	Compliant	-71.015701	42.17217	
4 WOODEDGE AV	rmp_113	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	1.3	0.1	0	3	2.4	Compliant	-71.013626	42.17367	
158 OLD COUNTRY WY	rmp_114	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	0.6	1.3	4.8	6	1.9	Compliant	-71.019363	42.17457	
1969 WASHINGTON ST	rmp_115	Pass	0	Good	Present	Good	Compliant	Compliant	2.7	0.7	2.7	3	2.1	Compliant	-71.013046	42.17509	
4 WOODEDGE LN	rmp_116	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	0.6	0.4	4	2	1.4	Compliant	-71.015657	42.17381	
1784 WASHINGTON ST	rmp_117	Pass	0	Good	Present	Good	Compliant	Compliant	3	0.2	2.4	3	1.9	Compliant	-71.014669	42.1797	
1712 WASHINGTON ST	rmp_118	Fail	2	Good	Present	Good	Compliant	Compliant	2.7	2.3	0.3	7	0.8	Compliant	-71.013492	42.18158	
1822 WASHINGTON ST	rmp_119	Fail	1	Good	Present	Good	Compliant	Compliant	0.4	2.3	0.1	4	0.7	Compliant	-71.014517	42.17833	
16 PARK AV	rmp_120	Pass	0	Good	Present	Good	Compliant	Compliant	0.5	0.5	0.2	4	1.9	Compliant	-71.013253	42.18188	
1738 WASHINGTON ST	rmp_121	Pass	0	Good	Present	Good	Compliant	Compliant	0.6	0.9	2.4	3	1.4	Compliant	-71.014238	42.18054	
1652 WASHINGTON ST	rmp_122	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	0.6	0.3	2	1	Compliant	-71.012714	42.18252	
1552 WASHINGTON ST	rmp_123	Pass	0	Good	Present	Good	Compliant	Compliant	4.5	0.8	3.5	0	2.4	Compliant	-71.008957	42.18549	
1822 WASHINGTON ST	rmp_124	Fail	1	Good	Present	Good	Compliant	Compliant	1.6	2.7	0.3	4	0.4	Compliant	-71.014479	42.17825	
2 BELLEVUE AV	rmp_125	Fail	1	Good	Present	Good	Compliant	Compliant	1.7	3.5	1.5	3	0.4	Compliant	-71.012608	42.18262	
1712 WASHINGTON ST	rmp_126	Pass	0	Good	Present	Good	Compliant	Compliant	3.4	0.2	2.2	3	0.1	Compliant	-71.013668	42.18135	
1681 WASHINGTON ST	rmp_127	Pass	0	Good	Present	Good	Compliant	Compliant	2.2	0.2	3.4	2	0.2	Compliant	-71.013354	42.18175	

**Braintree, MA - ADA Ramp Assessment  
2018**

1724 WASHINGTON ST	rmp_128	Pass	0	Good	Present	Good	Compliant	Compliant	2.1	0.2	2.7	5	1.1	Compliant	-71.013819	42.18116
1712 WASHINGTON ST	rmp_129	Pass	0	Good	Present	Good	Compliant	Compliant	2.4	0.2	2	2	0.5	Compliant	-71.013589	42.18144
31 ARBUTUS AV	rmp_130	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	1.3	0.7	2.2	3	2.3	Compliant	-71.013582	42.17866
1564 WASHINGTON ST	rmp_131	Fail	1	Good	Present	Good	Compliant	Compliant	2	3.4	0	0	1.1	Compliant	-71.009041	42.18544
1762 WASHINGTON ST	rmp_132	Fail	1	Good	Present	Good	Compliant	Compliant	2.9	1.5	0.7	4	0.3	Compliant	-71.014637	42.17981
1712 WASHINGTON ST	rmp_133	Pass	0	Good	Present	Good	Compliant	Compliant	2.6	1.1	1.5	2	2.1	Compliant	-71.013763	42.18124
1752 WASHINGTON ST	rmp_134	Pass	0	Good	Present	Good	Compliant	Compliant	2.5	1.1	2.7	4	2.3	Compliant	-71.014271	42.18046
85 CAIN AV	rmp_135	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	5.6	3.7	1.8	5	1.2	Compliant	-71.007109	42.17343
1807 WASHINGTON ST	rmp_136	Fail	1	Good	Present	Good	Compliant	Compliant	2.3	3.4	4.7	1	0.2	Compliant	-71.014658	42.17837
1625 WASHINGTON ST	rmp_137	Fail	1	Good	Present	Good	Compliant	Compliant	3.4	1.4	0	0	2.4	Compliant	-71.012283	42.18307
1552 WASHINGTON ST	rmp_138	Pass	0	Good	Present	Good	Compliant	Compliant	1.4	0.4	0.6	2	1.4	Compliant	-71.008723	42.18574
1625 WASHINGTON ST	rmp_139	Fail	1	Good	Present	Good	Compliant	Compliant	0.6	1.5	0	0	1.3	Compliant	-71.012773	42.18263
5 WAMPATUCK RD	rmp_140	Fail	1	Good	Present	Good	Compliant	Compliant	1.5	1.3	0.5	3	2.5	Compliant	-71.014888	42.17917
1751 WASHINGTON ST	rmp_141	Pass	0	Good	Present	Good	Compliant	Compliant	1.7	0.4	0	0	1.1	Compliant	-71.014726	42.17992
1625 WASHINGTON ST	rmp_142	Fail	1	Good	Present	Good	Compliant	Compliant	0.2	2.6	0	0	2	Compliant	-71.012229	42.18313
1701 WASHINGTON ST	rmp_143	Fail	1	Good	Present	Good	Compliant	Compliant	3.7	2.1	0.2	3	2.9	Compliant	-71.014172	42.18085
1731 WASHINGTON ST	rmp_144	Fail	1	Good	Present	Good	Compliant	Compliant	2.1	2.6	4	0	1	Compliant	-71.01423	42.18076
1625 WASHINGTON ST	rmp_145	Pass	0	Good	Present	Good	Compliant	Compliant	2.9	1	0	0	1	Compliant	-71.01283	42.18255
1769 WASHINGTON ST	rmp_146	Pass	0	Good	Present	Good	Compliant	Compliant	3.6	1.2	0	0	1.9	Compliant	-71.014764	42.17984
1552 WASHINGTON ST	rmp_147	Fail	1	Good	Present	Good	Compliant	Compliant	1.3	2.7	5.4	1	0.2	Compliant	-71.008429	42.18597
1801 WASHINGTON ST	rmp_148	Pass	0	Good	Present	Good	Compliant	Compliant	1.6	0.3	1.9	2	2.1	Compliant	-71.014704	42.17847
1791 WASHINGTON ST	rmp_149	Pass	0	Good	Present	Good	Compliant	Compliant	3.9	0.4	0	0	2.7	Compliant	-71.014876	42.17909
266 OLD COUNTRY WY	rmp_150	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	2.3	1.7	1.4	5	2.3	Compliant	-71.014921	42.17511
1899 WASHINGTON ST	rmp_151	Fail	1	Good	Present	Good	Compliant	Compliant	1.5	0.4	1.2	3	3.9	Compliant	-71.013373	42.17518
4 BELKNAP RD	rmp_152	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	3.1	2	2.1	6	1.6	Compliant	-71.008829	42.17494
90 SELWYN RD	rmp_153	Fail	5	Fair	Not Present	Not Present	Compliant	Compliant	10	2	14.3	12	2.5	Compliant	-71.007256	42.1733
105 CAIN AV	rmp_154	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	5.3	0.3	1.3	5	0.7	Compliant	-71.007254	42.17364
35 BELKNAP RD	rmp_155	Fail	5	Good	Not Present	Not Present	Compliant	Not Compliant	1	2.1	9.3	17	0.7	Compliant	-71.007578	42.17405
36 BELKNAP RD	rmp_156	Fail	6	Fair	Not Present	Not Present	Compliant	Not Compliant	9.9	1.3	16.4	9	1.1	Compliant	-71.007581	42.17417
1890 WASHINGTON ST	rmp_157	Pass	0	Good	Present	Good	Compliant	Compliant	1.7	0.2	3.6	1	1.2	Compliant	-71.013423	42.17594
5 WALDRON RD	rmp_158	Pass	0	Good	Present	Good	Compliant	Compliant	1	0.5	0	0	1.2	Compliant	-71.014423	42.1777
1843 WASHINGTON ST	rmp_159	Pass	0	Good	Present	Good	Compliant	Compliant	1.1	0.6	2.6	0	0.8	Compliant	-71.014108	42.17699
1878 WASHINGTON ST	rmp_160	Pass	0	Good	Present	Good	Compliant	Compliant	2.5	0.6	3	2	2.5	Compliant	-71.013464	42.17602
1831 WASHINGTON ST	rmp_161	Fail	1	Good	Present	Good	Compliant	Compliant	1.5	1.5	3.5	2	0.2	Compliant	-71.014379	42.17762
1891 WASHINGTON ST	rmp_162	Fail	1	Good	Present	Good	Compliant	Compliant	3	3.3	0	0	1.1	Compliant	-71.013587	42.17601
2 MILTON RD	rmp_163	Pass	0	Good	Present	Good	Compliant	Compliant	1.5	1.2	2.6	2	0.7	Compliant	-71.012738	42.17497
1899 WASHINGTON ST	rmp_164	Pass	0	Good	Present	Good	Compliant	Compliant	3.3	1.1	3.9	1	0.5	Compliant	-71.013283	42.17533
1899 WASHINGTON ST	rmp_165	Pass	0	Good	Present	Good	Compliant	Compliant	3.3	1.1	3.9	1	0.5	Compliant	-71.013283	42.17533
1851 WASHINGTON ST	rmp_166	Fail	1	Good	Present	Good	Compliant	Compliant	2.7	2.5	3	1	0.8	Compliant	-71.014078	42.17692
15 SOUTH ST	rmp_167	Pass	0	Fair	Present	Good	Compliant	Compliant	4.5	0.4	0	0	0.1	Compliant	-71.013432	42.17512
1891 WASHINGTON ST	rmp_168	Pass	0	Good	Present	Good	Compliant	Compliant	1.4	0.1	1.9	2	1.5	Compliant	-71.01355	42.17594
3 MILTON RD	rmp_169	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	1.2	1.3	3	1.4	Compliant	-71.012671	42.1749
69 LEAHAVEN TR	rmp_170	Fail	3	Poor	Not Present	Not Present	Compliant	Compliant	2.6	2	4	2	0.7	Compliant	-71.017301	42.17513
74 WOODSIDE AV	rmp_171	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	3.3	1.6	4.1	2	5.1	Compliant	-71.016529	42.17512
267 OLD COUNTRY WY	rmp_172	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	3.4	1.8	4.7	1	2.3	Compliant	-71.01491	42.17502
6 LEAHAVEN TR	rmp_173	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4.4	2.6	1	4	1.3	Compliant	-71.017628	42.17255
75 WOODSIDE AV	rmp_174	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	4	4.3	7.8	1	2.3	Compliant	-71.016366	42.17514
6 LEAHAVEN TR	rmp_175	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	2	1.2	2	4	1.7	Compliant	-71.017698	42.17252
279 OLD COUNTRY WY	rmp_176	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	1.3	0.8	1.4	0	0.4	Not Compliant	-71.014766	42.17501
4 BRAMBLEWOOD LN	rmp_177	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	5.8	1.1	1.9	3	1.6	Compliant	-71.006359	42.17361
131 WILDWOOD AV	rmp_178	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	3.5	0.7	0.7	3	1.1	Compliant	-71.005003	42.17707
4 MANN ST	rmp_179	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	0.3	0.8	4.4	4	0.7	Compliant	-71.004794	42.17615
141 WILDWOOD AV	rmp_180	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	2.6	0.3	5.2	5	2.3	Compliant	-71.004841	42.17703
1 MANN ST	rmp_181	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	2.1	2.2	1.7	6	1.4	Compliant	-71.004945	42.1763
16 MANN ST	rmp_182	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	2.8	2.1	4	3	2.4	Compliant	-71.003826	42.17561
54 ARBUTUS AV	rmp_183	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	3.6	1.2	3.9	2	3.7	Compliant	-71.012238	42.17945
55 ARBUTUS AV	rmp_184	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.9	1.2	4	3	0.5	Compliant	-71.01217	42.17936
44 ARBUTUS AV	rmp_185	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	2.1	0.3	2.8	3	3.8	Compliant	-71.012895	42.17911
58 MASS AV	rmp_186	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	4.8	1.1	1.5	2	1.4	Compliant	-71.01214	42.17949
66 MASS AV	rmp_187	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	0	0.4	4.4	4	0	Compliant	-71.012071	42.17941
15 ARBUTUS AV	rmp_188	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.2	0.4	3.7	4	0.4	Compliant	-71.013673	42.17862
56 WINTHROP AV	rmp_189	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	1.4	1.8	3.4	4	2.7	Compliant	-71.012867	42.17904
35 ARBUTUS AV	rmp_190	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	0	1.2	3.6	3	0.5	Compliant	-71.012928	42.17899
34 ARBUTUS AV	rmp_191	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	0.9	1.5	1.3	2	0.3	Compliant	-71.012983	42.17907
18 MANN ST	rmp_192	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.3	0.3	3.7	3	1	Compliant	-71.00371	42.17562

**Braintree, MA - ADA Ramp Assessment  
2018**

5 MANN ST	rmp_193	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	1	4.3	6	1	1.2	Compliant	-71.00495	42.17616
40 MANN ST	rmp_194	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.9	0.6	2.3	1	1.9	Compliant	-71.002755	42.17568
177 WILDWOOD AV	rmp_195	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.6	0.7	3.1	3	1.6	Compliant	-71.002858	42.17677
169 WILDWOOD AV	rmp_196	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	3.3	3	0.4	6	4.6	Compliant	-71.003632	42.17688
157 WILDWOOD AV	rmp_197	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4.8	1.7	2.9	3	1.3	Compliant	-71.003784	42.17688
189 WILDWOOD AV	rmp_198	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	2	1.1	0.6	4	0.9	Compliant	-71.002699	42.17674
26 MANN ST	rmp_199	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	1.6	1.3	5.5	2	1.6	Compliant	-71.002903	42.17563
17 MANN ST	rmp_200	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.2	0.4	2.8	3	1.2	Compliant	-71.003676	42.17551
1407 WASHINGTON ST	rmp_201	Pass	0	Good	Present	Good	Compliant	Compliant	0.9	0	1.9	4	1	Compliant	-71.007213	42.18983
325 HANCOCK ST	rmp_202	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	1.2	0	0	2.8	Compliant	-71.006591	42.19198
389 HANCOCK ST	rmp_203	Fail	1	Good	Present	Good	Compliant	Compliant	2.7	1.5	0	0	0.8	Compliant	-71.007179	42.18992
4 HIGHLAND AV	rmp_204	Pass	0	Good	Present	Good	Compliant	Compliant	2.6	1.2	0	0	1.8	Compliant	-71.006618	42.1919
1450 WASHINGTON ST	rmp_205	Fail	2	Good	Present	Good	Compliant	Compliant	0.7	3.7	5	1	3.5	Compliant	-71.007559	42.1884
1445 WASHINGTON ST	rmp_206	Pass	0	Good	Present	Good	Compliant	Compliant	0.6	0.4	2.7	5	1.5	Compliant	-71.007536	42.18848
1450 WASHINGTON ST	rmp_207	Fail	1	Good	Present	Good	Compliant	Compliant	0.7	3.5	4.3	3	1.3	Compliant	-71.007576	42.18835
1450 WASHINGTON ST	rmp_208	Fail	1	Good	Present	Good	Compliant	Compliant	0.8	1.8	0.3	4	0.6	Compliant	-71.007485	42.18833
70 LEHAVEN TR	rmp_209	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	3.8	1.5	3.2	1	0.7	Compliant	-71.017467	42.17515
23 OLD COUNTRY WY	rmp_210	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	3.8	0.1	3.1	6	1.2	Compliant	-71.016677	42.17241
5 MAPLEWOOD TR	rmp_211	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	1.9	0.7	1.8	3	1.5	Compliant	-71.00617	42.17473
6 MAPLEWOOD TR	rmp_212	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	4.6	7.3	4.2	6	3.4	Compliant	-71.006127	42.17484
3 BRAMBLEWOOD LN	rmp_213	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	7	1.4	2.4	6	0.5	Compliant	-71.006173	42.17361
77 CRANMORE RD	rmp_214	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	7.2	0.7	5	10	1	Compliant	-71.008443	42.17709
30 SELWYN RD	rmp_215	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	4.6	0.8	3.1	5	1.5	Compliant	-71.009676	42.17445
7 SMITH ST	rmp_216	Fail	1	Good	Present	Good	Compliant	Compliant	1.2	0.1	3.3	0	5.8	Compliant	-71.006156	42.19316
305 HANCOCK ST	rmp_217	Fail	1	Good	Present	Good	Compliant	Compliant	3.8	0.7	2.8	4	3.1	Compliant	-71.006206	42.19308
REAR PLAIN ST	rmp_218	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	4	1.2	7.4	4	1.1	Compliant	-71.005011	42.19602
1172 WASHINGTON ST	rmp_219	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	2.1	0.8	2.9	5	2	Compliant	-71.005343	42.1964
1177 WASHINGTON ST	rmp_220	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	2.1	0.6	3.9	5	0.5	Compliant	-71.005305	42.19601
35 ALDEN RD	rmp_221	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	6.7	3.3	4.7	4	2.3	Compliant	-71.008904	42.17682
36 ALDEN RD	rmp_222	Fail	6	Fair	Not Present	Not Present	Compliant	Not Compliant	9.5	1.7	7.9	10	0.5	Compliant	-71.008814	42.17691
75 WILDWOOD AV	rmp_223	Fail	3	Poor	Not Present	Not Present	Compliant	Compliant	0.4	1.4	3.3	2	0.9	Compliant	-71.007234	42.17857
11 CRANMORE RD	rmp_224	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	6.3	0.4	5.5	6	0.4	Compliant	-71.008957	42.1749
85 WILDWOOD AV	rmp_225	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	6.8	0.9	5.2	1	0.2	Compliant	-71.007087	42.17844
2089 WASHINGTON ST	rmp_226	Fail	2	Poor	Present	Good	Compliant	Compliant	3.3	1.5	0	0	0.2	Compliant	-71.008269	42.16982
2099 WASHINGTON ST	rmp_227	Pass	0	Good	Present	Good	Compliant	Compliant	3.9	0.5	0	0	0.1	Compliant	-71.008213	42.16975
30 MILTON RD	rmp_228	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	9	2.5	12.1	3	2.3	Compliant	-71.011322	42.17486
5 WATER ST	rmp_229	Pass	0	Good	Present	Good	Compliant	Compliant	1.8	0.6	1.1	1	1.8	Compliant	-71.008321	42.17004
105 MILTON RD	rmp_230	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	5.3	0.8	6.7	2	0.2	Compliant	-71.009288	42.17249
17 VIRGINIA RD	rmp_231	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	6.8	0.8	1.9	4	1.4	Compliant	-71.009202	42.17237
2016 WASHINGTON ST	rmp_232	Pass	0	Good	Present	Good	Compliant	Compliant	1.7	0.3	2.4	3	0.2	Compliant	-71.010124	42.17211
1960 WASHINGTON ST	rmp_233	Fail	1	Good	Present	Good	Compliant	Compliant	5.3	0.7	2.3	3	2.1	Compliant	-71.011556	42.17363
101 ARBUTUS AV	rmp_234	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	0.8	1.1	4.2	2	2.2	Compliant	-71.010607	42.18017
73 STANDISH AV	rmp_235	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.5	0.9	3.1	2	0.9	Compliant	-71.011437	42.17974
72 STANDISH AV	rmp_236	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	0.8	1.4	2.2	4	1.3	Compliant	-71.011348	42.17978
28 WILDWOOD AV	rmp_237	Fail	2	Good	Present	Good	Compliant	Not Compliant	0.7	2	0.1	4	2.1	Compliant	-71.008621	42.18034
30 SHERATON AV	rmp_238	Pass	0	Good	Present	Good	Compliant	Compliant	1.5	0	3.5	3	2.5	Compliant	-71.008788	42.18036
16 WILDWOOD AV	rmp_239	Pass	0	Good	Present	Good	Compliant	Compliant	1.1	0.9	4.2	0	0.4	Compliant	-71.008693	42.18041
91 ARBUTUS AV	rmp_240	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	1.6	1.6	0.9	3	4.5	Compliant	-71.010692	42.1801
66 STANDISH AV	rmp_241	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	1.3	0.7	3.1	3	5.6	Not Compliant	-71.011401	42.17986
33 WATER ST	rmp_242	Fail	2	Good	Not Present	Not Present	Not Compliant	Compliant	1.4	1.2	1.7	5	0.5	Compliant	-71.006742	42.17027
82 WATER ST	rmp_243	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.7	0.3	4.2	1	1.5	Compliant	-71.004466	42.1704
3 CAIN AV	rmp_244	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.1	0.8	3.4	1	0.3	Compliant	-71.006772	42.17036
50 LIVOLI AV	rmp_245	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	2.2	0.8	1.9	2	2.2	Compliant	-71.004498	42.17027
10 WATER ST	rmp_246	Pass	0	Good	Present	Good	Compliant	Compliant	1.8	0.7	1.3	2	1.2	Compliant	-71.00847	42.17023
4 PAUL ST	rmp_247	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.5	0.3	0.9	4	1.8	Compliant	-71.005433	42.17039
28 WATER ST	rmp_248	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	0.9	0.4	3.2	1	1.7	Compliant	-71.006899	42.17037
74 WATER ST	rmp_249	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.6	0.7	2.5	2	0.4	Compliant	-71.0053	42.17039
63 WATER ST	rmp_250	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	0.4	0.3	5.3	1	0.7	Compliant	-71.005389	42.17028
5 WATER ST	rmp_251	Pass	0	Good	Present	Good	Compliant	Compliant	2.9	0.8	2.7	2	0.4	Compliant	-71.008391	42.17014
238 GROVE ST	rmp_252	Fail	3	Poor	Not Present	Not Present	Compliant	Compliant	9.9	0.9	3.8	5	2.7	Compliant	-70.986218	42.18929
884 LIBERTY ST	rmp_253	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4.2	0.8	1.5	6	0.8	Compliant	-70.985376	42.19258
238 GROVE ST	rmp_254	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	10	0	5.1	4	1.1	Compliant	-70.986072	42.18977
884 LIBERTY ST	rmp_255	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	6.5	2.5	0	0	0.3	Compliant	-70.984374	42.19238
REAR LIBERTY ST	rmp_256	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	3	2.2	0	0	0.1	Not Compliant	-70.984477	42.19152
238 GROVE ST	rmp_257	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	7.2	1	2.2	4	0.2	Compliant	-70.986049	42.18996

**Braintree, MA - ADA Ramp Assessment  
2018**

832 LIBERTY ST	rmp_258	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4.9	0.2	4.9	2	1.7	Compliant	-70.984646	42.19387	
884 LIBERTY ST	rmp_259	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	6	0.8	0	0	0.9	Compliant	-70.984141	42.19239	
971 LIBERTY ST	rmp_260	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	6	2.4	1.8	4	0	Compliant	-70.985443	42.19243	
23 PORTLAND RD	rmp_261	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3.7	0.7	4.3	2	6.3	Compliant	-70.995088	42.18644	
6 TRAINOR DR	rmp_262	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	3	0.2	2.9	2	4.1	Compliant	-70.991765	42.18705	
11 KENMORE RD	rmp_263	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	6.2	1.9	4.7	4	0.3	Compliant	-70.995874	42.18489	
11 PORTLAND RD	rmp_264	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4	0.7	1.1	6	2.1	Compliant	-70.994984	42.18639	
1229 LIBERTY ST	rmp_265	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	2.2	1.2	4.1	3	0.7	Compliant	-70.994946	42.18467	
10 PORTLAND RD	rmp_266	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.4	1.1	2.2	6	1.4	Compliant	-70.995038	42.1863	
24 PORTLAND RD	rmp_267	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	4.9	1.7	2.9	7	0.9	Compliant	-70.995131	42.18636	
23 KENMORE RD	rmp_268	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	5.7	0.5	2.8	4	0.8	Compliant	-70.995993	42.18493	
1 PROCTOR RD	rmp_269	Fail	4	Fair	Not Present	Not Present	Compliant	Compliant	4.4	2.8	1.2	6	3.4	Compliant	-70.991644	42.18703	
49 PROCTOR RD	rmp_270	Fail	1	Good	Present	Good	Compliant	Compliant	2.7	0.1	2.6	1	5.2	Compliant	-70.993882	42.18638	
67 PROCTOR RD	rmp_271	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	2.7	1.8	5.2	2	0.8	Compliant	-70.994348	42.18602	
6 PORTLAND RD	rmp_272	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	2.5	0	5.8	5	0.1	Compliant	-70.994427	42.18594	
841 LIBERTY ST	rmp_273	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	2.8	0.5	1.5	6	6.2	Compliant	-70.984119	42.1949	
718 LIBERTY ST	rmp_274	Fail	1	Good	Present	Good	Compliant	Compliant	4.2	1.2	5	8	1.4	Compliant	-70.984643	42.1972	
821 LIBERTY ST	rmp_275	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	5.3	0	3.1	3	2.4	Compliant	-70.983975	42.19512	
1393 LIBERTY ST	rmp_276	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3.4	0.7	1.7	3	3.8	Compliant	-70.997268	42.17923	
1275 LIBERTY ST	rmp_277	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	3.4	0.4	3.4	3	2.7	Compliant	-70.996118	42.1835	
1237 LIBERTY ST	rmp_278	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3.6	1.7	3.8	3	2.7	Compliant	-70.995122	42.18451	
268 PEACH ST	rmp_279	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	4	0.3	4.9	3	1.3	Compliant	-70.996316	42.18337	
398 TILDEN COMMONS LN	rmp_280	Fail	4	Poor	Not Present	Not Present	Compliant	Compliant	2.7	1.2	5.8	2	3	Compliant	-70.997157	42.17923	
1229 LIBERTY ST	rmp_281	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	5.8	0	1.6	5	0	Compliant	-70.995037	42.18458	
1065 LIBERTY ST	rmp_282	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	6.3	1.3	5.5	4	2.5	Compliant	-70.989016	42.1877	
8 FOREST ST	rmp_283	Fail	1	Good	Present	Good	Compliant	Compliant	0.5	0.9	0.6	4	3.6	Compliant	-70.988727	42.18766	
1070 LIBERTY ST	rmp_284	Fail	1	Good	Present	Good	Compliant	Compliant	1.5	1.3	2.6	3	0.1	Compliant	-70.988946	42.18762	
44 KENDALL AV	rmp_285	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	0.1	0.2	4.4	3	2.3	Compliant	-70.991699	42.20093	
33 CONGRESS ST	rmp_286	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	1.6	0.4	3.9	4	0.6	Compliant	-70.988784	42.20193	
116 BOSCOBEL ST	rmp_287	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	1.2	0.1	1.7	1	5.6	Compliant	-70.990416	42.20069	
292 PLAIN ST	rmp_288	Pass	0	Good	Present	Good	Compliant	Compliant	1.2	0.1	0	0	0.1	Compliant	-70.99269	42.19932	
103 CONGRESS ST	rmp_289	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	1.6	2.9	5.1	2	2.9	Compliant	-70.989534	42.19961	
6 SPRING ST	rmp_290	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	2.1	0.8	3.9	4	1.1	Compliant	-70.988797	42.20182	
115 BOSCOBEL ST	rmp_291	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	4.2	0.7	3.3	3	2.6	Compliant	-70.990418	42.20058	
137 CONGRESS ST	rmp_292	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3	1.8	4.4	2	2.7	Compliant	-70.99068	42.19976	
97 EAST BOSCOBEL ST	rmp_293	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	0.9	1.9	2.6	3	2.3	Compliant	-70.99174	42.20084	
142 CONGRESS ST	rmp_294	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	4.3	0.3	4.3	4	0	Compliant	-70.99059	42.19964	
82 SPRING ST	rmp_295	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3.7	1.5	3	4	0.6	Compliant	-70.990518	42.19975	
161 CONGRESS ST	rmp_296	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	4	0.2	2	4	3.4	Compliant	-70.992263	42.20005	
112 CONGRESS ST	rmp_297	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	2.9	1.9	3.2	3	2.2	Compliant	-70.989278	42.19962	
174 CONGRESS ST	rmp_298	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	2.9	4	2.1	6	2	Compliant	-70.992344	42.19994	
56 PARK AV	rmp_299	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	1.2	3.6	1	2.6	Compliant	-71.010828	42.18149	
15 STANDISH AV	rmp_300	Pass	0	Good	Present	Fair	Compliant	Compliant	2.9	0.9	4.8	0	0.2	Compliant	-71.012978	42.18145	
53 PARK AV	rmp_301	Fail	1	Good	Present	Good	Compliant	Compliant	1.2	0.5	2.3	2	3.3	Compliant	-71.010844	42.18141	
247 PEARL ST	rmp_302 der	Construct	0	Good	Not Present	Not Present	Compliant	Not Compliant	0	0	0	0	0	Compliant	-70.995205	42.20304	under construction
3 WEBB ST	rmp_303	Fail	1	Good	Present	Good	Compliant	Compliant	1.5	0.8	4.2	0	3.9	Compliant	-70.99284	42.20173	
180 PEARL ST	rmp_304	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	6.6	0.9	3.5	4	0.1	Compliant	-70.998138	42.20334	
180 PEARL ST	rmp_305	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	4.6	1.6	3.3	5	0.7	Compliant	-70.998284	42.20353	
11 WEBB ST	rmp_306	Pass	0	Good	Present	Good	Compliant	Compliant	1.2	0.6	3.4	2	0.9	Compliant	-70.993044	42.20124	
355 PEARL ST	rmp_307 der	Construct	0	Good	Not Present	Not Present	Compliant	Not Compliant	0	0	0	0	0	Compliant	-70.991384	42.20252	under construction
4 WEBB ST	rmp_308	Pass	0	Good	Present	Good	Compliant	Compliant	1.8	0.4	2.1	4	2	Compliant	-70.992689	42.20168	
86 BOSCOBEL ST	rmp_309	Pass	0	Good	Present	Good	Compliant	Compliant	1.1	0.3	2.7	4	2.6	Compliant	-70.99184	42.20094	
12 WEBB ST	rmp_310	Fail	1	Good	Present	Good	Compliant	Compliant	1.7	1.2	2.1	4	3.7	Compliant	-70.992931	42.20124	
363 PEARL ST	rmp_311 der	Construct	0	Good	Not Present	Not Present	Compliant	Not Compliant	0	0	0	0	0	Compliant	-70.991276	42.20255	under construction
252 WILDWOOD AV	rmp_312	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	0.6	4.2	2	0.1	Compliant	-70.999688	42.17641	
15 STANDISH AV	rmp_313	Fail	1	Good	Present	Good	Compliant	Compliant	2.9	0.3	0	4	3.7	Compliant	-71.012835	42.18144	
252 WILDWOOD AV	rmp_314	Pass	0	Fair	Present	Good	Compliant	Compliant	0.6	0.6	4.9	2	1.5	Compliant	-70.999796	42.17641	
160 WILDWOOD AV	rmp_315	Pass	0	Fair	Present	Good	Compliant	Compliant	1.1	1	4.3	1	0.8	Compliant	-71.003629	42.17697	
174 WILDWOOD AV	rmp_316	Pass	0	Good	Present	Good	Compliant	Compliant	1.6	0.3	2.8	3	1.5	Compliant	-71.003486	42.17695	
245 WILDWOOD AV	rmp_317	Pass	0	Good	Present	Good	Compliant	Compliant	1.7	0	2.1	3	1.8	Compliant	-70.999742	42.17631	
50 FOUNTAIN ST	rmp_318	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	1.8	1	4.5	1	1.9	Compliant	-70.995894	42.20132	
63 FOUNTAIN ST	rmp_319	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	3.4	2.6	4.1	5	1.8	Compliant	-70.996148	42.20113	
17 FOUNTAIN ST	rmp_320	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	3.4	4	1.3	5	2.6	Compliant	-70.995607	42.20238	
42 FOUNTAIN ST	rmp_321	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	4.4	0.4	4.3	2	1.4	Compliant	-70.995749	42.20175	
239 PEARL ST	rmp_322 der	Construct	0	Good	Not Present	Not Present	Compliant	Not Compliant	0	0	0	0	0	Compliant	-70.995302	42.20308	under construction

**Braintree, MA - ADA Ramp Assessment  
2018**

15 FOUNTAIN ST	rmp_323	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	5.9	0.2	4.8	6	2	Compliant	-70.995522	42.20251
50 FOUNTAIN ST	rmp_324	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	3.3	0.7	5.4	2	0.8	Compliant	-70.995932	42.20123
53 FOUNTAIN ST	rmp_325	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	3	1.9	1	3	2.2	Compliant	-70.996055	42.20133
53 FOUNTAIN ST	rmp_326	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	2.9	0.6	0	4	1.6	Compliant	-70.996081	42.20126
56 FOUNTAIN ST	rmp_327	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	5.5	0.9	4.1	2	4.3	Compliant	-70.99601	42.20113
978 LIBERTY ST	rmp_328	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	7.9	2.5	2.8	5	0.4	Compliant	-70.986017	42.18925
978 LIBERTY ST	rmp_329	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	7.6	1.8	4.5	6	1.7	Compliant	-70.986055	42.18919
14 KIMBALL RD	rmp_330	Pass	0	Fair	Present	Good	Compliant	Compliant	3.3	0.5	2.7	3	0.4	Compliant	-71.004975	42.18586
6 CELIA RD	rmp_331	Pass	0	Good	Present	Good	Compliant	Compliant	2.8	0.7	1.9	3	1.8	Compliant	-71.004785	42.18606
2 GROVE CR	rmp_332	Fail	1	Good	Present	Good	Compliant	Compliant	0.2	1.6	3.6	2	0.7	Compliant	-70.996019	42.19484
14 KIMBALL RD	rmp_333	Pass	0	Fair	Present	Good	Compliant	Compliant	2.3	1.2	0	0	0.2	Compliant	-71.004931	42.18594
61 GROVE ST	rmp_334	Pass	0	Good	Present	Good	Compliant	Compliant	0.5	0.2	3.4	2	0.5	Compliant	-70.996175	42.19495
5 CELIA RD	rmp_335	Pass	0	Good	Present	Good	Compliant	Compliant	1.2	0.2	2.1	4	0.8	Compliant	-71.00481	42.18595
15 STONE CREST DR	rmp_336	Pass	0	Good	Present	Good	Compliant	Compliant	1.7	0.1	2	4	1.8	Compliant	-70.994717	42.19427
74 PEACH ST	rmp_337	Fail	1	Good	Present	Good	Compliant	Compliant	2.2	1.4	3.9	1	0.3	Compliant	-71.005185	42.18527
86 PEACH ST	rmp_338	Pass	0	Good	Present	Good	Compliant	Compliant	0.3	0.7	0	4	1.8	Compliant	-71.005017	42.18524
10 STONE CREST DR	rmp_339	Pass	0	Good	Present	Good	Compliant	Compliant	4.2	0.4	4.7	3	0.1	Compliant	-70.994525	42.19419
160 GROVE ST	rmp_340	Fail	2	Good	Present	Good	Compliant	Compliant	1.6	3.5	4.7	1	5.5	Compliant	-70.992547	42.1934
1217 WASHINGTON ST	rmp_341	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	4.1	2.3	0.3	4	1.9	Compliant	-71.005624	42.1955
1177 WASHINGTON ST	rmp_342	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	4.9	0.9	0	0	0.1	Compliant	-71.005341	42.19612
1207 WASHINGTON ST	rmp_343	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	8.3	0.6	6.6	0	0.8	Compliant	-71.005475	42.19533
1177 WASHINGTON ST	rmp_344	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	1.7	1.1	6.8	2	0.5	Compliant	-71.005312	42.19608
39 HIGHLAND AV	rmp_345	Pass	0	Good	Present	Good	Compliant	Compliant	3	1.2	0.9	4	1.8	Compliant	-71.008323	42.19199
214 JEFFERSON ST	rmp_346	Pass	0	Good	Present	Good	Compliant	Compliant	1.3	0.2	1.7	4	0.8	Compliant	-71.009057	42.192
29 HIGHLAND AV	rmp_347	Pass	0	Good	Present	Good	Compliant	Compliant	0.2	0.6	2.8	1	0.3	Compliant	-71.008182	42.19201
1505 BRAXTON ST	rmp_348	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	2.4	0.4	8.4	4	2.8	Compliant	-71.010533	42.18866
37 PEARL ST	rmp_349	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	4.4	1.2	2.5	6	2.5	Compliant	-71.004113	42.20219
15 CRESCENT AV	rmp_350	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	3.2	3.7	0	0	2.4	Compliant	-71.004235	42.202
89 PEARL ST	rmp_351	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	4	3.7	1.1	6	1.3	Compliant	-71.002637	42.20227
119 PLAIN ST	rmp_352	Fail	1	Good	Present	Good	Compliant	Compliant	0.3	0.1	0.1	3	6	Compliant	-70.999333	42.19663
145 PEARL ST	rmp_353	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	5.3	4	5.3	9	0.5	Compliant	-71.000655	42.20255
120 PEARL ST	rmp_354	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	4.8	0.2	5.9	4	2.8	Compliant	-71.000377	42.20282
766 WASHINGTON ST	rmp_355	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	3.9	1.4	4.5	1	5.5	Compliant	-71.004063	42.20723
4 8 FRENCH AV	rmp_356	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	3.7	2.3	6.6	0	2.8	Compliant	-71.0026	42.20278
145 PEARL ST	rmp_357	Fail	5	Good	Not Present	Not Present	Compliant	Not Compliant	1.9	4.9	3.2	13	4.8	Compliant	-71.00033	42.20264
120 PEARL ST	rmp_358	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	7.8	0.4	5.6	3	3.6	Compliant	-71.000604	42.20275
180 PEARL ST	rmp_359	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	4.1	1.9	1.7	6	3.9	Compliant	-70.995508	42.20486
120 PEARL ST	rmp_360	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	7	3.2	9.8	2	1.1	Compliant	-71.000113	42.20293
120 PEARL ST	rmp_361	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	4.1	0.3	5.6	3	2.8	Compliant	-71.000183	42.20305
120 PEARL ST	rmp_362	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4.8	1.2	3.2	9	1.3	Compliant	-71.000182	42.20287
14 UNION PL	rmp_363	Fail	1	Good	Present	Good	Compliant	Compliant	4.4	1.4	4.2	2	1.7	Compliant	-71.003627	42.20729
183 PEARL ST	rmp_364	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	7	0.8	3.7	4	0.2	Compliant	-70.998435	42.20328
108 UNION ST	rmp_365	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	6.1	0.5	7.7	5	0.4	Compliant	-71.000155	42.20885
148 HANCOCK ST	rmp_366	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	5.4	1	0	0	8.4	Compliant	-71.005032	42.19791
4 8 FRENCH AV	rmp_367	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	5.6	1.1	2.6	3	1.9	Compliant	-71.002548	42.20327
89 PEARL ST	rmp_368	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	2.2	4.7	5.7	2	0.6	Compliant	-71.002578	42.20245
100 PEARL ST	rmp_369	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	6.6	0.8	2.2	7	3.6	Compliant	-70.999689	42.20289
180 PEARL ST	rmp_370	Fail	6	Fair	Not Present	Not Present	Compliant	Not Compliant	5.6	1.3	4.6	6	5.8	Compliant	-70.999666	42.20502
120 PEARL ST	rmp_371	Fail	5	Good	Not Present	Not Present	Compliant	Not Compliant	5.9	3.3	7.8	3	1.8	Compliant	-71.000667	42.20271
38 WASHINGTON PARK RD	rmp_372	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	0.7	0.3	2	2	1.9	Compliant	-71.002551	42.20574
120 PEARL ST	rmp_373	Fail	4	Poor	Not Present	Not Present	Compliant	Compliant	6.2	1.5	0	0	0.7	Compliant	-71.000058	42.20309
280 IVORY ST	rmp_374	Fail	4	Fair	Not Present	Not Present	Compliant	Compliant	5.8	3	2.6	5	3.6	Compliant	-70.999931	42.20553
120 PEARL ST	rmp_375	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	4.4	1.5	0	2	2.8	Compliant	-71.001957	42.20225
90 HANCOCK ST	rmp_376	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.4	1.1	0	0	0.5	Compliant	-71.005038	42.19991
280 IVORY ST	rmp_377	Fail	5	Fair	Not Present	Not Present	Compliant	Compliant	5.1	1.5	6	2	4.4	Compliant	-71.000056	42.20666
39 WASHINGTON PARK RD	rmp_378	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	1.8	0.1	2.1	3	1.3	Compliant	-71.002575	42.20561
48 HANCOCK ST	rmp_379	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	5.1	0.6	3.6	2	1.9	Compliant	-71.004977	42.20142
15 CRESCENT AV	rmp_380	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	4.6	1.2	3.8	4	2	Compliant	-71.004984	42.20154
120 PEARL ST	rmp_381	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	4.8	0	0	0	2.1	Compliant	-71.002121	42.20247
121 PEARL ST	rmp_382	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	8.9	2.5	3.1	4	0.9	Compliant	-71.001939	42.20235
180 PEARL ST	rmp_383	Fail	3	Poor	Not Present	Not Present	Compliant	Not Compliant	3.2	1.1	2.4	2	1	Compliant	-70.998531	42.20348
121 PEARL ST	rmp_384	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	4.6	0.1	3.2	6	1.6	Compliant	-71.001793	42.20237
100 PEARL ST	rmp_385	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	6.3	0.2	4.8	4	2.9	Compliant	-70.999811	42.20284
280 IVORY ST	rmp_386	Fail	5	Poor	Not Present	Not Present	Compliant	Not Compliant	2.3	1.4	4.7	4	4.1	Compliant	-71.000026	42.20688
148 HANCOCK ST	rmp_387	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	3.4	2.3	0	0	3.8	Compliant	-71.005031	42.19781

**Braintree, MA - ADA Ramp Assessment  
2018**

25 PEARL ST	rmp_388	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	4.8	0.6	1.9	4	0.7	Compliant	-71.004265	42.20218
240 IVORY ST	rmp_389	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	3.1	0.7	0	0	1.8	Compliant	-70.999828	42.20533
119 PLAIN ST	rmp_390	Fail	1	Good	Present	Good	Compliant	Compliant	0.6	0.9	3	4	3.2	Compliant	-70.999351	42.19651
15 CRESCENT AV	rmp_391	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	6.3	0.4	0	0	0.1	Compliant	-71.004173	42.20162
172 PEACH ST	rmp_392	Fail	1	Good	Present	Good	Compliant	Compliant	2.9	0.7	1.2	7	0.1	Compliant	-71.000695	42.1843
180 PEACH ST	rmp_393	Pass	0	Good	Present	Good	Compliant	Compliant	1.9	0.4	4	2	2.7	Compliant	-71.000564	42.18428
92 CELIA RD	rmp_394	Pass	0	Good	Present	Good	Compliant	Compliant	1.1	0.8	0.6	4	2.1	Compliant	-71.000389	42.18528
193 GROVE ST	rmp_395	Fail	1	Good	Present	Good	Compliant	Compliant	0.8	0.2	4.1	2	3.2	Compliant	-70.991454	42.19266
130 PEACH ST	rmp_396	Fail	1	Good	Present	Good	Compliant	Compliant	3.4	1.1	0.4	4	1	Not Compliant	-71.002825	42.18474
220 GROVE ST	rmp_397	Pass	0	Good	Present	Good	Compliant	Compliant	0.3	0.1	3.5	4	0.9	Compliant	-70.990201	42.19177
65 RICHARD RD	rmp_398	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	2.5	1.3	1.3	3	7.1	Compliant	-70.999246	42.18668
75 KIMBALL RD	rmp_399	Fail	1	Good	Present	Good	Compliant	Compliant	3	0.4	1	7	1.2	Compliant	-71.005881	42.18781
193 GROVE ST	rmp_400	Fail	1	Good	Present	Good	Compliant	Compliant	2.4	3.5	5	2	0.5	Compliant	-70.991635	42.1928
51 LINDA RD	rmp_401	Fail	5	Fair	Not Present	Not Present	Compliant	Compliant	7.7	3.7	8.5	0	3.4	Compliant	-71.003072	42.18729
11 MARJORIE RD	rmp_402	Fail	5	Fair	Not Present	Not Present	Compliant	Compliant	10	2.6	7.3	13	0.3	Compliant	-71.002933	42.18735
30 ALIDA RD	rmp_403	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4.5	0.8	4.7	8	2.3	Compliant	-71.003065	42.18737
59 CELIA RD	rmp_404	Pass	0	Good	Present	Good	Compliant	Compliant	2	0.9	4.3	0	1.2	Compliant	-71.002609	42.18557
3 MARJORIE RD	rmp_405	Fail	4	Fair	Not Present	Not Present	Compliant	Compliant	8.7	0.7	7	8	0.2	Compliant	-71.002708	42.18805
79 RICHARD RD	rmp_406	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	2.9	5.8	7.4	4	0.4	Compliant	-70.999256	42.18664
15 ALIDA RD	rmp_407	Fail	5	Good	Not Present	Not Present	Compliant	Compliant	10	0	6.2	9	3.6	Compliant	-71.002954	42.18725
220 GROVE ST	rmp_408	Fail	1	Good	Present	Good	Compliant	Compliant	0.4	0.5	3.1	2	4.1	Compliant	-70.989565	42.19152
95 CROSS RD	rmp_409	Pass	0	Good	Present	Good	Compliant	Compliant	2.3	0.1	3.7	2	1.8	Compliant	-71.005151	42.18828
76 KIMBALL RD	rmp_410	Pass	0	Good	Present	Good	Compliant	Compliant	2.3	0.7	4.1	3	0.1	Compliant	-71.005956	42.18773
70 MARJORIE RD	rmp_411	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	5.5	0.4	5.2	2	2	Compliant	-70.999054	42.18747
122 PEACH ST	rmp_412	Pass	0	Good	Present	Good	Compliant	Compliant	2.5	0.4	0.1	4	2.8	Compliant	-71.002916	42.18474
126 LINDA RD	rmp_413	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	5	4.3	5.1	0	0.4	Compliant	-70.999063	42.18738
45 KIMBALL RD	rmp_414	Pass	0	Good	Present	Good	Compliant	Compliant	1.5	0.7	3.8	3	0.9	Compliant	-71.004693	42.18669
183 RICHARD RD	rmp_415	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	7.6	1.4	4.6	7	0.6	Compliant	-71.003331	42.18658
100 RICHARD RD	rmp_416	Pass	0	Good	Present	Good	Compliant	Compliant	0.9	0.7	3.2	0	1.8	Compliant	-71.000028	42.18593
220 GROVE ST	rmp_417	Pass	0	Good	Present	Good	Compliant	Compliant	0.6	0.8	0	2	2.1	Compliant	-70.990014	42.19187
38 HICKORY RD	rmp_418	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	0.6	4.8	6.9	0	1	Compliant	-70.988711	42.18946
112 CELIA RD	rmp_419	Pass	0	Good	Present	Good	Compliant	Compliant	1.9	0.2	2.6	4	0.7	Compliant	-71.000252	42.18527
10 SUNNYSIDE LN	rmp_420	Fail	2	Good	Present	Good	Compliant	Compliant	1.4	3.3	6	0	2.7	Compliant	-70.99229	42.19325
47 CELIA RD	rmp_421	Fail	1	Good	Present	Good	Compliant	Compliant	2	1	4.6	1	3.2	Compliant	-71.002711	42.18559
167 RICHARD RD	rmp_422	Fail	5	Fair	Not Present	Not Present	Compliant	Compliant	10	2.2	5.3	8	4.4	Compliant	-71.003182	42.18657
112 RICHARD RD	rmp_423	Pass	0	Good	Present	Good	Compliant	Compliant	1	1.1	4.6	3	0.9	Compliant	-71.000135	42.18593
111 CELIA RD	rmp_424	Fail	1	Good	Present	Good	Compliant	Compliant	6	0.7	3.7	2	0.8	Compliant	-71.000289	42.1852
37 KIMBALL RD	rmp_425	Pass	0	Good	Present	Good	Compliant	Compliant	3	0.1	4.5	3	0.1	Compliant	-71.004562	42.18665
95 CELIA RD	rmp_426	Pass	0	Good	Present	Good	Compliant	Compliant	0.9	1.2	3.6	2	2.8	Compliant	-71.0004	42.18521
50 HICKORY RD	rmp_427	Fail	4	Poor	Not Present	Not Present	Compliant	Compliant	0.7	2.1	3.5	4	4.1	Compliant	-70.988852	42.18959
4 MARJORIE RD	rmp_428	Fail	4	Fair	Not Present	Not Present	Compliant	Compliant	10	3.4	3.9	9	0.3	Compliant	-71.002634	42.18815
71 HANCOCK ST	rmp_429	Fail	1	Good	Present	Fair	Compliant	Compliant	3.6	1.4	1.2	4	0.8	Compliant	-71.005199	42.20072
72 TAYLOR ST	rmp_430	Pass	0	Fair	Present	Good	Compliant	Compliant	3.8	0.6	2.3	4	2.2	Compliant	-71.008386	42.20424
37 SAFFORD ST	rmp_431	Fail	2	Good	Present	Good	Compliant	Compliant	1.7	1.4	4	2	4.7	Compliant	-71.009491	42.20407
941 WASHINGTON ST	rmp_432	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	5.1	0.6	3.3	4	0.5	Compliant	-71.005248	42.20239
81 HANCOCK ST	rmp_433	Fail	1	Good	Present	Good	Compliant	Compliant	1.4	1.3	3.2	5	0.4	Compliant	-71.005221	42.20027
944 WASHINGTON ST	rmp_434	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	5.6	0.2	0.3	0	1.6	Compliant	-71.005189	42.20219
1060 WASHINGTON ST	rmp_435	Fail	1	Good	Present	Fair	Compliant	Compliant	0.7	0.5	1.8	3	4.8	Compliant	-71.007369	42.20003
10 TREMONT ST	rmp_436	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	5.4	0.6	7	5	1.7	Compliant	-71.007123	42.20192
944 WASHINGTON ST	rmp_437	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	4.4	0.5	3.1	5	1.1	Compliant	-71.00519	42.20209
40 TREMONT ST	rmp_438	Pass	0	Fair	Present	Good	Compliant	Compliant	1.4	0.8	1.4	3	2	Compliant	-71.007687	42.20316
1060 WASHINGTON ST	rmp_439	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	6.7	2	5.5	1	4.5	Compliant	-71.007693	42.20009
1060 WASHINGTON ST	rmp_440	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	8.7	1.2	10.7	9	1	Compliant	-71.007478	42.20004
94 FRANKLIN ST	rmp_441	Fail	1	Good	Present	Good	Compliant	Compliant	3.3	0.8	0	0	3.9	Compliant	-71.009204	42.20466
50 TREMONT ST	rmp_442	Pass	0	Good	Present	Good	Compliant	Compliant	1.4	0	1.7	4	1	Compliant	-71.007148	42.20343
16 PEARL ST	rmp_443	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	3.8	0.7	3.3	4	1.3	Compliant	-71.004955	42.20233
85 FRANKLIN ST	rmp_444	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	0.5	1.2	0	0.9	Compliant	-71.008734	42.20444
15 CRESCENT AV	rmp_445	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	5.6	0.2	2.5	4	0.6	Compliant	-71.004936	42.20215
10 TREMONT ST	rmp_446	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	6.3	0.7	4.2	3	1.6	Compliant	-71.006869	42.20219
90 FRANKLIN ST	rmp_447	Pass	0	Good	Present	Good	Compliant	Compliant	1.2	0.4	0.1	3	1.5	Compliant	-71.008953	42.20446
6 FRANKLIN ST	rmp_448	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.5	0	4.5	4	0	Compliant	-71.007323	42.20192
89 HANCOCK ST	rmp_449	Fail	1	Good	Present	Good	Compliant	Compliant	4.7	1.9	3.1	4	0	Compliant	-71.005164	42.20016
1060 WASHINGTON ST	rmp_450	Fail	5	Good	Not Present	Not Present	Compliant	Not Compliant	7.3	0.8	7.9	9	2	Compliant	-71.007635	42.20005
39 SUMMER ST	rmp_451	Fail	1	Good	Present	Good	Compliant	Compliant	1.4	0.3	4.3	1	3.8	Compliant	-71.007003	42.20345
15 CRESCENT AV	rmp_452	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	4	0.1	3.3	2	0.6	Compliant	-71.004968	42.20207

**Braintree, MA - ADA Ramp Assessment  
2018**

53 FRANKLIN ST	rmp_453	Pass	0	Good	Present	Good	Compliant	Compliant	3.2	0.1	3.7	3	2.7	Compliant	-71.007761	42.2033
865 WASHINGTON ST	rmp_454	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3	0.7	4	3	0.8	Compliant	-71.005201	42.20369
1012 WASHINGTON ST	rmp_455	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.8	0.6	2.5	2	2.4	Compliant	-71.007009	42.2017
90 FRANKLIN ST	rmp_456	Pass	0	Good	Present	Good	Compliant	Compliant	1.2	0.6	3.4	2	2	Compliant	-71.009125	42.20459
40 SUMMER ST	rmp_457	Pass	0	Good	Present	Good	Compliant	Compliant	4.8	0.5	0.7	3	2.9	Compliant	-71.006993	42.20336
928 WASHINGTON ST	rmp_458	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	5.3	0.5	2.4	3	0.6	Compliant	-71.004981	42.20255
121 CENTRAL AV	rmp_459	Fail	1	Good	Present	Good	Compliant	Compliant	5.4	0.6	1.7	2	0.1	Compliant	-71.009378	42.20512
161 HANCOCK ST	rmp_460	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	5.9	1.5	3.5	5	2.3	Compliant	-71.005218	42.19767
65 HANCOCK ST	rmp_461	Pass	0	Good	Present	Fair	Compliant	Compliant	3.6	1.2	2.1	4	0.4	Compliant	-71.005208	42.20081
52 FRANKLIN ST	rmp_462	Pass	0	Good	Present	Good	Compliant	Compliant	3.2	1	2.3	4	0.4	Compliant	-71.007933	42.20326
1060 WASHINGTON ST	rmp_463	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	4.9	0.8	10.5	10	1.9	Compliant	-71.0076	42.19993
871 WASHINGTON ST	rmp_464	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	4.4	0.2	1.5	4	0.3	Compliant	-71.005236	42.20356
85 FRANKLIN ST	rmp_465	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	0.5	0.9	0	1.4	Compliant	-71.008831	42.20454
42 FRANKLIN ST	rmp_466	Pass	0	Good	Present	Good	Compliant	Compliant	3.2	0.3	3.2	1	1.8	Compliant	-71.007862	42.20315
1075 WASHINGTON ST	rmp_467	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	4.4	1.3	4.1	1	0.8	Compliant	-71.007606	42.19983
941 WASHINGTON ST	rmp_468	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	5.3	0.3	3.4	4	2.3	Compliant	-71.005195	42.20255
83 FRANKLIN ST	rmp_469	Pass	0	Good	Present	Good	Compliant	Compliant	1.7	0.5	3.4	3	0.5	Compliant	-71.008474	42.20344
1012 WASHINGTON ST	rmp_470	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	5.3	0.3	3.7	2	1.5	Compliant	-71.007195	42.20158
40 TREMONT ST	rmp_471	Pass	0	Good	Present	Good	Compliant	Compliant	1.2	0	2.8	1	1.8	Compliant	-71.007121	42.20333
1021 WASHINGTON ST	rmp_472	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4.4	0.1	3.6	4	4	Compliant	-71.007377	42.20159
106 PLAIN ST	rmp_473	Fail	1	Good	Present	Good	Compliant	Compliant	1.4	1.8	4.4	0	0.6	Compliant	-70.999741	42.19663
70 PLAIN ST	rmp_474	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	4.6	0.7	5.6	6	0.1	Compliant	-71.001436	42.1964
80 PLAIN ST	rmp_475	Fail	4	Fair	Not Present	Not Present	Not Compliant	Not Compliant	4.1	1.7	0	0	0.5	Compliant	-71.001281	42.19641
4 THETFORD AV	rmp_476	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.6	0.3	3.8	3	1.6	Compliant	-70.98689	42.18698
11 FOX HILL DR	rmp_477	Pass	0	Good	Present	Good	Compliant	Compliant	1	0.1	1.3	4	0.3	Compliant	-70.993914	42.18032
50 CHRISTINA DR	rmp_478	Pass	0	Good	Present	Good	Compliant	Compliant	0.9	0.4	2.4	3	2.4	Compliant	-70.99385	42.18239
51 CHRISTINA DR	rmp_479	Pass	0	Good	Present	Good	Compliant	Compliant	1.3	1.2	3.4	0	2.5	Compliant	-70.993861	42.1823
51 OAK LEDGE DR	rmp_480	Pass	0	Good	Present	Good	Compliant	Compliant	0.3	0.2	4.2	4	0.1	Compliant	-70.9941	42.18032
4 8 FRENCH AV	rmp_481	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.8	0	0.2	4	2.3	Compliant	-71.002874	42.20335
535 JOHN MAHAR HWY	rmp_482	Fail	5	Good	Present	Good	Compliant	Not Compliant	5.5	1.6	11.4	11	1.3	Compliant	-70.999236	42.2004
535 JOHN MAHAR HWY	rmp_483	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	4.3	0.6	4.6	3	0.4	Compliant	-70.998571	42.2005
884 WASHINGTON ST	rmp_484	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4.6	3	0	1	0.2	Compliant	-71.004975	42.20315
535 JOHN MAHAR HWY	rmp_485	Fail	2	Good	Present	Good	Compliant	Not Compliant	1.2	1.2	3.3	0	4.8	Compliant	-70.999232	42.20024
535 JOHN MAHAR HWY	rmp_486	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	3.7	1.1	4.3	1	0.7	Compliant	-70.998688	42.20027
14 FRENCH AV	rmp_487	Fail	2	Poor	Not Present	Not Present	Compliant	Compliant	2.4	0.7	2.6	3	1.9	Compliant	-71.003033	42.20402
900 WASHINGTON ST	rmp_488	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	5.7	1.6	0.6	0	0.5	Compliant	-71.004988	42.20305
86 HOLBROOK AV	rmp_489	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.9	0	2.9	3	0.2	Compliant	-71.002967	42.20344
88 PEARL ST	rmp_490	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	3.2	3.5	6.9	2	1.5	Compliant	-71.002797	42.20242
22 FRENCH AV	rmp_491	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	4.5	1.3	2.6	1	1.2	Compliant	-71.003005	42.20413
1229 LIBERTY ST	rmp_492	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	1.2	1.5	2.8	4	0.4	Compliant	-70.994906	42.18478
1154 LIBERTY ST	rmp_493	Pass	0	Good	Present	Good	Compliant	Compliant	1.1	0.8	1.8	4	0.9	Compliant	-70.99217	42.18619
1228 LIBERTY ST	rmp_494	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	2.7	0.1	2	3	3.1	Compliant	-70.994809	42.1846
1276 LIBERTY ST	rmp_495	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3.8	0.5	4	4	3.9	Compliant	-70.99598	42.18346
80 SYCAMORE RD	rmp_496	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.2	1.2	4.4	4	2.6	Compliant	-70.985724	42.18633
1107 LIBERTY ST	rmp_497	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	1.4	2	0.1	7	1.1	Compliant	-70.990988	42.18693
1134 LIBERTY ST	rmp_498	Pass	0	Fair	Present	Good	Compliant	Compliant	1.1	0.2	2.9	4	0.2	Compliant	-70.992004	42.1863
81 SYCAMORE RD	rmp_499	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	1.7	0.5	4.3	4	0.9	Compliant	-70.985726	42.18621
50 SYCAMORE RD	rmp_500	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	1.5	3.9	0.6	5	0.6	Compliant	-70.986801	42.18683
1108 LIBERTY ST	rmp_501	Fail	2	Poor	Present	Good	Compliant	Compliant	1.9	1.7	4.7	0	1	Compliant	-70.990974	42.18684
1050 WASHINGTON ST	rmp_502	Pass	0	Good	Present	Fair	Compliant	Compliant	0.7	0.7	0	0	0.6	Compliant	-71.007345	42.20083
1074 WASHINGTON ST	rmp_503	Pass	0	Good	Present	Good	Compliant	Compliant	1	0.7	3.4	4	0	Compliant	-71.007368	42.19984
3 JEFFERSON ST	rmp_504	Fail	5	Good	Not Present	Not Present	Compliant	Compliant	7.1	4.2	1.9	9	5.3	Compliant	-71.006546	42.19826
20 POND ST	rmp_505	Fail	4	Fair	Not Present	Not Present	Compliant	Compliant	5.4	0.4	5.9	7	1.3	Compliant	-71.00861	42.19993
962 WASHINGTON ST	rmp_506	Pass	0	Good	Present	Good	Compliant	Compliant	4.3	0.6	4.1	1	0.5	Compliant	-71.005869	42.20211
970 WASHINGTON ST	rmp_507	Pass	0	Good	Present	Good	Compliant	Compliant	4.7	1	2.3	3	0.2	Compliant	-71.00596	42.20209
1036 WASHINGTON ST	rmp_508	Fail	2	Good	Present	Good	Compliant	Compliant	3.5	0.6	6.8	2	3.5	Compliant	-71.007349	42.20091
1131 WASHINGTON ST	rmp_509	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	5.6	1.2	4.1	3	4.7	Compliant	-71.006453	42.19815
1125 LIBERTY ST	rmp_510	Fail	1	Fair	Present	Poor	Compliant	Compliant	1.1	0.3	0	3	4.3	Compliant	-70.991359	42.18681
1223 LIBERTY ST	rmp_511	Fail	4	Fair	Not Present	Not Present	Compliant	Compliant	6.2	4	3.8	0	3.3	Compliant	-70.994782	42.18487
842 WASHINGTON ST	rmp_512	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	2.2	0.8	4.8	4	1.5	Compliant	-71.004899	42.20423
60 PEARL ST	rmp_513	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	1.3	1.5	6.7	3	0.4	Compliant	-71.003552	42.20239
798 WASHINGTON ST	rmp_514	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3.9	1.8	3.8	3	0.2	Compliant	-71.004387	42.20588
84 PEARL ST	rmp_515	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	3.5	2	4.9	2	0.2	Compliant	-71.003379	42.2024
798 WASHINGTON ST	rmp_516	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.3	0.4	3.6	4	0.2	Compliant	-71.00451	42.20563
9 UNION PL	rmp_517	Fail	1	Good	Present	Good	Compliant	Compliant	3.3	1.9	0	0	1.4	Compliant	-71.003513	42.20721

no flares

**Braintree, MA - ADA Ramp Assessment  
2018**

786 WASHINGTON ST	rmp_518	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	4.4	0.2	3.4	2	1	Compliant	-71.004362	42.20601	
766 WASHINGTON ST	rmp_519	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.7	0.2	2.7	4	2.9	Compliant	-71.00417	42.20694	
766 WASHINGTON ST	rmp_520	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	4.3	0.4	1.5	4	0.5	Compliant	-71.004107	42.20705	
850 WASHINGTON ST	rmp_521	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	4.1	0.2	3.4	4	2.9	Compliant	-71.005009	42.20363	
6 RICHARD RD	rmp_522	Fail	5	Good	Not Present	Not Present	Compliant	Not Compliant	5.3	1.4	2.8	9	2.1	Compliant	-70.999245	42.18907	
8 MCANDREW RD	rmp_523	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	5.8	0.7	7.1	5	2.5	Compliant	-70.984935	42.18121	
5 ANGELA RD	rmp_524	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4.5	2.2	5.6	2	1.3	Compliant	-70.984706	42.18117	
1142 WASHINGTON ST	rmp_525	Fail	1	Good	Present	Good	Compliant	Compliant	0.6	0.8	3.5	2	8.4	Compliant	-71.005912	42.19753	
1150 WASHINGTON ST	rmp_526	Pass	0	Good	Present	Good	Compliant	Compliant	1	0.6	0	1	0.3	Compliant	-71.005864	42.19744	
249 FRANKLIN ST	rmp_527	Pass	0	Good	Present	Good	Compliant	Compliant	0.4	0.4	1.9	1	0.1	Compliant	-71.013931	42.20866	
199 FRANKLIN ST	rmp_528	Fail	1	Good	Present	Good	Compliant	Compliant	0.9	2.2	3.7	0	1	Compliant	-71.012333	42.20735	
199 FRANKLIN ST	rmp_529	Fail	1	Good	Present	Good	Compliant	Compliant	4.2	0.3	1.9	2	3.5	Compliant	-71.012321	42.20717	
199 FRANKLIN ST	rmp_530	Fail	1	Good	Present	Good	Compliant	Compliant	3.7	0.7	2.1	4	3.2	Compliant	-71.012412	42.20725	
20 SUMNER AV	rmp_531	Pass	0	Good	Present	Fair	Compliant	Compliant	0.8	1.2	3.1	3	2.5	Compliant	-71.011705	42.20795	
137 FRANKLIN ST	rmp_532	Pass	0	Good	Present	Good	Compliant	Compliant	3.3	0.5	4.3	4	2.7	Compliant	-71.010051	42.20562	
10 TREMONT ST	rmp_533	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	3.6	1.4	2.5	6	3	Compliant	-71.00652	42.20208	
261 FRANKLIN ST	rmp_534	Fail	1	Good	Present	Good	Compliant	Compliant	1.6	1.8	3.4	0	2.3	Compliant	-71.014107	42.20879	
161 FRANKLIN ST	rmp_535	Pass	0	Fair	Present	Good	Compliant	Compliant	2.8	0.9	1.7	0	1	Compliant	-71.010825	42.20623	
123 FRANKLIN ST	rmp_536	Fail	1	Good	Present	Good	Compliant	Compliant	2.5	0.1	1.3	4	5.3	Compliant	-71.009971	42.20556	
199 FRANKLIN ST	rmp_537	Pass	0	Good	Present	Good	Compliant	Compliant	2.6	1.1	1.9	1	0.4	Compliant	-71.012432	42.20745	
189 FRANKLIN ST	rmp_538	Pass	0	Good	Present	Good	Compliant	Compliant	3.6	0.7	4	2	2.5	Compliant	-71.011703	42.20693	
175 FRANKLIN ST	rmp_539	Pass	0	Good	Present	Good	Compliant	Compliant	0.6	0.5	2.4	4	2.9	Compliant	-71.011643	42.20687	
57 ELMWOOD AV	rmp_540	Pass	0	Good	Present	Good	Compliant	Compliant	1.4	0.4	1.4	3	2.5	Compliant	-71.011768	42.20802	
149 FRANKLIN ST	rmp_541	Pass	0	Good	Present	Good	Compliant	Compliant	3	1	1	1	0.6	Compliant	-71.010766	42.20618	
209 FRANKLIN ST	rmp_542	Pass	0	Good	Present	Good	Compliant	Compliant	3.6	0.3	5.3	3	0.8	Compliant	-71.012515	42.20751	
38 ELMWOOD AV	rmp_543	Pass	0	Good	Present	Good	Compliant	Compliant	1.4	0.7	4.2	1	2.6	Compliant	-71.011576	42.20802	
985 WASHINGTON ST	rmp_544	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	2.7	2.4	5.5	2	0.3	Compliant	-71.006413	42.20208	
85 QUINCY AV	rmp_545	Pass	0	Good	Present	Fair	Compliant	Compliant	4.1	0.1	0.7	1	1.6	Compliant	-70.968975	42.22464	
85 QUINCY AV	rmp_546	Fail	2	Good	Present	Good	Compliant	Compliant	4.1	0.8	5.8	1	7.8	Compliant	-70.968995	42.22457	
621 UNION ST	rmp_547	Pass	0	Good	Present	Good	Compliant	Compliant	0.3	0.7	2.4	3	1.7	Compliant	-70.982404	42.21894	
6 BAKER AV	rmp_548	Pass	0	Good	Present	Good	Compliant	Compliant	0.7	0.8	0.3	3	0.9	Compliant	-70.983528	42.21735	
603 UNION ST	rmp_549	Pass	0	Fair	Present	Good	Compliant	Compliant	0.8	0.7	2	4	0.3	Compliant	-70.982551	42.21877	
521 UNION ST	rmp_550	Fail	1	Poor	Present	Good	Compliant	Compliant	1.6	0.9	3.7	3	1.6	Compliant	-70.985063	42.2161	
575 UNION ST	rmp_551	Fail	1	Good	Present	Good	Compliant	Compliant	1.2	0.8	1.9	3	3.2	Compliant	-70.983362	42.21767	
572 UNION ST	rmp_552	Fail	1	Good	Present	Good	Compliant	Compliant	0.7	0.7	6.6	3	0.5	Compliant	-70.983475	42.21784	
559 UNION ST	rmp_553	Pass	0	Good	Present	Good	Compliant	Compliant	2.5	0.6	2.8	5	2.3	Compliant	-70.983655	42.21724	
552 UNION ST	rmp_554	Pass	0	Good	Present	Good	Compliant	Compliant	0.5	0.9	3.5	0	0.4	Compliant	-70.98355	42.21769	
529 UNION ST	rmp_555	Fail	1	Fair	Present	Good	Compliant	Compliant	0.8	0.4	2.7	2	4	Compliant	-70.984919	42.21619	
404 UNION ST	rmp_556	Fail	1	Good	Present	Good	Compliant	Compliant	1.4	0.4	3.4	2	3	Compliant	-70.988216	42.21345	
391 MIDDLE ST	rmp_557	Pass	0	Good	Present	Good	Compliant	Compliant	1.1	1.1	0.7	4	0.7	Compliant	-70.988509	42.21329	
404 UNION ST	rmp_558	Pass	0	Good	Present	Good	Compliant	Compliant	1.1	0.2	3.5	1	0.9	Compliant	-70.988416	42.21346	
163 CLEVELAND AV	rmp_559	Pass	0	Good	Present	Fair	Compliant	Compliant	2.9	0.5	2.1	2	0.7	Compliant	-70.99616	42.21149	
399 MIDDLE ST	rmp_560	Pass	0	Good	Present	Good	Compliant	Compliant	1.2	0.4	4	1	2.1	Compliant	-70.988487	42.21305	
401 UNION ST	rmp_561	Pass	0	Fair	Present	Good	Compliant	Not Compliant	0.4	0.1	4.6	1	0.4	Compliant	-70.988235	42.21316	landing compliant because of flares
401 UNION ST	rmp_562	Pass	0	Good	Present	Good	Compliant	Compliant	0.2	0.4	3.7	4	1.4	Compliant	-70.988195	42.21328	
429 UNION ST	rmp_563	Fail	1	Fair	Present	Good	Compliant	Compliant	2.1	1.2	1.1	7	1.9	Compliant	-70.987443	42.21394	
275 UNION ST	rmp_564	Pass	0	Good	Present	Good	Compliant	Compliant	0.6	0.4	0.6	2	0.4	Compliant	-70.992483	42.21153	
259 UNION ST	rmp_565	Pass	0	Fair	Present	Good	Compliant	Compliant	0.9	1.1	1.4	4	0.5	Compliant	-70.994158	42.21122	
399 MIDDLE ST	rmp_566	Pass	0	Good	Present	Good	Compliant	Compliant	4.3	1	2.7	4	2.7	Compliant	-70.98835	42.213	
320 UNION ST	rmp_567	Pass	0	Good	Present	Good	Compliant	Compliant	0.6	0.5	4.2	3	1.1	Compliant	-70.99151	42.21189	
151 GROSSMAN DR	rmp_568	Pass	0	Good	Present	Good	Compliant	Compliant	2.8	0.3	2.9	2	2	Compliant	-70.997366	42.21127	
325 UNION ST	rmp_569	Fail	1	Good	Present	Good	Compliant	Compliant	0.7	0.7	2.9	3	3.3	Compliant	-70.991464	42.21181	
163 CLEVELAND AV	rmp_570	Pass	0	Good	Present	Good	Compliant	Compliant	3.3	0.2	3	2	0.5	Compliant	-70.996269	42.21144	
437 UNION ST	rmp_571	Pass	0	Fair	Present	Good	Compliant	Compliant	1.2	0.8	4	1	0.7	Compliant	-70.987375	42.21403	
1 STRATHMORE RD	rmp_572	Fail	1	Fair	Present	Good	Compliant	Compliant	5.5	0.4	5.3	1	0.1	Compliant	-70.987486	42.21414	
151 GROSSMAN DR	rmp_573	Pass	0	Good	Present	Fair	Compliant	Compliant	3	1.2	1.6	3	1.9	Compliant	-70.997453	42.21125	
4 STRATHMORE RD	rmp_574	Pass	0	Fair	Present	Good	Compliant	Compliant	4.6	0.5	1.4	4	1.5	Compliant	-70.987579	42.21401	
251 UNION ST	rmp_575	Pass	0	Good	Present	Good	Compliant	Compliant	1.1	0.4	2.6	4	0.9	Compliant	-70.994341	42.21118	
301 UNION ST	rmp_576	Pass	0	Good	Present	Good	Compliant	Compliant	0.5	0.3	2.8	4	0.5	Compliant	-70.992291	42.21158	
311 UNION ST	rmp_577	Fail	2	Poor	Present	Good	Compliant	Compliant	0.3	1.2	0.6	4	3.2	Compliant	-70.991691	42.21174	
45 ARTHUR ST	rmp_578	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	2.1	2.3	0	0	1	Compliant	-70.967844	42.22702	
27 ARTHUR ST	rmp_579	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	4.1	1.5	0	0	0.2	Compliant	-70.96739	42.22633	
5 ARTHUR ST	rmp_580	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	9	1.7	0	0	0.5	Not Compliant	-70.966935	42.22577	Garbage
17 ARTHUR ST	rmp_581	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	0.9	3.7	0	0	2.1	Compliant	-70.967347	42.22627	
33 ARTHUR ST	rmp_582	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	1.4	3.2	5.1	0	7.8	Compliant	-70.967787	42.22691	

**Braintree, MA - ADA Ramp Assessment  
2018**

6 ARDMORE ST	rmp_583	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	2.7	0.4	0	2	0	Compliant	-70.968384	42.22764
77 ARTHUR ST	rmp_584	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	3.6	3	9	0	1.1	Compliant	-70.968743	42.22814
5 ARDMORE ST	rmp_585	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	1.2	1.8	1.9	0	3.4	Compliant	-70.968283	42.22755
45 ARDMORE ST	rmp_586	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	4.6	2.8	2.3	0	1.5	Compliant	-70.966467	42.22837
82 ARGYLE RD	rmp_587	Fail	6	Fair	Not Present	Not Present	Compliant	Not Compliant	5.1	1.6	9.1	9	2.5	Compliant	-70.966514	42.22846
128 PLAIN ST	rmp_588	Fail	1	Good	Present	Good	Compliant	Compliant	1.4	0.4	3.7	4	4.5	Compliant	-70.998647	42.19662
2 GROVE ST	rmp_589	Fail	1	Good	Present	Good	Compliant	Compliant	0.6	1.5	4.2	0	1.5	Compliant	-70.998452	42.19656
552 UNION ST	rmp_590	Fail	1	Fair	Present	Good	Compliant	Compliant	1.4	0.2	0.4	6	0.3	Compliant	-70.983626	42.21773
200 GROSSMAN DR	rmp_591	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	5.4	0.9	5.8	3	1.7	Compliant	-70.999144	42.21225
200 GROSSMAN DR	rmp_592	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	2	0.1	5.2	4	0.2	Compliant	-70.999154	42.21229
100 GROSSMAN DR	rmp_593	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	6.5	1.7	6.3	2	1.4	Compliant	-70.99923	42.21074
100 GROSSMAN DR	rmp_594	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	7.7	0	7.6	7	0.1	Compliant	-70.999366	42.21086
621 UNION ST	rmp_595	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	0.9	3.8	2	0.5	Compliant	-70.982271	42.21924
282 UNION ST	rmp_596	Fail	1	Good	Present	Good	Compliant	Compliant	4.4	1.3	0	5	1.5	Compliant	-70.993022	42.21149
7 HAMILTON ST	rmp_597	Pass	0	Good	Present	Good	Compliant	Compliant	3.5	1.1	3.5	0	1.7	Compliant	-70.985826	42.21564
360 UNION ST	rmp_598	Pass	0	Good	Present	Good	Compliant	Compliant	0.6	0.9	1.7	3	2.1	Compliant	-70.989654	42.21246
660 UNION ST	rmp_599	Pass	0	Good	Present	Good	Compliant	Compliant	2.4	1.1	2.4	0	0.8	Compliant	-70.981238	42.21942
100 GROSSMAN DR	rmp_600	Fail	5	Poor	Not Present	Not Present	Compliant	Not Compliant	0.4	1.4	2	6	1.4	Compliant	-71.000284	42.20977
368 UNION ST	rmp_601	Pass	0	Good	Present	Good	Compliant	Compliant	1.4	0.8	0.9	6	1.3	Compliant	-70.989566	42.21255
660 UNION ST	rmp_602	Pass	0	Good	Present	Good	Compliant	Compliant	3.5	0.7	0	4	1.5	Compliant	-70.981068	42.21946
625 UNION ST	rmp_603	Pass	0	Fair	Present	Good	Compliant	Compliant	0.1	0.1	0.6	4	2.9	Compliant	-70.98195	42.21934
282 UNION ST	rmp_604	Fail	1	Good	Present	Good	Compliant	Compliant	3.5	0.9	2.7	0	4.2	Compliant	-70.993181	42.21143
26 WINSLOW RD	rmp_605	Fail	1	Good	Present	Good	Compliant	Compliant	6	0.4	0.8	5	2.5	Compliant	-70.989941	42.21307
8 WINSLOW RD	rmp_606	Pass	0	Good	Present	Good	Compliant	Compliant	4.1	0.4	0.1	4	2.3	Compliant	-70.989909	42.21298
7 HAMILTON ST	rmp_607	Pass	0	Good	Present	Good	Compliant	Compliant	0.9	0.6	0	1	0	Compliant	-70.985752	42.21575
100 GROSSMAN DR	rmp_608	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	5.7	1.1	6.3	3	0.1	Compliant	-71.000246	42.20984
20 GRANITE ST	rmp_609	Pass	0	Good	Present	Good	Compliant	Compliant	0.4	0.6	0	0	0.4	Compliant	-71.031709	42.22691
75 GRANITE ST	rmp_610	Fail	1	Good	Present	Good	Compliant	Compliant	3.4	1.3	4.3	4	1.6	Compliant	-71.032128	42.22596
20 GRANITE ST	rmp_611	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	2.4	1	5.7	2	0.7	Compliant	-71.031547	42.22746
19 GRANITE ST	rmp_612	Fail	1	Good	Present	Good	Compliant	Compliant	2	1.7	0	0	0.5	Compliant	-71.03189	42.22696
19 GRANITE ST	rmp_613	Fail	6	Fair	Not Present	Not Present	Compliant	Not Compliant	7.4	2.2	7.1	6	3.6	Compliant	-71.032003	42.22659
44 GRANITE ST	rmp_614	Fail	7	Fair	Not Present	Not Present	Compliant	Not Compliant	9.7	2.8	12.5	8	4.8	Compliant	-71.032057	42.22638
44 GRANITE ST	rmp_615	Pass	0	Good	Present	Good	Compliant	Compliant	1.2	0.3	1.3	0	1.9	Compliant	-71.03176	42.22606
75 GRANITE ST	rmp_616	Pass	0	Good	Present	Good	Compliant	Compliant	1.3	0.1	4.6	2	1.5	Compliant	-71.032114	42.22594
75 GRANITE ST	rmp_617	Fail	1	Good	Present	Fair	Compliant	Compliant	1.1	1.8	3.5	5	2.5	Compliant	-71.032109	42.22618
8 EDGEHILL RD	rmp_618	Fail	1	Good	Present	Good	Compliant	Compliant	1.1	1.2	3.5	1	4.4	Compliant	-70.969098	42.22569
109 QUINCY AV	rmp_619	Pass	0	Good	Present	Good	Compliant	Compliant	0.3	1	4.2	4	0.5	Compliant	-70.969131	42.22555
197 QUINCY AV	rmp_620	Pass	0	Good	Present	Good	Compliant	Compliant	0.2	0.8	1.5	0	0.4	Compliant	-70.970222	42.22867
65 TREFTON DR	rmp_621	Fail	5	Good	Not Present	Not Present	Compliant	Not Compliant	6.2	2.8	5	10	1	Compliant	-70.968011	42.23036
197 QUINCY AV	rmp_622	Fail	1	Good	Present	Good	Compliant	Compliant	1.1	1.4	0	0	1	Compliant	-70.969954	42.22824
39 TREFTON DR	rmp_623	Fail	2	Poor	Not Present	Not Present	Compliant	Compliant	2.1	0.7	0	0	0	Compliant	-70.969147	42.22977
95 COMMERCIAL ST	rmp_624	Pass	0	Good	Present	Good	Compliant	Compliant	3.5	0.6	0	4	2.8	Compliant	-70.970758	42.22079
2 ARTHUR ST	rmp_625	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	5	1.2	2.8	0	0	Compliant	-70.967077	42.22567
197 QUINCY AV	rmp_626	Fail	1	Good	Present	Good	Compliant	Compliant	2	2.1	2.3	2	1.1	Compliant	-70.969989	42.2283
86 QUINCY AV	rmp_627	Pass	0	Good	Present	Good	Compliant	Compliant	2.4	0.9	2.6	6	0.7	Compliant	-70.969199	42.22454
110 QUINCY AV	rmp_628	Pass	0	Good	Present	Good	Compliant	Compliant	4.4	1	0	0	1.6	Compliant	-70.969343	42.22544
3 BEECHWOOD RD	rmp_629	Pass	0	Good	Present	Good	Compliant	Compliant	1.1	1.2	2.3	1	2.3	Compliant	-70.969187	42.22626
225 QUINCY AV	rmp_630	Fail	1	Good	Present	Good	Compliant	Compliant	0.3	0.1	3.1	6	0.2	Compliant	-70.970594	42.2291
1 ARBORWAY DR	rmp_631	Pass	0	Good	Present	Good	Compliant	Compliant	1.5	0	0.5	2	1.8	Compliant	-70.969723	42.22772
4 ALLEN ST	rmp_632	Pass	0	Fair	Present	Fair	Compliant	Compliant	3.1	1.2	3.2	3	1.4	Compliant	-70.969152	42.22397
197 QUINCY AV	rmp_633	Pass	0	Good	Present	Fair	Compliant	Compliant	0.7	0.6	0	0	0.5	Compliant	-70.969938	42.2282
217 QUINCY AV	rmp_634	Pass	0	Good	Present	Good	Compliant	Compliant	4.1	0	0.7	3	1.3	Compliant	-70.970528	42.22899
197 QUINCY AV	rmp_635	Fail	1	Good	Present	Good	Compliant	Compliant	4.1	1.3	2.9	3	1.4	Compliant	-70.969754	42.22784
1 ROCKDALE ST	rmp_636	Fail	1	Good	Present	Fair	Compliant	Compliant	4.4	0.5	6	5	1.7	Compliant	-71.031751	42.22593
176 WEST ST	rmp_637	Fail	1	Good	Present	Good	Compliant	Compliant	1.6	1.2	5.3	1	3.5	Compliant	-71.012938	42.21477
129 WEST ST	rmp_638	Fail	1	Good	Present	Good	Compliant	Compliant	1.5	1	5.9	2	0.5	Compliant	-71.010446	42.2145
192 WEST ST	rmp_639	Pass	0	Good	Present	Good	Compliant	Compliant	0.5	0.6	3.5	3	0.2	Compliant	-71.013141	42.21478
140 WEST ST	rmp_640	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	1.7	1.5	0	0	3.5	Compliant	-71.010749	42.21454
157 PARKSIDE AV	rmp_641	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	9.3	4.7	14.2	2	1.1	Compliant	-71.013729	42.21871
113 WALNUT ST	rmp_642	Fail	3	Good	Present	Fair	Compliant	Compliant	2	5.4	1.1	6	4.9	Compliant	-71.012755	42.2188
142 WALNUT ST	rmp_643	Fail	1	Good	Present	Good	Compliant	Compliant	1.2	1.3	4.5	2	2	Compliant	-71.013146	42.2199
211 HOLLIS AV	rmp_644	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	0.4	1	3	2.5	Compliant	-71.01258	42.21659
114 WALNUT ST	rmp_645	Pass	0	Fair	Present	Good	Compliant	Compliant	0.8	0.2	4.7	0	0.8	Compliant	-71.012945	42.21878
162 PARKSIDE AV	rmp_646	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	10	4.1	2.6	12	2.1	Compliant	-71.013553	42.21872
124 WALNUT ST	rmp_647	Fail	2	Fair	Present	Fair	Compliant	Compliant	2.9	6	5.4	3	3	Compliant	-71.012955	42.21894

Braintree, MA - ADA Ramp Assessment

2018

3 PARKSIDE CR	rmp_648	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	10	5.2	11.6	2	2.5	Compliant	-71.013808	42.2189	ramp slope is 10.6 but can't go higher than 10
152 PARKSIDE AV	rmp_649	Fail	6	Fair	Not Present	Not Present	Compliant	Not Compliant	6.5	6.5	2	16	4.2	Compliant	-71.013556	42.21891	
50 WALNUT ST	rmp_650	Fail	1	Good	Present	Poor	Compliant	Compliant	1.7	1.2	3.4	0	3.9	Compliant	-71.01254	42.21645	
43 WALNUT ST	rmp_651	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	5.5	0.3	4.2	4	1.3	Compliant	-71.012348	42.21646	
135 MONATIQUOT AV	rmp_652	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	4.3	1.3	4.2	3	4.2	Compliant	-71.012228	42.21563	
203 HOLLIS AV	rmp_653	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	4.5	0.3	4	4	2.8	Compliant	-71.012354	42.21662	
123 WALNUT ST	rmp_654	Fail	1	Fair	Present	Fair	Compliant	Compliant	0.8	4.3	0.1	4	1.5	Compliant	-71.012786	42.21892	
267 TREMONT ST	rmp_655	Fail	2	Good	Present	Good	Compliant	Compliant	3.5	1.4	0.8	7	0.4	Compliant	-71.009838	42.21091	
104 CENTRAL AV	rmp_656	Fail	1	Good	Present	Good	Compliant	Compliant	5	0.6	3.6	2	2.3	Compliant	-71.008226	42.20552	
257 TREMONT ST	rmp_657	Fail	2	Good	Present	Good	Compliant	Compliant	2.3	6.9	10.1	3	2.3	Compliant	-71.009862	42.21021	
845 WASHINGTON ST	rmp_658	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	5.2	0.1	4.2	3	0.5	Compliant	-71.005056	42.20425	
365 TREMONT ST	rmp_659	Pass	0	Good	Present	Good	Compliant	Compliant	1.6	0.7	3.4	3	1.8	Compliant	-71.009345	42.21434	
99 WEST ST	rmp_660	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	0.1	1.2	3.1	3	2.9	Compliant	-71.009218	42.21447	
295 TREMONT ST	rmp_661	Pass	0	Good	Present	Good	Compliant	Compliant	3.4	0.6	4.2	3	0.4	Compliant	-71.009734	42.21189	
245 TREMONT ST	rmp_662	Fail	2	Good	Present	Good	Compliant	Compliant	1.7	1.6	0.4	4	5.3	Compliant	-71.009852	42.21007	
309 TREMONT ST	rmp_663	Pass	0	Good	Present	Good	Compliant	Compliant	3.6	0.2	3.5	2	2.2	Compliant	-71.009736	42.21202	
12 SUMMER ST	rmp_664	Fail	1	Good	Present	Good	Compliant	Compliant	1.2	1.5	3.2	1	0.6	Compliant	-71.005871	42.20361	
101 CENTRAL AV	rmp_665	Pass	0	Good	Present	Poor	Compliant	Compliant	3.9	0.6	3	3	1.9	Compliant	-71.008278	42.20566	
76 TREMONT ST	rmp_666	Fail	1	Good	Present	Good	Compliant	Compliant	2.3	0.3	2.7	2	3.9	Compliant	-71.007659	42.20451	
833 WASHINGTON ST	rmp_667	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	5.1	0.3	3.1	3	0.8	Compliant	-71.004984	42.20478	
27 CENTRAL ST	rmp_668	Pass	0	Good	Present	Good	Compliant	Compliant	2.3	1.1	4.3	2	1.5	Compliant	-71.006013	42.20477	
220 TREMONT ST	rmp_669	Fail	2	Good	Present	Good	Compliant	Compliant	0.8	3.1	0.4	6	2.1	Compliant	-71.009858	42.20916	
56 LAKEVIEW AV	rmp_670	Fail	1	Good	Present	Good	Compliant	Compliant	2.7	1.5	0.3	4	0	Compliant	-71.00951	42.20848	
281 TREMONT ST	rmp_671	Fail	2	Good	Present	Good	Compliant	Compliant	3.6	1.3	1.3	4	3.1	Compliant	-71.009816	42.21103	
21 SUMMER ST	rmp_672	Pass	0	Good	Present	Good	Compliant	Compliant	1.7	0	2.6	4	0	Compliant	-71.006042	42.2036	
190 TREMONT ST	rmp_673	Pass	0	Good	Present	Good	Compliant	Compliant	0.6	0.5	1.9	5	1.2	Compliant	-71.009475	42.20832	
110 MONATIQUOT AV	rmp_674	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	6.3	0.1	4.1	6	0.3	Compliant	-71.009344	42.21548	
88 TREMONT ST	rmp_675	Pass	0	Good	Present	Good	Compliant	Compliant	2.1	0.8	1.2	3	0.2	Compliant	-71.007716	42.20462	
99 FRANKLIN ST	rmp_676	Pass	0	Good	Present	Good	Compliant	Compliant	4.6	0.9	3.4	1	2.3	Compliant	-71.009336	42.20498	
323 FRANKLIN ST	rmp_677	Fail	2	Good	Present	Good	Compliant	Not Compliant	0.2	0.4	0	0	6.9	Compliant	-71.016146	42.21028	
315 FRANKLIN ST	rmp_678	Pass	0	Good	Present	Fair	Compliant	Compliant	0.5	0.9	0	0	1.4	Compliant	-71.016039	42.2102	
210 WEST ST	rmp_679	Pass	0	Good	Present	Good	Compliant	Compliant	1	0	2.3	4	1.1	Compliant	-71.014456	42.21439	
377 FRANKLIN ST	rmp_680	Pass	0	Fair	Present	Good	Compliant	Compliant	1.1	0.9	0	0	1.8	Compliant	-71.01807	42.21131	
232 WEST ST	rmp_681	Pass	0	Good	Present	Good	Compliant	Compliant	1.8	0.8	3.9	3	1.8	Compliant	-71.014657	42.21429	
367 FRANKLIN ST	rmp_682	Pass	0	Good	Present	Good	Compliant	Compliant	0.3	0.5	0	0	1.5	Compliant	-71.01797	42.21124	
368 FRANKLIN ST	rmp_683	Pass	0	Good	Present	Good	Compliant	Compliant	0.9	1	0	0	2.6	Compliant	-71.017881	42.21105	
350 FRANKLIN ST	rmp_684	Fail	2	Good	Present	Fair	Compliant	Compliant	2.1	2.8	6.6	3	1.4	Compliant	-71.017702	42.21092	
28 CENTRAL ST	rmp_685	Pass	0	Good	Present	Good	Compliant	Compliant	3	0.8	0	0	0.2	Compliant	-71.006121	42.20476	
773 WASHINGTON ST	rmp_686	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.5	1	3.3	3	0.4	Compliant	-71.004444	42.20697	
773 WASHINGTON ST	rmp_687	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.6	0.4	2.1	4	1	Compliant	-71.004674	42.20566	
823 WASHINGTON ST	rmp_688	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.9	0.8	2.5	4	1.4	Compliant	-71.004923	42.20486	
773 WASHINGTON ST	rmp_689	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	4	0.5	3.3	3	0.5	Compliant	-71.004721	42.20554	
773 WASHINGTON ST	rmp_690	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	2.2	0.7	3.4	4	0.4	Compliant	-71.004781	42.2054	
75 TREMONT ST	rmp_691	Fail	2	Good	Present	Good	Compliant	Compliant	5.4	0.2	2.8	1	3.2	Compliant	-71.007521	42.20455	
36 MONATIQUOT AV	rmp_692	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	3.1	3.1	0.8	6	4	Compliant	-71.006222	42.21577	
20 HOLLIS AV	rmp_693	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3.5	2.4	1.7	5	0.3	Compliant	-71.004269	42.21778	
469 WASHINGTON ST	rmp_694	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.9	0.4	3.1	4	1.8	Compliant	-71.003523	42.21643	
37 MONATIQUOT AV	rmp_695	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4.7	0.5	3.9	2	5.9	Compliant	-71.006218	42.21595	
435 WASHINGTON ST	rmp_696	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.3	0.1	3	3	0.5	Compliant	-71.003227	42.21801	
42 ASH ST	rmp_697	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	5.2	5.2	8.3	2	1.6	Compliant	-71.006459	42.21594	
46 HOLLIS AV	rmp_698	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3.1	1.5	0.7	5	1	Compliant	-71.005561	42.21746	
439 WASHINGTON ST	rmp_699	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	1.6	1.6	4.7	0	1.8	Compliant	-71.003214	42.21786	
25 HOLLIS AV	rmp_700	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	3.7	1.8	6.1	0	3	Compliant	-71.004279	42.2179	
6 OAK ST	rmp_701	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	2.1	1.1	4	2	5.1	Compliant	-71.00944	42.21452	
485 WASHINGTON ST	rmp_702	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	5	1	3.6	2	5.2	Compliant	-71.00364	42.21634	
45 WEST ST	rmp_703	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	1.3	4.4	4.8	1	3.9	Compliant	-71.006323	42.21468	
507 WASHINGTON ST	rmp_704	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	3.1	3.3	4	3	3.9	Compliant	-71.004407	42.21573	
507 WASHINGTON ST	rmp_705	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4	0.4	6.2	5	2	Compliant	-71.004802	42.21586	
37 WEST ST	rmp_706	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	1.8	2.8	4.4	0	5.7	Compliant	-71.006059	42.21476	
5 MAPLE ST	rmp_707	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	2.7	0.2	2.8	2	0.8	Compliant	-71.004254	42.21593	
56 MONATIQUOT AV	rmp_708	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	4.5	0.5	2.8	4	1.5	Compliant	-71.006415	42.21576	
17 HOLLIS AV	rmp_709	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	3.9	3.3	2.2	5	3.5	Compliant	-71.004158	42.21793	
81 HOBART AV	rmp_710	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	4.2	1.7	2.7	3	0.8	Compliant	-71.007314	42.20902	
81 HOBART AV	rmp_711	Fail	4	Poor	Not Present	Not Present	Compliant	Compliant	6.9	1.2	4.2	7	1.3	Compliant	-71.007509	42.20925	
745 WASHINGTON ST	rmp_712	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.1	0.1	5	4	0.8	Compliant	-71.007303	42.20888	

**Braintree, MA - ADA Ramp Assessment  
2018**

745 WASHINGTON ST	rmp_713	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.6	0.9	4.2	6	0.4	Compliant	-71.007518	42.20878
109 TREMONT ST	rmp_714	Pass	0	Good	Present	Good	Compliant	Compliant	4.2	0.6	4.4	3	0.7	Compliant	-71.008024	42.20556
81 HOBART AV	rmp_715	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	4.6	0.2	7	4	0.5	Compliant	-71.006973	42.20902
773 WASHINGTON ST	rmp_716	Pass	0	Good	Present	Good	Compliant	Compliant	2.8	0.5	3.3	1	1.4	Compliant	-71.005109	42.20687
773 WASHINGTON ST	rmp_717	Fail	1	Good	Present	Good	Compliant	Compliant	3	0.6	0	4	4.5	Compliant	-71.005264	42.20683
59 HOBART AV	rmp_718	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	2.4	1.7	2.3	1	2.3	Compliant	-71.006788	42.20902
745 WASHINGTON ST	rmp_719	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.8	0.7	2.1	3	1.7	Compliant	-71.003859	42.20884
19 HOBART AV	rmp_720	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	3.5	0.9	7.1	3	1.5	Compliant	-71.004542	42.20906
745 WASHINGTON ST	rmp_721	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3.3	0.8	2.8	3	5.2	Compliant	-71.004114	42.20796
5 HOBART AV	rmp_722	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	2.8	2.5	4.2	1	1.1	Compliant	-71.003829	42.20907
81 HOBART AV	rmp_723	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	5.7	1.1	3.8	6	2.4	Compliant	-71.007484	42.20902
81 HOBART AV	rmp_724	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.2	0.3	3	5	0.2	Compliant	-71.007512	42.20953
47 TAYLOR ST	rmp_725	Pass	0	Good	Present	Good	Compliant	Compliant	2.5	0.3	3.7	3	1.6	Compliant	-71.007596	42.20466
81 HOBART AV	rmp_726	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.2	0.3	5.4	4	1.4	Compliant	-71.006969	42.20942
745 WASHINGTON ST	rmp_727	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	2	1.3	4.9	2	1	Compliant	-71.004388	42.2072
145 OAK ST	rmp_728	Fail	1	Good	Present	Good	Compliant	Compliant	0.5	1.5	1.5	5	1.7	Compliant	-71.009865	42.21949
98 STORRS AV	rmp_729	Fail	2	Good	Present	Good	Compliant	Compliant	2.1	2	0.9	7	1.4	Compliant	-71.00825	42.21987
38 DEAN ST	rmp_730	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	2.1	2.9	3.5	6	0.9	Compliant	-71.009508	42.21758
37 DEAN ST	rmp_731	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	2.4	2	2.4	8	4.9	Compliant	-71.009526	42.21778
745 WASHINGTON ST	rmp_732	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	3.2	1.9	5	6	0.1	Compliant	-71.005423	42.20899
714 WASHINGTON ST	rmp_733	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	1.6	2.3	0	0	1.7	Compliant	-71.003892	42.20785
745 WASHINGTON ST	rmp_734	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	2.6	2.2	5.4	3	1.5	Compliant	-71.005606	42.20899
745 WASHINGTON ST	rmp_735	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	4.8	1.9	6.5	6	0.3	Compliant	-71.004461	42.20893
700 WASHINGTON ST	rmp_736	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	1.7	3.2	1	4	2	Compliant	-71.003605	42.2091
23 CENTRAL AV	rmp_737	Fail	1	Good	Present	Good	Compliant	Compliant	4.1	0.3	3	4	3	Compliant	-71.005402	42.20689
692 WASHINGTON ST	rmp_738	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	4.9	2.6	3.2	1	1.9	Compliant	-71.003553	42.20927
714 WASHINGTON ST	rmp_739	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	2.3	1.5	3.2	2	3.2	Compliant	-71.003882	42.20802
714 WASHINGTON ST	rmp_740	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.6	0	2.1	4	1	Compliant	-71.00364	42.20879
742 WASHINGTON ST	rmp_741	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	0.2	1.5	0	0	1.1	Compliant	-71.003951	42.20767
745 WASHINGTON ST	rmp_742	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	0.5	2.1	1.5	4	1.8	Compliant	-71.00665	42.20895
745 WASHINGTON ST	rmp_743	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	2.1	1.6	3.5	5	2.4	Compliant	-71.004604	42.20894
714 WASHINGTON ST	rmp_744	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	2.4	2.3	0	0	1.3	Compliant	-71.003892	42.20788
87 CENTRAL AV	rmp_745	Pass	0	Good	Present	Good	Compliant	Compliant	4.4	1	2.8	4	0.5	Compliant	-71.008037	42.20573
742 WASHINGTON ST	rmp_746	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	0.1	1.4	0	0	0.7	Compliant	-71.003933	42.2077
745 WASHINGTON ST	rmp_747	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	2.4	1.3	2.5	3	0.9	Compliant	-71.00389	42.20891
745 WASHINGTON ST	rmp_748	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	0.6	2.1	2.4	8	2.1	Compliant	-71.004321	42.20895
23 CENTRAL AV	rmp_749	Pass	0	Good	Present	Good	Compliant	Compliant	4.4	0.4	4.7	4	1.2	Compliant	-71.005235	42.20696
714 WASHINGTON ST	rmp_750	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	2.5	0.2	0	0	3.8	Compliant	-71.003948	42.20787
745 WASHINGTON ST	rmp_751	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	3.5	2	2.8	2	1.6	Compliant	-71.006775	42.20893
110 MONATIQUOT AV	rmp_752	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	4.1	0.4	4	2	2.6	Compliant	-71.009464	42.21548
3 WINDEMERE CR	rmp_753	Pass	0	Fair	Present	Good	Compliant	Compliant	0.4	0.7	4.5	2	0.9	Compliant	-71.011228	42.2191
111 MONATIQUOT AV	rmp_754	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	4.3	0.3	5.1	3	2.8	Compliant	-71.009593	42.21569
84 OAK ST	rmp_755	Fail	3	Good	Present	Good	Compliant	Not Compliant	3.2	3.7	8.4	3	0.3	Compliant	-71.009711	42.21737
140 HOLLIS AV	rmp_756	Fail	5	Good	Not Present	Not Present	Compliant	Not Compliant	3.9	2.2	1.5	6	3	Compliant	-71.00941	42.21662
150 HOLLIS AV	rmp_757	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	4.1	0.6	4.1	3	1	Compliant	-71.009681	42.21662
149 HOLLIS AV	rmp_758	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	5.5	1.2	4.4	2	0.4	Compliant	-71.009674	42.21679
149 HOLLIS AV	rmp_759	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	5.5	1.2	4.4	2	0.4	Compliant	-71.009674	42.21679
83 WINDEMERE CR	rmp_760	Pass	0	Fair	Present	Good	Compliant	Compliant	2.3	1.1	1.8	4	0.9	Compliant	-71.011972	42.21893
39 OAK ST	rmp_761	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	4.2	1	5.4	5	2.7	Compliant	-71.009303	42.21574
4 WINDEMERE CR	rmp_762	Pass	0	Good	Present	Good	Compliant	Compliant	0.9	0.4	1	4	0.7	Compliant	-71.010984	42.21918
84 HOLLIS AV	rmp_763	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.4	0.1	5	5	1.6	Compliant	-71.006503	42.21685
144 OAK ST	rmp_764	Pass	0	Fair	Present	Good	Compliant	Compliant	1.1	0.4	3.7	0	1.4	Compliant	-71.010068	42.21942
50 MAPLE ST	rmp_765	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	5.4	0	3.1	4	0.7	Compliant	-71.005693	42.21742
139 HOLLIS AV	rmp_766	Fail	3	Poor	Not Present	Not Present	Compliant	Not Compliant	4.7	1	3.1	3	1.8	Compliant	-71.009443	42.21678
39 OAK ST	rmp_767	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.1	0.9	3.8	5	1.5	Compliant	-71.009279	42.2156
110 MONATIQUOT AV	rmp_768	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	4.7	0.2	3.6	5	2.9	Compliant	-71.009587	42.2156
507 WASHINGTON ST	rmp_769	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4.4	2.9	3.3	6	0.1	Compliant	-71.004815	42.21599
84 WINDEMERE CR	rmp_770	Pass	0	Fair	Present	Good	Compliant	Compliant	3.4	0.3	2.8	2	0	Compliant	-71.01216	42.21888
39 OAK ST	rmp_771	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	4.3	1.1	4.5	4	2.2	Compliant	-71.009387	42.21577
100 OAK ST	rmp_772	Fail	3	Good	Present	Good	Compliant	Not Compliant	2.1	3.1	7.7	2	2.1	Compliant	-71.009738	42.21752
70 HOLLIS AV	rmp_773	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3	0.6	1.9	6	0.3	Compliant	-71.006399	42.21719
111 MONATIQUOT AV	rmp_774	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	4.2	0.7	5.3	3	0.3	Compliant	-71.009512	42.21576
21 CLARK ST	rmp_775	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	7.5	0.9	2.5	4	0.9	Compliant	-71.001846	42.21765
490 WASHINGTON ST	rmp_776	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	2.8	0.2	0	6	3.4	Compliant	-71.003593	42.21605
22 CLARK ST	rmp_777	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	5.2	0.2	3.8	1	5.8	Compliant	-71.001777	42.21777

**Braintree, MA - ADA Ramp Assessment  
2018**

482 WASHINGTON ST	rmp_778	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3	1.7	1.6	4	0.4	Compliant	-71.003502	42.21621
440 WASHINGTON ST	rmp_779	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	2.6	1.3	2	1	2	Compliant	-71.002977	42.21772
519 WASHINGTON ST	rmp_780	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	3.3	1.6	2.9	1	8.2	Compliant	-71.004618	42.21515
104 WYMAN RD	rmp_781	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	5.7	0.1	8.2	8	0.1	Compliant	-71.001828	42.21629
482 WASHINGTON ST	rmp_782	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	2.2	1.9	1.2	6	0.6	Compliant	-71.003289	42.21643
490 WASHINGTON ST	rmp_783	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	2.2	2.3	4.2	3	3.4	Compliant	-71.003687	42.21607
482 WASHINGTON ST	rmp_784	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	5.2	1.4	1.7	4	0.7	Compliant	-71.003176	42.21664
24 WEBSTER RD	rmp_785	Fail	4	Fair	Not Present	Not Present	Not Compliant	Compliant	3.6	3	7.1	0	1.5	Compliant	-71.00204	42.21636
546 WASHINGTON ST	rmp_786	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	5.2	0.4	2.3	4	1.7	Compliant	-71.004376	42.21512
432 WASHINGTON ST	rmp_787	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	1.4	1.1	0.4	2	4.1	Compliant	-71.002979	42.21787
10 WEBSTER RD	rmp_788	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	5	0	0.5	3	1	Compliant	-71.002433	42.21651
519 WASHINGTON ST	rmp_789	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3.8	0.8	3.5	3	4.5	Compliant	-71.00474	42.21507
482 WASHINGTON ST	rmp_790	Fail	4	Poor	Not Present	Not Present	Compliant	Compliant	3	2.4	0	0	3.3	Compliant	-71.002488	42.21644
482 WASHINGTON ST	rmp_791	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	2.9	1.4	0.5	3	4.6	Compliant	-71.003201	42.21661
460 WASHINGTON ST	rmp_792	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3	1.1	3.5	5	0.4	Compliant	-71.003135	42.21674
482 WASHINGTON ST	rmp_793	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	4.7	1.5	5.9	4	2.1	Compliant	-71.003362	42.21634
7 DAVIS RD	rmp_794	Fail	5	Good	Not Present	Not Present	Compliant	Not Compliant	2.1	3	6.1	2	3.7	Compliant	-71.023304	42.21604
381 WASHINGTON ST	rmp_795	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	5.2	0.4	3.6	2	0.7	Compliant	-71.003682	42.21955
469 WASHINGTON ST	rmp_796	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	1.7	1.8	2.7	2	1.3	Compliant	-71.003364	42.21667
87 COCHATO RD	rmp_797	Fail	3	Good	Present	Good	Compliant	Compliant	1.1	3	8.2	9	0.9	Compliant	-71.008042	42.21994
381 WASHINGTON ST	rmp_798	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	0.8	0.9	0	0	3	Compliant	-71.003665	42.2195
391 WASHINGTON ST	rmp_799	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	2.1	1.7	0	0	6.4	Compliant	-71.003641	42.21942
28 ELMWOOD AV	rmp_800	Fail	1	Good	Present	Good	Compliant	Compliant	1.9	1.5	4.7	1	1	Compliant	-71.010899	42.20842
46 AZEL RD	rmp_801	Pass	0	Good	Present	Good	Compliant	Compliant	4	0.2	2.3	3	0.3	Compliant	-71.010042	42.20685
34 LAKEVIEW AV	rmp_802	Pass	0	Good	Present	Good	Compliant	Compliant	3.8	0.9	2	4	0.5	Compliant	-71.010384	42.20782
37 AZEL RD	rmp_803	Pass	0	Good	Present	Good	Compliant	Compliant	3.8	0.3	2	3	2.3	Compliant	-71.009827	42.20674
256 TREMONT ST	rmp_804	Pass	0	Good	Present	Good	Compliant	Compliant	3.5	0.3	2	3	1	Compliant	-71.010023	42.21021
26 LAKEVIEW AV	rmp_805	Pass	0	Good	Present	Good	Compliant	Compliant	4.7	0.1	2.7	4	1.7	Compliant	-71.010944	42.20748
6 OAK ST	rmp_806	Fail	1	Poor	Present	Good	Compliant	Compliant	3.9	0.6	3.4	4	0.6	Compliant	-71.009617	42.21435
44 LAKEVIEW AV	rmp_807	Fail	1	Good	Present	Good	Compliant	Compliant	2.7	1.5	5.1	2	1.3	Compliant	-71.010252	42.20791
14 SUMNER AV	rmp_808	Fail	1	Fair	Present	Good	Compliant	Compliant	1.5	0.3	2	3	3.6	Compliant	-71.011028	42.20738
33 LAKEVIEW AV	rmp_809	Fail	1	Good	Present	Good	Compliant	Compliant	2.2	2.6	2.2	0	2.4	Compliant	-71.010523	42.2076
242 TREMONT ST	rmp_810	Pass	0	Good	Present	Good	Compliant	Compliant	4.2	1.1	1	4	1.1	Compliant	-71.010049	42.21008
23 LAKEVIEW AV	rmp_811	Pass	0	Good	Present	Good	Compliant	Compliant	4.6	0.5	4.2	3	2.9	Compliant	-71.010651	42.20751
122 WESTON AV	rmp_812	Pass	0	Good	Present	Good	Compliant	Compliant	2.8	0.7	3.6	2	0.7	Compliant	-71.009931	42.21191
26 LAKEVIEW AV	rmp_813	Fail	1	Good	Present	Good	Compliant	Compliant	3.4	1.4	2.1	2	2.1	Compliant	-71.010784	42.20756
187 HOLLINGSWORTH AV	rmp_814	Fail	5	Good	Not Present	Not Present	Compliant	Not Compliant	6.9	1.8	2.8	6	2.9	Compliant	-71.013565	42.20906
34 AZEL RD	rmp_815	Pass	0	Good	Present	Good	Compliant	Compliant	4.3	0.1	3.1	1	2	Compliant	-71.00995	42.20668
230 TREMONT ST	rmp_816	Fail	1	Good	Present	Good	Compliant	Compliant	3.8	0.8	2	6	0.4	Compliant	-71.00991	42.20931
175 HOLLINGSWORTH AV	rmp_817	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	5	1.1	1.8	2	2.8	Compliant	-71.013396	42.20914
280 TREMONT ST	rmp_818	Fail	1	Good	Present	Good	Compliant	Compliant	3.2	2.5	5.6	2	0.9	Compliant	-71.009981	42.21101
175 WEST ST	rmp_819	Pass	0	Fair	Present	Fair	Compliant	Compliant	1.8	0.2	0	4	0.4	Compliant	-71.012378	42.21489
7 WALNUT ST	rmp_820	Pass	0	Good	Present	Good	Compliant	Compliant	1	0.9	0.1	2	0.5	Compliant	-71.012161	42.21492
405 FRANKLIN ST	rmp_821	Fail	1	Good	Present	Good	Compliant	Compliant	0.6	1.1	2.5	3	3.3	Compliant	-71.019421	42.21197
220 FORBES RD	rmp_822	Pass	0	Good	Present	Good	Compliant	Compliant	4.3	0.8	0	0	1.6	Compliant	-71.035265	42.21992
161 FORBES RD	rmp_823	Pass	0	Good	Present	Good	Compliant	Compliant	3.6	0.6	0	0	1	Compliant	-71.033678	42.22057
161 FORBES RD	rmp_824	Fail	1	Good	Present	Good	Compliant	Compliant	0.8	2.1	0	0	2.4	Compliant	-71.033012	42.22074
220 FORBES RD	rmp_825	Fail	3	Good	Present	Good	Compliant	Compliant	6.3	1.3	0	0	5.6	Compliant	-71.035574	42.21965
161 FORBES RD	rmp_826	Pass	0	Good	Present	Good	Compliant	Compliant	1.4	0.8	0	0	0.6	Compliant	-71.03385	42.22055
161 FORBES RD	rmp_827	Fail	1	Good	Present	Good	Compliant	Compliant	4.8	1.1	0	0	4	Compliant	-71.03358	42.2207
121 GRANDVIEW RD	rmp_828	Pass	0	Good	Present	Good	Compliant	Compliant	0.3	0.6	0	0	0.9	Compliant	-71.032347	42.22067
220 FORBES RD	rmp_829	Fail	1	Good	Present	Good	Compliant	Compliant	3.9	1.5	0	0	0.7	Compliant	-71.035369	42.21983
161 FORBES RD	rmp_830	Pass	0	Good	Present	Good	Compliant	Compliant	0.3	1.1	0	0	1.2	Compliant	-71.033729	42.22067
121 GRANDVIEW RD	rmp_831	Fail	2	Good	Present	Good	Compliant	Not Compliant	0.3	2.8	0	0	0.3	Compliant	-71.032861	42.22067
20 30 60 FORBES RD	rmp_832	Fail	2	Good	Present	Good	Compliant	Not Compliant	0.4	0.6	0.7	1	6	Compliant	-71.032026	42.22066
161 FORBES RD	rmp_833	Pass	0	Good	Present	Good	Compliant	Compliant	0.3	0.2	0	0	0.4	Compliant	-71.033698	42.22067
121 GRANDVIEW RD	rmp_834	Fail	1	Good	Present	Good	Compliant	Compliant	3.2	1.6	0	0	2	Compliant	-71.033702	42.22056
550 WASHINGTON ST	rmp_835	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3.7	0.3	3.1	4	4.5	Compliant	-71.004473	42.21477
384 WASHINGTON ST	rmp_836	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	4.3	0.3	3.5	5	2.6	Compliant	-71.003531	42.21967
374 WASHINGTON ST	rmp_837	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4	1.3	2.1	3	0.6	Compliant	-71.003577	42.21986
10 FORBES RD	rmp_838	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	4.2	1.4	4.3	4	2.4	Compliant	-71.028411	42.22017
10 FORBES RD	rmp_839	Pass	0	Good	Present	Good	Compliant	Not Compliant	1.2	0.9	0	0	1.9	Compliant	-71.02886	42.22025
50 FORBES RD	rmp_840	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	1.2	0.1	0	0	1.2	Compliant	-71.031122	42.22061
265 GRANITE ST	rmp_841	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	0.3	1.5	4.4	0	1.2	Compliant	-71.028226	42.22025
50 FORBES RD	rmp_842	Fail	2	Good	Present	Fair	Compliant	Not Compliant	1.7	3.2	0	0	0.5	Compliant	-71.031186	42.22074

Ramp is not flush to road.

landing compliant because of flares

**Braintree, MA - ADA Ramp Assessment  
2018**

50 FORBES RD	rmp_843	Pass	0	Good	Present	Good	Compliant	Not Compliant	1.2	0.4	0	0	1.4	Compliant	-71.028994	42.22035	landing compliant because of flares
50 FORBES RD	rmp_844	Pass	0	Good	Present	Good	Compliant	Compliant	4.3	1.1	0	0	1.4	Compliant	-71.031405	42.22074	
275 GRANITE ST	rmp_845	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	11.4	1.5	0	0	1.6	Compliant	-71.027246	42.21956	ramp slope 11.4
10 FORBES RD	rmp_846	Fail	5	Good	Not Present	Not Present	Compliant	Not Compliant	5.2	0.1	6.8	7	1.7	Compliant	-71.028545	42.22014	
265 GRANITE ST	rmp_847	Fail	5	Poor	Not Present	Not Present	Compliant	Not Compliant	9.2	1.8	0	0	2.8	Compliant	-71.027788	42.21996	
275 GRANITE ST	rmp_848	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	6.8	1	1.4	0	0.5	Not Compliant	-71.027469	42.21974	
265 GRANITE ST	rmp_849	Fail	4	Poor	Not Present	Not Present	Compliant	Not Compliant	4.5	1	0	0	4.9	Compliant	-71.027593	42.21982	
265 GRANITE ST	rmp_850	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	8.2	1.6	0	0	2.1	Compliant	-71.027903	42.22002	
50 FORBES RD	rmp_851	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	0.5	0.2	0	0	1.1	Compliant	-71.029418	42.22057	
610 WASHINGTON ST	rmp_852	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.3	1	0.9	4	0.8	Compliant	-71.004301	42.21209	
594 WASHINGTON ST	rmp_853	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3.3	1.9	3.3	2	0.8	Compliant	-71.004347	42.21223	
1 WYNOT RD	rmp_854	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.7	1.2	2.2	3	2.3	Compliant	-71.004566	42.21376	
620 WASHINGTON ST	rmp_855	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	5.7	1.7	0	0	0.4	Compliant	-71.004198	42.21177	
586 WASHINGTON ST	rmp_856	Fail	3	Poor	Not Present	Not Present	Compliant	Compliant	2.8	2.1	0.7	4	2	Compliant	-71.004443	42.21281	
594 WASHINGTON ST	rmp_857	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.8	0.7	3.4	3	0.3	Compliant	-71.004429	42.21243	
614 WASHINGTON ST	rmp_858	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	5.2	2.5	0	0	1.3	Compliant	-71.004221	42.21183	
654 WASHINGTON ST	rmp_859	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	2.4	0.4	3.8	4	9.4	Compliant	-71.003669	42.21056	
578 WASHINGTON ST	rmp_860	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	2.3	3.6	4.6	1	3.8	Compliant	-71.004497	42.21297	
552 WASHINGTON ST	rmp_861	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.5	0.4	0.7	2	0.4	Compliant	-71.004568	42.21383	
62 PARTRIDGE HILL RD	rmp_862	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.9	1.2	1.1	4	0.2	Compliant	-71.029094	42.21824	
4 WESTON AV	rmp_863	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	4.1	0.1	2.6	2	2.9	Compliant	-71.004378	42.21182	
41 ACADEMY ST	rmp_864	Fail	1	Good	Present	Good	Compliant	Compliant	0.7	1.8	4.4	2	0.7	Compliant	-71.005673	42.20985	
601 WASHINGTON ST	rmp_865	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	5	0.7	1	1	2.1	Compliant	-71.00456	42.21239	
659 WASHINGTON ST	rmp_866	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	6.1	0.2	2.2	3	0.8	Compliant	-71.003813	42.21045	
53 ACADEMY ST	rmp_867	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	0.5	4.4	1	1.9	Compliant	-71.005848	42.20986	
581 WASHINGTON ST	rmp_868	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4.3	2	2.8	2	1.5	Compliant	-71.004693	42.21294	
607 WASHINGTON ST	rmp_869	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	4.2	1.1	3.7	1	2.2	Compliant	-71.004457	42.21197	
671 WASHINGTON ST	rmp_870	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	5.7	1.9	3	2	2.4	Compliant	-71.003741	42.20992	
569 WASHINGTON ST	rmp_871	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.9	0.9	0	2	2.4	Compliant	-71.004754	42.21355	
555 WASHINGTON ST	rmp_872	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4.1	2.3	2.6	0	2.1	Compliant	-71.004766	42.21366	
77 ACADEMY ST	rmp_873	Fail	2	Good	Present	Good	Compliant	Compliant	1.8	1.7	3.6	3	5.8	Compliant	-71.007133	42.20998	
77 ACADEMY ST	rmp_874	Pass	0	Good	Present	Good	Compliant	Compliant	0.9	0.5	0	3	2.5	Compliant	-71.00717	42.20989	
87 WESTON AV	rmp_875	Pass	0	Good	Present	Good	Compliant	Compliant	3	0.9	4.8	2	0.1	Compliant	-71.008076	42.21175	
71 WESTON AV	rmp_876	Fail	1	Good	Present	Good	Compliant	Compliant	2.9	1.6	4.4	0	2.6	Compliant	-71.007884	42.21178	
20 PARTRIDGE HILL RD	rmp_877	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	2.2	1.6	1.5	3	2.9	Compliant	-71.027899	42.21882	
87 BRIERWOOD RD	rmp_878	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	2.3	0.2	5.5	4	0.2	Compliant	-71.026191	42.21675	
66 BLOSSOM RD	rmp_879	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.4	0.4	1.5	4	2	Compliant	-71.026116	42.21692	
32 PARTRIDGE HILL RD	rmp_880	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.1	0.1	1.8	2	1.9	Compliant	-71.028037	42.21874	
57 BLOSSOM RD	rmp_881	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	1	2.9	3.6	1	0.3	Compliant	-71.02632	42.21688	
74 ROBINSON AV	rmp_882	Fail	1	Good	Present	Good	Compliant	Compliant	4.2	1	1.7	4	3.7	Compliant	-71.007983	42.21209	
71 MT VERNON AV	rmp_883	Pass	0	Fair	Present	Fair	Compliant	Compliant	2.8	0.9	4.6	3	1.1	Compliant	-71.008202	42.213	
65 MT VERNON ST	rmp_884	Pass	0	Good	Present	Good	Compliant	Compliant	3.1	0.9	2.7	4	2.3	Compliant	-71.008099	42.21213	
41 MT VERNON ST	rmp_885	Pass	0	Good	Present	Good	Compliant	Compliant	3.8	0.8	3.3	3	0.4	Compliant	-71.008296	42.21291	
72 MT VERNON AV	rmp_886	Pass	0	Good	Present	Good	Compliant	Compliant	3.4	0.3	1.5	5	2.1	Compliant	-71.008185	42.21289	
16 MT VERNON ST	rmp_887	Fail	1	Good	Present	Good	Compliant	Compliant	4.5	0.7	4.3	2	4	Compliant	-71.008367	42.21337	
19 MT VERNON ST	rmp_888	Pass	0	Good	Present	Good	Compliant	Compliant	3	0.2	3.4	4	0.3	Compliant	-71.008498	42.21366	
6 FALLON CR	rmp_889	Fail	3	Poor	Not Present	Not Present	Compliant	Not Compliant	3.9	0.8	4.2	4	2	Compliant	-71.023119	42.21588	
94 WEST ST	rmp_890	Pass	0	Fair	Present	Good	Compliant	Compliant	2.7	0.8	3.1	2	1	Compliant	-71.008646	42.21431	
86 WEST ST	rmp_891	Pass	0	Good	Present	Poor	Compliant	Compliant	0.8	1	0	0	1.8	Compliant	-71.0085	42.21431	
60 WEST ST	rmp_892	Fail	1	Fair	Present	Poor	Compliant	Compliant	2.2	1.1	0	0	3.5	Compliant	-71.007179	42.21439	
68 WEST ST	rmp_893	Fail	1	Poor	Present	Fair	Compliant	Compliant	2.9	0.9	5.2	3	2.5	Compliant	-71.007318	42.21438	
111 PARKSIDE AV	rmp_894	Fail	1	Fair	Present	Fair	Compliant	Compliant	1.3	1.2	3.7	3	3.7	Compliant	-71.01307	42.22015	
152 WALNUT ST	rmp_895	Fail	3	Poor	Not Present	Not Present	Compliant	Compliant	0.8	2.1	4.6	3	0.3	Compliant	-71.013226	42.22005	
126 HERBERT RD	rmp_896	Pass	0	Good	Present	Good	Compliant	Compliant	0.3	0.4	3.4	4	2.2	Compliant	-71.013112	42.21419	
176 WEST ST	rmp_897	Pass	0	Good	Present	Good	Compliant	Compliant	0.5	0.6	3.1	3	1.4	Compliant	-71.012998	42.21418	
45 PACKARD DR	rmp_898	Pass	0	Good	Present	Good	Compliant	Compliant	1.8	0.2	3	2	2.4	Compliant	-71.014438	42.21578	
215 WEST ST	rmp_899	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	1	3.5	1	2.7	Compliant	-71.01394	42.21487	
20 PACKARD DR	rmp_900	Pass	0	Good	Present	Good	Compliant	Compliant	1.6	0.2	2	3	0.3	Compliant	-71.014562	42.21572	
15 WEST ST	rmp_901	Fail	1	Fair	Present	Good	Compliant	Compliant	3.8	2.5	0	0	2.1	Compliant	-71.005274	42.21488	
23 WEST ST	rmp_902	Fail	2	Poor	Present	Good	Compliant	Compliant	3.9	1.7	0	0	2.8	Compliant	-71.005411	42.21483	
529 WASHINGTON ST	rmp_903	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	4.7	0.6	2.8	2	1.9	Compliant	-71.00471	42.21488	
529 WASHINGTON ST	rmp_904	Fail	2	Poor	Not Present	Not Present	Compliant	Compliant	3.6	0.5	2.1	2	1.8	Compliant	-71.004624	42.21477	
55 CLEVELAND AV	rmp_905	Pass	0	Good	Present	Good	Compliant	Compliant	2.1	0.9	3.6	2	2	Compliant	-70.994089	42.21624	
45 CLEVELAND AV	rmp_906	Fail	1	Good	Present	Good	Compliant	Compliant	0.4	3.5	3.7	6	2.1	Compliant	-70.994081	42.21637	
114 ADAMS ST	rmp_907	Pass	0	Good	Present	Good	Compliant	Compliant	0.9	0.9	3.8	0	1.5	Compliant	-70.990841	42.22452	

**Braintree, MA - ADA Ramp Assessment  
2018**

477 ELM ST	rmp_908	Fail	1	Good	Present	Good	Compliant	Compliant	4.3	0.3	0	0	5	Compliant	-70.986723	42.22419
540 COMMERCIAL ST	rmp_909	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	7.7	2	2.7	5	1.6	Compliant	-70.986855	42.22735
25 ADAMS ST	rmp_910	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	1.4	2.9	1.3	4	5.4	Compliant	-70.996447	42.22457
437 COMMERCIAL ST	rmp_911	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	5.6	0.8	3.8	4	2.6	Compliant	-70.985702	42.22471
532 COMMERCIAL ST	rmp_912	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	6.1	1.4	2.8	7	0.8	Compliant	-70.986777	42.22724
560 COMMERCIAL ST	rmp_913	Pass	0	Good	Present	Good	Compliant	Compliant	1.9	0.1	1.2	3	0.5	Compliant	-70.987427	42.22803
50 MORRISON RD	rmp_914	Fail	2	Good	Present	Good	Compliant	Compliant	2.8	0.4	0	0	5.4	Not Compliant	-70.992338	42.22513
293 ELM ST	rmp_915	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	1.7	0.8	4.7	6	4.5	Compliant	-70.996793	42.22427
1 MORRISON RD	rmp_916	Fail	1	Good	Present	Good	Compliant	Compliant	0.6	2.7	5.1	1	1.5	Compliant	-70.990716	42.22451
30 MORRISON RD	rmp_917	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	3.3	2.8	4.6	7	0.7	Compliant	-70.991166	42.22533
25 ADAMS ST	rmp_918	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	2.8	2.4	1.3	6	7.2	Compliant	-70.99631	42.22469
200 ADAMS ST	rmp_919	Pass	0	Good	Present	Good	Compliant	Compliant	2.3	0.5	0	0	1.8	Compliant	-70.986853	42.2242
124 CLEVELAND AV	rmp_920	Fail	1	Good	Present	Good	Compliant	Compliant	4.2	2.9	3.3	2	1.8	Compliant	-70.993953	42.2138
136 CLEVELAND AV	rmp_921	Pass	0	Good	Present	Good	Compliant	Compliant	3.7	0.8	5.7	3	2.9	Compliant	-70.994005	42.21328
3 HARRISON AV	rmp_922	Pass	0	Good	Present	Good	Compliant	Compliant	3.2	1	3.2	3	2.9	Compliant	-70.99389	42.21523
150 CLEVELAND AV	rmp_923	Fail	1	Good	Present	Good	Compliant	Compliant	5	0	3.3	4	0.2	Compliant	-70.994026	42.21271
94 CLEVELAND AV	rmp_924	Pass	0	Good	Present	Good	Compliant	Compliant	4.8	0.7	5.2	4	0.7	Compliant	-70.993928	42.21445
144 CLEVELAND AV	rmp_925	Pass	0	Good	Present	Good	Compliant	Compliant	3.8	1	3.2	3	1.9	Compliant	-70.99401	42.21317
32 COOLIDGE AV	rmp_926	Fail	1	Good	Present	Good	Compliant	Compliant	3.4	1.9	3.2	4	0.2	Compliant	-70.992447	42.21388
162 CLEVELAND AV	rmp_927	Fail	1	Good	Present	Good	Compliant	Compliant	5.2	1	3.7	3	0.9	Compliant	-70.994021	42.21256
116 CLEVELAND AV	rmp_928	Pass	0	Good	Present	Good	Compliant	Compliant	3.9	1	4.3	3	0.3	Compliant	-70.993974	42.21395
106 CLEVELAND AV	rmp_929	Fail	2	Good	Present	Good	Compliant	Compliant	3.6	1.9	0	4	2.4	Not Compliant	-70.993939	42.21433
71 CLEVELAND AV	rmp_930	Fail	1	Good	Present	Good	Compliant	Compliant	2	1.2	0.4	4	3.7	Compliant	-70.99406	42.21531
6 HARRISON AV	rmp_931	Fail	3	Good	Present	Good	Compliant	Compliant	1.9	4.4	6.2	2	3.1	Compliant	-70.993892	42.21534
48 CLEVELAND AV	rmp_932	Pass	0	Good	Present	Fair	Compliant	Compliant	1.5	0.1	1.1	5	1.9	Compliant	-70.993906	42.21637
50 CLEVELAND AV	rmp_933	Fail	1	Good	Present	Good	Compliant	Compliant	3.2	0.6	4.9	2	3.7	Compliant	-70.993903	42.21628
6 JAY ST	rmp_934	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	0.9	0	0	0.1	Compliant	-70.99015	42.22718
465 ELM ST	rmp_935	Pass	0	Good	Present	Fair	Compliant	Compliant	1.8	0.6	0	0	0.2	Compliant	-70.99013	42.22718
527 ELM ST	rmp_936	Fail	1	Good	Present	Good	Compliant	Compliant	2.3	0.2	1.5	6	0.7	Compliant	-70.987887	42.22805
397 ELM ST	rmp_937	Fail	1	Fair	Present	Good	Compliant	Compliant	1.6	1.5	0.9	5	0.1	Compliant	-70.992963	42.22619
419 ELM ST	rmp_938	Fail	3	Poor	Not Present	Not Present	Compliant	Compliant	1.8	0.8	2.2	2	3.9	Compliant	-70.992737	42.22631
80 INDEPENDENCE AV	rmp_939	Pass	0	Good	Present	Good	Compliant	Compliant	4.6	0.5	3.2	3	0.2	Compliant	-71.00454	42.22719
178 WASHINGTON ST	rmp_940	Fail	1	Good	Present	Good	Compliant	Compliant	2.6	0.5	1.1	5	4.9	Compliant	-71.004344	42.22651
280 ELM ST	rmp_941	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	0	1.2	4.4	1	0.3	Compliant	-70.997245	42.22427
71 INDEPENDENCE AV	rmp_942	Fail	6	Fair	Not Present	Not Present	Compliant	Not Compliant	7.6	3	2.7	7	4.2	Compliant	-71.005028	42.22827
96 CHURCH ST	rmp_943	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	1	0.6	0	0	0.7	Compliant	-71.003382	42.22561
4 BUSHNELL TR	rmp_944	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	4.1	1.4	4.3	4	1.9	Compliant	-71.003465	42.22602
275 ELM ST	rmp_945	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	1	1.7	2	6	4	Compliant	-70.996962	42.22414
109 CHURCH ST	rmp_946	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	0.7	0.1	4.7	3	0.8	Compliant	-71.003381	42.22592
8 HAWTHORN RD	rmp_947	Fail	5	Poor	Not Present	Not Present	Compliant	Not Compliant	1.1	1.4	3.7	3	3.8	Compliant	-70.996931	42.22446
275 ELM ST	rmp_948	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	0.6	2.5	0.9	4	2	Compliant	-70.997183	42.22412
80 INDEPENDENCE AV	rmp_949	Fail	5	Poor	Not Present	Not Present	Compliant	Compliant	7.3	1.3	7.4	6	0.9	Compliant	-71.00483	42.22829
293 ELM ST	rmp_950	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	0.6	0.3	2.2	4	3.2	Compliant	-70.996769	42.22435
178 WASHINGTON ST	rmp_951	Fail	2	Good	Present	Good	Compliant	Compliant	4	0.7	6.1	5	3.6	Compliant	-71.004376	42.22659
80 INDEPENDENCE AV	rmp_952	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	0.8	2.8	4	1.7	Compliant	-71.004527	42.22725
391 MIDDLE ST	rmp_953	Pass	0	Good	Present	Good	Compliant	Compliant	0.9	0.5	0	4	0.3	Compliant	-70.988567	42.21321
361 ELM ST	rmp_954	Pass	0	Good	Present	Good	Compliant	Compliant	2.1	0.5	3.1	4	1.9	Compliant	-70.99446	42.22577
6 LAWNVIEW DR	rmp_955	Fail	1	Good	Present	Good	Compliant	Compliant	0.5	1.1	1.4	5	3.2	Compliant	-70.994123	42.2259
16 LOGAN DR	rmp_956	Fail	2	Good	Present	Good	Compliant	Compliant	1	1.9	7	3	1.6	Compliant	-70.988683	42.21143
11 KIRBY ST	rmp_957	Fail	1	Good	Present	Good	Compliant	Compliant	0.6	1.5	3.4	2	1.3	Compliant	-70.99018	42.21027
94 KENSINGTON ST	rmp_958	Pass	0	Good	Present	Good	Compliant	Compliant	0.3	0.6	3.6	3	0.3	Compliant	-70.99009	42.21202
70 LOGAN DR	rmp_959	Pass	0	Good	Present	Good	Compliant	Compliant	0.7	0.6	3.4	3	0.3	Compliant	-70.990423	42.21079
5 KENSINGTON ST	rmp_960	Fail	2	Good	Present	Good	Compliant	Compliant	1.5	2.1	7.8	3	2.2	Compliant	-70.988923	42.21137
10 KIRBY ST	rmp_961	Pass	0	Good	Present	Good	Compliant	Compliant	0	0.8	1.1	4	0.1	Compliant	-70.990062	42.21033
10 KIRBY ST	rmp_962	Fail	1	Good	Present	Good	Compliant	Compliant	1	1.5	3.2	2	1.7	Compliant	-70.990312	42.21084
24 CONRAD ST	rmp_963	Pass	0	Good	Present	Good	Compliant	Compliant	3.9	0.3	0	1	0.4	Compliant	-70.997361	42.2322
210 ELM LAWN RD	rmp_964	Pass	0	Good	Present	Good	Compliant	Compliant	1.3	0.1	0	0	2.4	Compliant	-70.998587	42.23228
37 ROBERT ST	rmp_965	Pass	0	Good	Present	Good	Compliant	Not Compliant	0.2	0.6	2.7	4	0.3	Compliant	-70.998149	42.23189
185 ELM LAWN RD	rmp_966	Fail	1	Good	Present	Good	Compliant	Compliant	1	0.7	4.3	0	2.7	Not Compliant	-70.998058	42.23177
74 ELM LAWN RD	rmp_967	Fail	1	Good	Present	Good	Compliant	Compliant	1.7	2.7	1.5	4	2.1	Compliant	-70.994759	42.22841
188 ELM LAWN RD	rmp_968	Fail	1	Good	Present	Good	Compliant	Compliant	1.1	1.4	4.3	2	1.7	Compliant	-70.998184	42.23168
37 ROBERT ST	rmp_969	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	0.1	0	4	0.5	Compliant	-70.998312	42.23217
155 ELM LAWN RD	rmp_970	Pass	0	Good	Present	Good	Compliant	Compliant	0.5	0.5	1.3	5	1.8	Compliant	-70.997132	42.23087
27 ROBERT ST	rmp_971	Pass	0	Good	Present	Good	Compliant	Compliant	2.4	0.2	1.5	2	1.3	Compliant	-70.997574	42.23224
28 ROBERT ST	rmp_972	Pass	0	Good	Present	Good	Compliant	Compliant	3.3	0.7	4.4	2	0.2	Compliant	-70.997479	42.23212

lip at street

landing compliant because of flares

**Braintree, MA - ADA Ramp Assessment  
2018**

400 ELM ST	rmp_973	Fail	1	Fair	Present	Good	Compliant	Compliant	3.6	1	2.9	6	0.8	Compliant	-70.992833	42.22646
74 ELMELAWN RD	rmp_974	Fail	3	Good	Present	Good	Compliant	Compliant	1.6	1.7	6.3	2	4.9	Compliant	-70.99463	42.22846
14 PERRY RD	rmp_975	Pass	0	Good	Present	Good	Compliant	Compliant	2.9	0.2	0	0	1.3	Compliant	-70.994051	42.22871
27 PERRY RD	rmp_976	Fail	3	Good	Present	Good	Compliant	Not Compliant	0.3	1.4	1	9	2	Compliant	-70.993209	42.22897
3 ROGERS CR	rmp_977	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	4.7	6.3	4.9	1	0.5	Compliant	-70.992927	42.23001
81 BOWER RD	rmp_978	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	5.1	1.8	1	3	1.4	Compliant	-70.993298	42.22973
57 BURROUGHS RD	rmp_979	Fail	1	Good	Present	Good	Compliant	Compliant	2.3	1.6	3.4	0	2.8	Compliant	-70.993779	42.22287
68 BURROUGHS RD	rmp_980	Pass	0	Good	Present	Good	Compliant	Compliant	0	0	1.8	1	0.9	Compliant	-70.993967	42.22863
57 BURROUGHS RD	rmp_981	Pass	0	Good	Present	Good	Compliant	Compliant	0.6	0.2	1.2	2	1	Compliant	-70.993775	42.22874
422 ELM ST	rmp_982	Fail	1	Good	Present	Good	Compliant	Compliant	1.7	0.3	3.9	2	6.4	Compliant	-70.992178	42.22669
68 BURROUGHS RD	rmp_983	Pass	0	Good	Present	Good	Compliant	Compliant	3.3	0.4	0.5	3	0.9	Compliant	-70.993897	42.22864
115 BOWER RD	rmp_984	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	4.5	5.9	2.7	8	0.4	Compliant	-70.992148	42.23047
426 ELM ST	rmp_985	Fail	1	Good	Present	Good	Compliant	Compliant	1.2	1.5	5.7	2	1.8	Compliant	-70.992042	42.22675
6 JAY ST	rmp_986	Pass	0	Good	Present	Good	Compliant	Compliant	0.9	0.7	0	0	1.3	Compliant	-70.990246	42.22727
30 PERRY RD	rmp_987	Fail	1	Good	Present	Good	Compliant	Compliant	1.3	1	0	4	3.1	Compliant	-70.99331	42.22906
520 ELM ST	rmp_988	Pass	0	Good	Present	Good	Compliant	Compliant	1.8	0.4	3.8	0	0.2	Compliant	-70.987941	42.22821
484 ELM ST	rmp_989	Pass	0	Good	Present	Poor	Compliant	Compliant	0.9	1.1	0	0	0.8	Compliant	-70.990167	42.22728
80 BOWER RD	rmp_990	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	6	1.7	4.4	1	1.8	Compliant	-70.993445	42.22983
410 ELM ST	rmp_991	Fail	1	Good	Present	Good	Compliant	Compliant	0.9	1.8	5.2	2	0.4	Compliant	-70.992662	42.22653
4 WASHINGTON ST	rmp_992	Pass	0	Fair	Present	Good	Compliant	Compliant	3.6	1	4.5	2	0.1	Compliant	-71.001917	42.23195
30 WASHINGTON ST	rmp_993	Pass	0	Good	Present	Good	Compliant	Compliant	2.9	0.2	3.4	1	0.6	Compliant	-71.00202	42.23122
25 WASHINGTON ST	rmp_994	Pass	0	Good	Present	Good	Compliant	Compliant	2.7	0.4	0	0	1.8	Compliant	-71.002325	42.23122
16 WASHINGTON ST	rmp_995	Pass	0	Good	Present	Good	Compliant	Compliant	3.4	0	1.4	2	1.7	Compliant	-71.001922	42.23185
20 WASHINGTON ST	rmp_996	Pass	0	Good	Present	Good	Compliant	Compliant	3	0.6	4.1	2	2.4	Compliant	-71.001997	42.23133
358 ELM ST	rmp_997	Fail	1	Good	Present	Good	Compliant	Compliant	4	1.5	0	0	1	Compliant	-70.995283	42.22608
69 HOME PARK RD	rmp_998	Fail	2	Good	Present	Good	Compliant	Compliant	2	6.5	8.5	6	2.8	Compliant	-70.998658	42.22874
104 BLANCHARD BD	rmp_999	Fail	2	Fair	Present	Fair	Compliant	Compliant	1.8	6	6.8	4	0.2	Compliant	-70.998048	42.22913
4 BLANCHARD BD	rmp_1000	Fail	1	Good	Present	Good	Compliant	Compliant	1.7	1.1	1.6	6	3.4	Compliant	-70.995446	42.22606
112 HOME PARK RD	rmp_1001	Fail	1	Poor	Present	Good	Compliant	Compliant	0.6	0.6	0	0	2	Compliant	-70.997142	42.2298
119 BLANCHARD BD	rmp_1002	Fail	2	Good	Present	Good	Compliant	Compliant	1.8	3.9	1.4	8	1.3	Compliant	-70.997962	42.22933
7 LONGWOOD RD	rmp_1003	Fail	2	Good	Present	Good	Compliant	Compliant	1.4	5.9	4.5	8	1	Compliant	-70.998709	42.22884
62 HOME PARK RD	rmp_1004	Fail	2	Good	Present	Good	Compliant	Compliant	2.6	1.6	1	4	3.5	Compliant	-70.998872	42.22877
414 MIDDLE ST	rmp_1005	Pass	0	Good	Present	Good	Compliant	Compliant	1.2	0.3	5	5	0.5	Compliant	-70.987944	42.2126
166 CEDAR ST	rmp_1006	Fail	1	Good	Present	Good	Compliant	Compliant	1.6	1.5	4.2	0	2.1	Compliant	-71.003377	42.22854
248 RIVER ST	rmp_1007	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	1.7	1.7	2.5	5	4.9	Compliant	-70.992416	42.22079
46 LEMOYNE ST	rmp_1008	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	2.7	0.5	2.9	3	3.3	Compliant	-70.993491	42.22068
300 RIVER ST	rmp_1009	Fail	4	Poor	Not Present	Not Present	Compliant	Compliant	3.1	3.2	7.3	1	2	Compliant	-70.989555	42.22087
300 RIVER ST	rmp_1010	Fail	3	Poor	Not Present	Not Present	Compliant	Compliant	2	4.6	0.2	0	0.5	Compliant	-70.989516	42.22099
45 LEMOYNE ST	rmp_1011	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	5.1	2.4	2.2	2	1.9	Compliant	-70.993707	42.22063
234 RIVER ST	rmp_1012	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	3.4	2	6	3	4	Compliant	-70.992669	42.22076
300 RIVER ST	rmp_1013	Fail	1	Good	Present	Good	Compliant	Compliant	5.3	0.6	0.8	4	0.6	Compliant	-70.987029	42.22057
300 RIVER ST	rmp_1014	Pass	0	Fair	Present	Good	Compliant	Compliant	4.2	0.5	5	1	0.8	Compliant	-70.986926	42.22059
485 COMMERCIAL ST	rmp_1015	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3.5	2.7	4.3	0	0.3	Compliant	-70.986016	42.22587
20 HAYWARD ST	rmp_1016	Fail	2	Good	Present	Good	Compliant	Compliant	4.4	2.3	3.9	1	5.9	Compliant	-70.987651	42.2283
113 HAYWARD ST	rmp_1017	Fail	5	Good	Not Present	Not Present	Compliant	Not Compliant	1.4	1.3	6.3	6	1.9	Compliant	-70.981974	42.22947
453 COMMERCIAL ST	rmp_1018	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.7	0.7	2.7	2	2.2	Compliant	-70.985752	42.22534
116 HAYWARD ST	rmp_1019	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	0.4	1.4	2.8	2	3.6	Compliant	-70.982738	42.22946
43 CYPRESS ST	rmp_1020	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	10	0.9	1.7	8	1.3	Compliant	-70.981278	42.22479
85 HAYWARD ST	rmp_1021	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	7.1	2	4.4	1	0.7	Compliant	-70.983532	42.22913
20 HAYWARD ST	rmp_1022	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	0.2	4.7	5	1.4	Compliant	-70.987258	42.22823
67 TINGLEY RD	rmp_1023	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	5.3	0.4	3.6	5	2.2	Compliant	-70.981025	42.22474
57 TINGLEY RD	rmp_1024	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	6	1.1	3.8	7	3.3	Compliant	-70.981187	42.22468
98 HAYWARD ST	rmp_1025	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	8.9	3.6	7.3	1	2.2	Compliant	-70.982909	42.22944
125 HAYWARD ST	rmp_1026	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4.6	0.1	1.6	5	3.5	Compliant	-70.981762	42.22947
79 HAYWARD ST	rmp_1027	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	5.8	3.7	10.3	0	1.4	Compliant	-70.983759	42.22905
32 TINGLEY RD	rmp_1028	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	7.1	0.3	5.2	6	2.1	Compliant	-70.982151	42.22443
66 TINGLEY RD	rmp_1029	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	5.9	1.3	6.1	4	1.1	Compliant	-70.981116	42.22486
560 COMMERCIAL ST	rmp_1030	Pass	0	Good	Present	Good	Compliant	Compliant	2.2	0	1.1	5	1	Compliant	-70.987282	42.22812
447 COMMERCIAL ST	rmp_1031	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	1.1	0.9	0	0	0.8	Compliant	-70.985688	42.22519
8 WILKINS RD	rmp_1032	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	3.2	1.2	2.8	2	0.6	Compliant	-70.986117	42.22604
185 MIDDLE ST	rmp_1033	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	7.3	3.1	7.1	0	2.8	Compliant	-70.994539	42.21827
30 HAMILTON ST	rmp_1034	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	3.7	2.4	7.1	0	3.2	Compliant	-70.986284	42.21217
3 STRATHMORE CR	rmp_1035	Pass	0	Good	Present	Good	Compliant	Compliant	2.2	0.4	1.4	4	0.5	Compliant	-70.989056	42.21542
30 PENNIMAN TR	rmp_1036	Pass	0	Good	Present	Good	Compliant	Compliant	3.2	0.2	3.7	2	0.8	Compliant	-70.98897	42.21557
29 MARSHALL ST	rmp_1037	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	3.8	0.1	2.7	3	3.4	Compliant	-70.989383	42.21665

**Braintree, MA - ADA Ramp Assessment  
2018**

30 CLEVELAND AV	rmp_1038	Fail	2	Good	Present	Good	Compliant	Compliant	3.9	1.8	6.2	3	0.5	Compliant	-70.994033	42.21714
156 RIVER ST	rmp_1039	Fail	3	Poor	Not Present	Not Present	Compliant	Compliant	9.1	0.6	0	0	0.6	Compliant	-70.996649	42.22033
131 RIVER ST	rmp_1040	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	8.3	1.2	5.4	5	0	Compliant	-70.997684	42.22011
4 STRATHMORE CR	rmp_1041	Pass	0	Good	Present	Good	Compliant	Compliant	1.7	0.1	3	4	1.9	Compliant	-70.988929	42.21544
25 CLEVELAND AV	rmp_1042	Fail	1	Good	Present	Good	Compliant	Compliant	3.9	3.2	1.2	4	1.4	Compliant	-70.994273	42.21718
25 STRATHMORE CR	rmp_1043	Pass	0	Good	Present	Good	Compliant	Compliant	3.9	0.6	1	4	0.9	Compliant	-70.988336	42.21487
157 RIVER ST	rmp_1044	Fail	4	Poor	Not Present	Not Present	Compliant	Compliant	10	0.1	10	0	2.5	Compliant	-70.996625	42.22023
130 RIVER ST	rmp_1045	Fail	4	Poor	Not Present	Not Present	Compliant	Compliant	4.2	2.3	0	0	3.7	Compliant	-70.99791	42.2203
96 MARSHALL ST	rmp_1046	Fail	4	Fair	Not Present	Not Present	Compliant	Compliant	1	1.8	6.3	2	3.5	Compliant	-70.98631	42.21712
288 MIDDLE ST	rmp_1047	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	5.8	1.1	3.6	0	1.4	Compliant	-70.990504	42.21662
175 MIDDLE ST	rmp_1048	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	7.2	2.1	0.5	2	4.6	Compliant	-70.994598	42.21838
145 RIVER ST	rmp_1049	Fail	3	Poor	Not Present	Not Present	Compliant	Compliant	0.9	0.5	0	2	3.7	Compliant	-70.996761	42.2202
279 MIDDLE ST	rmp_1050	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	0.2	2.5	5.6	5	5.3	Not Compliant	-70.990868	42.21667
59 MARSHALL ST	rmp_1051	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	2.6	0.5	3.7	5	0.8	Compliant	-70.987797	42.21668
75 MARSHALL ST	rmp_1052	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	2.9	0.3	1.1	5	1.7	Compliant	-70.987603	42.21683
184 MIDDLE ST	rmp_1053	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	3	1.4	0	0	4	Compliant	-70.994338	42.2183
35 SPRUCE ST	rmp_1054	Fail	4	Poor	Not Present	Not Present	Compliant	Compliant	8	3.6	0	0	2.7	Compliant	-70.996785	42.22033
22 CLEVELAND AV	rmp_1055	Fail	1	Good	Present	Good	Compliant	Compliant	1.4	1.9	5.5	5	1.3	Compliant	-70.994089	42.21728
33 MARSHALL ST	rmp_1056	Fail	2	Poor	Not Present	Not Present	Compliant	Compliant	1.4	0.2	3.8	4	0	Compliant	-70.988877	42.21669
123 RIVER ST	rmp_1057	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	2	1	5.3	2	3.8	Compliant	-70.997866	42.22011
282 MIDDLE ST	rmp_1058	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3.9	1.4	2.1	5	1.6	Compliant	-70.990671	42.21679
289 MIDDLE ST	rmp_1059	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	0.2	3.9	5.2	1	3.3	Compliant	-70.990739	42.21654
33 STRATHMORE CR	rmp_1060	Pass	0	Good	Present	Good	Compliant	Compliant	2.4	0.8	4.6	2	1	Compliant	-70.988182	42.2149
16 STRATHMORE CR	rmp_1061	Pass	0	Good	Present	Good	Compliant	Compliant	3.7	0.9	4.1	1	0.5	Compliant	-70.988342	42.21497
21 MARSHALL ST	rmp_1062	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	2.3	0.2	3.4	3	1.3	Compliant	-70.989573	42.21664
33 CLEVELAND AV	rmp_1063	Fail	1	Fair	Present	Good	Compliant	Compliant	3.6	0.1	4.1	4	5.4	Compliant	-70.994232	42.21701
4 HATCH AV	rmp_1064	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	0.8	0.6	1.9	4	0.7	Compliant	-70.984246	42.21568
96 POWDER HILL DR	rmp_1065	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.1	0.6	0.4	4	1.1	Compliant	-70.984397	42.21556
30 ROBBIE RD	rmp_1066	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	0.3	0.3	3.1	2	1.6	Compliant	-70.984058	42.21557
31 ROBBIE RD	rmp_1067	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.2	0.1	1.1	3	0.5	Compliant	-70.984236	42.21544
125 HAYWARD ST	rmp_1068	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	3.4	1.8	1.7	4	0.9	Compliant	-70.981683	42.22952
130 HAYWARD ST	rmp_1069	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	4.8	5.5	6.1	0	1.2	Compliant	-70.981662	42.22965
197 HOBART ST	rmp_1070	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	2.3	0.5	3.4	3	2.4	Compliant	-70.979923	42.22873
153 HAYWARD ST	rmp_1071	Fail	1	Good	Present	Good	Compliant	Compliant	3.9	0.2	2	2	6.8	Compliant	-70.980236	42.22947
167 HAYWARD ST	rmp_1072	Fail	1	Good	Present	Good	Compliant	Compliant	2.6	1.2	0	2	5.6	Compliant	-70.980052	42.22944
2 HOWARD ST	rmp_1073	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	5.3	2.9	6.4	0	1.4	Compliant	-70.98194	42.22966
40 MAY ST	rmp_1074	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	0.3	2.3	8.3	0	2	Compliant	-70.979979	42.22888
385 COMMERCIAL ST	rmp_1075	Fail	1	Good	Present	Good	Compliant	Compliant	1.7	1.3	3.4	3	0.8	Compliant	-70.983439	42.22247
385 COMMERCIAL ST	rmp_1076	Fail	1	Good	Present	Good	Compliant	Compliant	1.7	1.3	3.4	3	0.8	Compliant	-70.983439	42.22247
365 COMMERCIAL ST	rmp_1077	Fail	1	Good	Present	Fair	Compliant	Compliant	1.1	1.3	0	0	0.4	Compliant	-70.983295	42.22221
365 COMMERCIAL ST	rmp_1078	Fail	1	Good	Present	Fair	Compliant	Compliant	1.1	1.3	0	0	0.4	Compliant	-70.983295	42.22221
50 FRONT ST	rmp_1079	Pass	0	Good	Present	Good	Compliant	Compliant	2.1	0.9	0	0	0.9	Compliant	-70.981002	42.22232
60 FRONT ST	rmp_1080	Pass	0	Good	Present	Good	Compliant	Compliant	2.3	1.2	3.2	2	0.1	Compliant	-70.980817	42.22232
84 FRONT ST	rmp_1081	Fail	1	Good	Present	Good	Compliant	Compliant	4.1	2.1	0	0	0.5	Compliant	-70.979784	42.22227
121 ALLEN ST	rmp_1082	Fail	5	Good	Not Present	Not Present	Compliant	Not Compliant	7.3	4.5	1.9	6	1.6	Compliant	-70.974077	42.22279
113 SHAW ST	rmp_1083	Fail	5	Poor	Not Present	Not Present	Compliant	Not Compliant	7.8	0.1	0	0	5	Compliant	-70.973995	42.22283
110 FRONT ST	rmp_1084	Pass	0	Fair	Present	Good	Compliant	Compliant	1.4	0.2	3.6	4	0.2	Compliant	-70.978723	42.22223
6 BOWDITCH ST	rmp_1085	Pass	0	Good	Present	Good	Compliant	Compliant	3	0.9	2.3	3	0.4	Compliant	-70.978894	42.22225
94 ALLEN ST	rmp_1086	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	5.7	4.1	8.1	1	2.9	Compliant	-70.973875	42.22262
126 FRONT ST	rmp_1087	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	10	1.2	1.7	6	5	Compliant	-70.977617	42.22218
95 SHAW ST	rmp_1088	Pass	0	Good	Present	Good	Compliant	Compliant	0.7	1	1.1	4	2.2	Compliant	-70.973622	42.22211
76 FRONT ST	rmp_1089	Pass	0	Fair	Present	Good	Compliant	Compliant	1.8	0.8	1.7	2	1.5	Compliant	-70.97992	42.22226
134 FRONT ST	rmp_1090	Fail	5	Good	Not Present	Not Present	Compliant	Not Compliant	7.7	2.5	6.2	5	1.5	Compliant	-70.97741	42.22214
95 SHAW ST	rmp_1091	Pass	0	Good	Present	Good	Compliant	Compliant	1.8	1	4.6	3	1.6	Compliant	-70.973549	42.22222
121 ALLEN ST	rmp_1092	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	3	2.4	0.9	10	2	Compliant	-70.974059	42.22271
10 HARVEST LN	rmp_1093	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	8.4	1.1	3.1	8	1.9	Compliant	-70.991013	42.21819
319 LISLE ST	rmp_1094	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	3	1.9	2.3	6	1.3	Compliant	-70.985575	42.21285
354 LISLE ST	rmp_1095	Fail	1	Poor	Present	Good	Compliant	Compliant	1.7	0.3	3.2	4	0.5	Compliant	-70.987863	42.21244
5 CONNELLY CR	rmp_1096	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	3.2	1.8	2.8	7	6.1	Compliant	-70.985339	42.2128
240 MIDDLE ST	rmp_1097	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4.5	0.6	1.9	6	0.3	Compliant	-70.99077	42.21824
244 MIDDLE ST	rmp_1098	Fail	5	Good	Not Present	Not Present	Compliant	Compliant	10	3.5	1.2	7	5.3	Compliant	-70.991735	42.21802
230 MIDDLE ST	rmp_1099	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	2.7	3	0	0	1.6	Compliant	-70.992145	42.21816
238 MIDDLE ST	rmp_1100	Fail	5	Poor	Not Present	Not Present	Compliant	Not Compliant	9.1	5.4	0	5	2.6	Compliant	-70.991934	42.21818
244 MIDDLE ST	rmp_1101	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	8.9	0.6	4.1	8	0.7	Compliant	-70.991825	42.21805
308 LISLE ST	rmp_1102	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	1.7	3.5	7.1	3	2	Compliant	-70.985279	42.21266

**Braintree, MA - ADA Ramp Assessment  
2018**

318 LISLE ST	rmp_1103	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4	1.7	2.7	3	0.5	Compliant	-70.985552	42.21267
318 LISLE ST	rmp_1104	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	8.8	0.9	5.9	1	2.1	Compliant	-70.98547	42.21265
238 MIDDLE ST	rmp_1105	Fail	5	Good	Not Present	Not Present	Compliant	Compliant	10	2	8.2	6	3.7	Compliant	-70.99187	42.21808
61 ROSEWOOD DR	rmp_1106	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	7.1	0.3	4.6	3	2.8	Compliant	-70.984842	42.21161
68 MARSHALL ST	rmp_1107	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	4.1	1	6.5	4	2	Compliant	-70.98778	42.21692
353 COMMERCIAL ST	rmp_1108	Pass	0	Good	Present	Good	Compliant	Compliant	2	1.1	0.1	3	1.8	Compliant	-70.98277	42.22145
230 MIDDLE ST	rmp_1109	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	1.9	0	0	0	3.2	Compliant	-70.992113	42.2182
604 UNION ST	rmp_1110	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	2.9	0.6	2.2	2	0.6	Compliant	-70.982517	42.21965
300 RIVER ST	rmp_1111	Fail	1	Good	Present	Good	Compliant	Compliant	3.9	1.6	0	4	1.4	Compliant	-70.985863	42.21808
218 MIDDLE ST	rmp_1112	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	6.2	1.8	1.3	1	0.4	Compliant	-70.993023	42.21815
169 RIVER ST	rmp_1113	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	4.3	2.3	5.5	1	4.4	Compliant	-70.995617	42.22026
184 MIDDLE ST	rmp_1114	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.3	0.3	0	0	2.6	Compliant	-70.994076	42.21818
170 RIVER ST	rmp_1115	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	1.4	0.1	2	2	3.3	Compliant	-70.995683	42.22045
208 MIDDLE ST	rmp_1116	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	6	1	2.9	4	0.3	Compliant	-70.993225	42.21816
126 MIDDLE ST	rmp_1117	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	6	2	3.5	2	3.6	Compliant	-70.995352	42.22028
54 HILLSIDE RD	rmp_1118	Fail	1	Good	Present	Good	Compliant	Compliant	1.1	1.2	0	0	3.7	Compliant	-70.985804	42.21802
340 COMMERCIAL ST	rmp_1119	Fail	2	Good	Present	Good	Compliant	Compliant	1.6	1.6	2.6	7	2.1	Compliant	-70.982593	42.22131
114 MIDDLE ST	rmp_1120	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3.5	2.8	2.3	3	1	Compliant	-70.995348	42.22049
4 CLEVELAND AV	rmp_1121	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3	1.6	0	0	0.2	Compliant	-70.994083	42.21801
4 EDWARDS RD	rmp_1122	Pass	0	Good	Present	Good	Compliant	Compliant	3.6	0.9	4.4	2	0.3	Compliant	-70.998722	42.23135
335 SHAW ST	rmp_1123	Fail	1	Good	Present	Good	Compliant	Compliant	3.5	1.3	0	0	1.6	Compliant	-70.977588	42.22949
95 HOWARD ST	rmp_1124	Fail	7	Poor	Not Present	Not Present	Compliant	Compliant	9.9	1.8	0.7	6	3.7	Not Compliant	-70.980129	42.23279
20 HAYWARD ST	rmp_1125	Pass	0	Good	Present	Good	Compliant	Compliant	4.3	0.4	2.7	2	1.9	Compliant	-70.987498	42.22832
444 QUINCY AV	rmp_1127	Pass	0	Good	Present	Good	Compliant	Compliant	2.6	0.5	0	0	1.6	Compliant	-70.977327	42.2343
379 SHAW ST	rmp_1128	Fail	3	Poor	Not Present	Not Present	Compliant	Compliant	3.3	1.9	0	0	1.1	Compliant	-70.978413	42.23101
379 SHAW ST	rmp_1129	Fail	3	Poor	Not Present	Not Present	Compliant	Compliant	3.3	1.9	0	0	1.1	Compliant	-70.978413	42.23101
597 COMMERCIAL ST	rmp_1130	Fail	2	Good	Present	Good	Compliant	Compliant	3.8	1.3	2.1	4	3.1	Compliant	-70.988811	42.22887
345 QUINCY AV	rmp_1131	Pass	0	Good	Present	Good	Compliant	Compliant	0.4	0.5	0	0	0.6	Compliant	-70.976285	42.23327
332 QUINCY AV	rmp_1132	Pass	0	Good	Present	Good	Compliant	Compliant	3.3	0.1	2.4	0	0.2	Compliant	-70.975256	42.23245
451 QUINCY AV	rmp_1133	Fail	1	Good	Present	Good	Compliant	Compliant	1.7	0.8	0	0	4.6	Compliant	-70.977798	42.23468
444 QUINCY AV	rmp_1134	Pass	0	Good	Present	Good	Compliant	Compliant	0.2	0.7	0	0	2	Compliant	-70.977536	42.23446
20 HAYWARD ST	rmp_1135	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	6.9	0.5	6.3	7	0.6	Compliant	-70.98603	42.22868
444 QUINCY AV	rmp_1136	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	3.4	1.1	4.1	2	1	Compliant	-70.979978	42.23308
17 SKYLINE DR	rmp_1137	Fail	3	Poor	Not Present	Not Present	Compliant	Compliant	7.2	0.3	2.7	6	1.2	Compliant	-70.980211	42.23304
410 QUINCY AV	rmp_1138	Fail	1	Good	Present	Good	Compliant	Compliant	0.7	0.5	0	0	3.5	Compliant	-70.976469	42.23343
6 ERICKSON ST	rmp_1139	Pass	0	Good	Present	Good	Compliant	Compliant	1.8	0.6	4.1	1	0.2	Compliant	-70.988977	42.22895
335 SHAW ST	rmp_1140	Fail	1	Good	Present	Good	Compliant	Compliant	2	0.3	1.1	4	5.7	Compliant	-70.977471	42.22951
40 SKYLINE DR	rmp_1141	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	5.8	1.5	6.3	4	1.8	Compliant	-70.98042	42.2343
290 HAYWARD ST	rmp_1142	Fail	1	Good	Present	Good	Compliant	Compliant	3.9	1.2	4.2	3	7.6	Compliant	-70.974137	42.23059
164 ELMLAWN RD	rmp_1143	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	0.8	2.6	0	0.9	Compliant	-70.997361	42.23088
238 HAYWARD ST	rmp_1144	Fail	1	Good	Present	Good	Compliant	Compliant	2.5	2.4	0.9	6	1	Compliant	-70.976363	42.22973
335 SHAW ST	rmp_1145	Pass	0	Good	Present	Good	Compliant	Compliant	3.5	1.2	0	0	0.3	Compliant	-70.977553	42.2295
20 HAYWARD ST	rmp_1146	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	5.8	1.9	0	5	0.2	Compliant	-70.985885	42.22871
194 HAYWARD ST	rmp_1147	Fail	1	Good	Present	Good	Compliant	Compliant	2.4	1	4.5	2	5.5	Compliant	-70.977746	42.22951
345 QUINCY AV	rmp_1148	Pass	0	Good	Present	Good	Compliant	Compliant	2.6	1	1	3	2.5	Compliant	-70.975089	42.23254
345 QUINCY AV	rmp_1149	Pass	0	Good	Present	Good	Compliant	Compliant	0.2	0	0	0	2.2	Compliant	-70.973286	42.23117
41 LORETTA AV	rmp_1150	Pass	0	Good	Present	Good	Compliant	Compliant	2.8	0.4	3.6	0	1.3	Compliant	-70.999964	42.23142
80 ROBERT ST	rmp_1151	Fail	1	Good	Present	Good	Compliant	Compliant	1.4	1.6	3	2	1.3	Compliant	-70.999446	42.23094
63 ROBERT ST	rmp_1152	Pass	0	Good	Present	Good	Compliant	Compliant	1.3	1	0.3	0	2.3	Compliant	-70.998971	42.23134
1 PANTANO ST	rmp_1153	Fail	2	Good	Present	Good	Compliant	Compliant	2.9	1.6	5.1	0	5.7	Compliant	-70.988319	42.22948
365 SHAW ST	rmp_1154	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	2.5	0.8	0	0	0.8	Compliant	-70.978015	42.23037
365 SHAW ST	rmp_1155	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	2.5	0.8	0	0	0.8	Compliant	-70.978015	42.23037
343 SHAW ST	rmp_1156	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	6.3	0.1	0	0	0.2	Compliant	-70.97788	42.23026
343 SHAW ST	rmp_1157	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	6.3	0.1	0	0	0.2	Compliant	-70.97788	42.23026
648 COMMERCIAL ST	rmp_1158	Pass	0	Good	Present	Good	Compliant	Compliant	1.1	0.4	0	0	1.4	Compliant	-70.991026	42.23002
156 ELMLAWN RD	rmp_1159	Pass	0	Good	Present	Good	Compliant	Compliant	2.7	0.8	3.7	1	0.5	Compliant	-70.997266	42.23079
10 SKYLINE DR	rmp_1160	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	6.9	0.1	5.5	5	0.3	Compliant	-70.980671	42.2326
20 HAYWARD ST	rmp_1161	Fail	1	Good	Present	Good	Compliant	Compliant	3.2	3.4	1	4	2.8	Compliant	-70.987394	42.22835
310 HAYWARD ST	rmp_1162	Fail	1	Good	Present	Good	Compliant	Compliant	0.6	0.6	5.8	6	0.4	Compliant	-70.973418	42.231
129 HOLMES ST	rmp_1163	Pass	0	Good	Present	Good	Compliant	Compliant	2.8	0.8	1.8	3	2.3	Compliant	-71.00005	42.23157
70 HAYWARD ST	rmp_1164	Fail	2	Good	Present	Good	Compliant	Compliant	1.7	2.3	0.3	6	0.1	Compliant	-70.984433	42.22906
17 SKYLINE DR	rmp_1165	Fail	4	Poor	Not Present	Not Present	Compliant	Not Compliant	6.2	0.9	4.1	5	2.7	Compliant	-70.980506	42.23282
4 PANTANO ST	rmp_1166	Fail	3	Good	Present	Good	Compliant	Compliant	1.5	3.8	7	2	3.3	Compliant	-70.988436	42.2294
62 HAYWARD ST	rmp_1167	Pass	0	Good	Present	Good	Compliant	Compliant	4.1	1.2	3.3	6	2.3	Compliant	-70.984598	42.22902
444 QUINCY AV	rmp_1168	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	6.3	1.5	1.7	4	0.8	Compliant	-70.980156	42.23398

**Braintree, MA - ADA Ramp Assessment  
2018**

650 COMMERCIAL ST	rmp_1169	Pass	0	Good	Present	Good	Compliant	Compliant	1.1	0	0	0	0.1	Compliant	-70.991141	42.23006	
149 HOLMES ST	rmp_1170	Pass	0	Good	Present	Good	Compliant	Compliant	3.4	0.4	1.5	2	2.5	Compliant	-70.999706	42.23095	
372 QUINCY AV	rmp_1171	Pass	0	Good	Present	Good	Compliant	Compliant	0.1	0.6	0	0	1.8	Compliant	-70.975458	42.23262	
387 SHAW ST	rmp_1172	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	3.6	0.3	0	0	0.2	Compliant	-70.978539	42.23114	
387 SHAW ST	rmp_1173	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	3.6	0.3	0	0	0.2	Compliant	-70.978539	42.23114	
150 HOLMES ST	rmp_1174	Pass	0	Good	Present	Good	Compliant	Compliant	4.6	1	0.7	4	1.5	Compliant	-70.999491	42.23105	
332 QUINCY AV	rmp_1175	Pass	0	Good	Present	Good	Compliant	Compliant	3.5	1.2	0.5	1	1.3	Compliant	-70.975256	42.23247	
335 SHAW ST	rmp_1176	Fail	2	Good	Present	Good	Compliant	Compliant	1.6	1.6	3.5	3	3	Compliant	-70.977424	42.22948	
20 HAYWARD ST	rmp_1177	Fail	1	Good	Present	Good	Compliant	Compliant	0.6	1.4	1.8	3	0.5	Compliant	-70.987409	42.22841	
3 EDWARDS RD	rmp_1178	Pass	0	Good	Present	Good	Compliant	Compliant	4.1	0.3	5.2	0	1.7	Compliant	-70.998863	42.23128	
300 HAYWARD ST	rmp_1179	Fail	1	Good	Present	Good	Compliant	Compliant	2.9	1	1.8	2	4.7	Compliant	-70.973982	42.23068	
20 HAYWARD ST	rmp_1180	Pass	0	Good	Present	Good	Compliant	Compliant	0.3	0.8	0	0	0.3	Compliant	-70.987203	42.22837	
20 HAYWARD ST	rmp_1181	Pass	0	Good	Present	Good	Compliant	Compliant	4.1	0.6	4.5	2	1.4	Compliant	-70.987778	42.22836	
152 HAYWARD ST	rmp_1182	Pass	0	Good	Present	Good	Compliant	Compliant	2	1.1	5.1	2	2.1	Compliant	-70.980241	42.22957	
141 ALLEN ST	rmp_1183	Fail	5	Good	Not Present	Not Present	Compliant	Not Compliant	7.4	4.6	7.4	2	1.1	Compliant	-70.975397	42.22255	
149 ALLEN ST	rmp_1184	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	6.6	0.3	2.4	6	0.5	Compliant	-70.975508	42.22225	
19 SHAW ST	rmp_1185	Pass	0	Good	Present	Good	Compliant	Compliant	0.3	0.5	0.6	2	1.6	Compliant	-70.971267	42.22178	
19 SHAW ST	rmp_1186	Pass	0	Good	Present	Good	Compliant	Compliant	0.1	1.2	4.1	4	2.8	Compliant	-70.971079	42.22171	
253 COMMERCIAL ST	rmp_1187	Pass	0	Good	Present	Good	Compliant	Compliant	4	0.2	4.5	2	1.1	Compliant	-70.979015	42.22137	
214 SHAW ST	rmp_1188	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	1	1.3	8	10	0.2	Compliant	-70.975739	42.22608	Not a ramp.
265 COMMERCIAL ST	rmp_1189	Pass	0	Good	Present	Good	Compliant	Compliant	1.1	0.9	1.2	4	0.7	Compliant	-70.979238	42.22142	
324 SHAW ST	rmp_1190	Fail	1	Good	Present	Good	Compliant	Compliant	2.5	0.7	0.3	3	7.8	Compliant	-70.977623	42.22926	
6 HILLCREST RD	rmp_1191	Fail	1	Good	Present	Good	Compliant	Compliant	2.2	0.2	1.2	1	6.5	Compliant	-70.979148	42.22933	
6 FAIRMOUNT AV	rmp_1192	Fail	3	Good	Present	Good	Compliant	Compliant	3.7	2.1	0.5	7	5.5	Compliant	-70.978363	42.22926	
22 SOMERVILLE AV	rmp_1193	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	4.2	6.8	7.2	6	0.5	Compliant	-70.976453	42.22778	
226 SHAW ST	rmp_1194	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	5.8	1.2	0.5	4	0.2	Compliant	-70.975911	42.22646	
324 SHAW ST	rmp_1195	Fail	1	Good	Present	Good	Compliant	Compliant	2.4	0.7	0.7	4	6.3	Compliant	-70.977553	42.22924	
185 HAYWARD ST	rmp_1196	Fail	1	Good	Present	Good	Compliant	Compliant	4.7	0.8	2.8	3	3.4	Compliant	-70.978578	42.22927	
171 HAYWARD ST	rmp_1197	Fail	1	Good	Present	Good	Compliant	Compliant	2.4	0.2	0.6	4	9.6	Compliant	-70.979332	42.22933	
218 SHAW ST	rmp_1198	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	2.4	0	3	4	1.6	Compliant	-70.975881	42.22634	
332 COMMERCIAL ST	rmp_1199	Pass	0	Good	Present	Good	Compliant	Compliant	1.2	1.2	0	6	1.5	Compliant	-70.98216	42.22129	
141 HOBART ST	rmp_1200	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	4.7	0.5	4.4	0	6.1	Compliant	-70.979063	42.22702	
99 HOBART ST	rmp_1201	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	1.4	0.6	6.7	5	1.9	Compliant	-70.97909	42.22582	
32 ORCHARD ST	rmp_1202	Fail	5	Poor	Not Present	Not Present	Not Compliant	Not Compliant	0	0	0	0	0	Not Compliant	-70.97719	42.22689	not a ramp
114 HOBART ST	rmp_1203	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	2.4	1.9	3.4	7	3.9	Compliant	-70.9792	42.22596	
117 HOBART ST	rmp_1204	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	5	0.1	4.9	6	1.2	Compliant	-70.978723	42.22628	
31 ORCHARD ST	rmp_1205	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	1	1.2	0	13	0.3	Compliant	-70.97718	42.22677	
328 COMMERCIAL ST	rmp_1206	Pass	0	Fair	Present	Good	Compliant	Compliant	0.3	0.9	1.2	0	1.8	Compliant	-70.982014	42.22129	
125 HOBART ST	rmp_1207	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	1.2	1.9	7.3	2	5.8	Compliant	-70.978799	42.22642	
269 SHAW ST	rmp_1208	Fail	4	Poor	Not Present	Not Present	Compliant	Not Compliant	1	0.4	0.3	9	1.2	Compliant	-70.976547	42.22819	
20 HERITAGE LN	rmp_1209	Pass	0	Good	Present	Good	Compliant	Compliant	0.2	1	0	0	0.9	Compliant	-70.97655	42.22954	
20 HERITAGE LN	rmp_1210	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	5.4	2.4	3.6	5	0.5	Compliant	-70.974425	42.22899	
297 QUINCY AV	rmp_1211	Fail	2	Good	Present	Good	Compliant	Compliant	4.4	0.7	0.7	4	3.9	Not Compliant	-70.973056	42.2231	
20 HERITAGE LN	rmp_1212	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	4.6	0.3	5.2	6	0.7	Compliant	-70.975108	42.22926	
20 HERITAGE LN	rmp_1213	Fail	3	Fair	Present	Good	Compliant	Compliant	3.6	2.6	6.7	1	6.4	Compliant	-70.976272	42.22959	
20 HERITAGE LN	rmp_1214	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	4.3	0.1	4.2	4	2.5	Compliant	-70.973658	42.22901	
297 QUINCY AV	rmp_1215	Pass	0	Good	Present	Good	Compliant	Compliant	3.9	0.3	0	0	0.5	Compliant	-70.972773	42.23075	
227 HAYWARD ST	rmp_1216	Fail	1	Good	Present	Good	Compliant	Compliant	2.5	0.3	1.6	3	7.3	Compliant	-70.977273	42.22931	
286 QUINCY AV	rmp_1217	Fail	1	Good	Present	Good	Compliant	Compliant	3.8	0.5	4.1	4	3.8	Compliant	-70.973241	42.23083	
219 SHAW ST	rmp_1218	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	5.5	1.3	3.2	2	0.8	Compliant	-70.975634	42.22622	
20 HERITAGE LN	rmp_1219	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.8	0.4	4.8	4	1.3	Compliant	-70.974487	42.22882	
215 SHAW ST	rmp_1220	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	6.7	1.1	1	6	2.4	Compliant	-70.975591	42.22609	
20 HERITAGE LN	rmp_1221	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	4.6	1.7	6.5	2	0.5	Compliant	-70.976348	42.22912	
20 HERITAGE LN	rmp_1222	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	5	1.3	5.2	6	0.2	Compliant	-70.973799	42.22891	
20 HERITAGE LN	rmp_1223	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	5	0.9	4.6	4	0	Compliant	-70.97274	42.22928	
289 QUINCY AV	rmp_1224	Pass	0	Good	Present	Good	Compliant	Compliant	0.6	0.5	0	0	1.3	Compliant	-70.972637	42.23067	
286 QUINCY AV	rmp_1225	Pass	0	Good	Present	Good	Compliant	Compliant	4.2	0.4	3.2	2	2.9	Compliant	-70.973306	42.23082	
259 SHAW ST	rmp_1226	Fail	4	Poor	Not Present	Not Present	Compliant	Compliant	9.2	0.3	0	2	4.3	Compliant	-70.976248	42.22777	
20 HERITAGE LN	rmp_1227	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	8	0.5	0	0	5.7	Compliant	-70.975305	42.22906	
299 QUINCY AV	rmp_1228	Fail	1	Good	Present	Good	Compliant	Compliant	3.8	1.6	0	0	2.3	Compliant	-70.973061	42.23105	
20 HERITAGE LN	rmp_1229	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4.6	1.7	1	4	0	Compliant	-70.97435	42.22877	
20 HERITAGE LN	rmp_1230	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	4.8	2.2	2.2	7	1.8	Compliant	-70.974266	42.22895	
20 HERITAGE LN	rmp_1231	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	4.8	0.6	0	0	0.7	Compliant	-70.973345	42.22891	
20 HERITAGE LN	rmp_1232	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	0.2	0.2	0	0	0.9	Compliant	-70.976252	42.22895	
20 HERITAGE LN	rmp_1233	Fail	3	Fair	Present	Good	Compliant	Compliant	5.6	1.6	0	0	6.8	Compliant	-70.976298	42.22958	

**Braintree, MA - ADA Ramp Assessment  
2018**

20 HERITAGE LN	rmp_1234	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	4.8	0.2	6	5	2.8	Compliant	-70.973034	42.22911
20 HERITAGE LN	rmp_1235	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	5.5	0.8	4.6	4	0.1	Compliant	-70.973636	42.22877
130 QUINCY AV	rmp_1236	Fail	2	Good	Present	Fair	Compliant	Compliant	4.2	1.5	0	0	3.8	Compliant	-70.969356	42.22558
23 CEDAR ST	rmp_1237	Pass	0	Good	Present	Good	Compliant	Compliant	4.1	0.5	3.7	1	0.8	Compliant	-70.998606	42.22484
274 ELM ST	rmp_1238	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	1	0.9	4.7	4	0.3	Compliant	-70.99774	42.22409
76 SCHOOL ST	rmp_1239	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	0.9	0.1	3.4	2	1.5	Compliant	-71.002487	42.22444
13 PLEASANT ST	rmp_1240	Pass	0	Good	Present	Fair	Compliant	Compliant	2.7	0.3	0	0	1.3	Compliant	-71.002955	42.22532
97 CHURCH ST	rmp_1241	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	1.1	0.2	1.4	3	2.1	Compliant	-71.00301	42.22539
17 PLEASANT ST	rmp_1242	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	1.2	0	0	0	1.6	Compliant	-71.002671	42.22544
80 INDEPENDENCE AV	rmp_1243	Pass	0	Good	Present	Good	Compliant	Compliant	1.1	0	1.8	4	0.5	Compliant	-71.004055	42.22694
178 WASHINGTON ST	rmp_1244	Fail	1	Good	Present	Good	Compliant	Compliant	4.7	1.1	6.1	6	1	Compliant	-71.004418	42.22672
80 INDEPENDENCE AV	rmp_1245	Fail	1	Good	Present	Good	Compliant	Compliant	2.2	0.4	1.2	3	3.6	Compliant	-71.004299	42.22695
178 WASHINGTON ST	rmp_1246	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	0.8	0.7	0	0	0.8	Compliant	-71.003945	42.22663
178 WASHINGTON ST	rmp_1247	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	0.7	1.3	0	0	0.2	Compliant	-71.003856	42.22624
96 CHURCH ST	rmp_1248	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	1.9	1.4	0	0	0.5	Compliant	-71.003493	42.22576
80 INDEPENDENCE AV	rmp_1249	Fail	1	Good	Present	Good	Compliant	Compliant	3.8	0.4	4.4	6	5.5	Compliant	-71.004156	42.22694
96 CHURCH ST	rmp_1250	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	0.8	0.1	0	0	1.4	Compliant	-71.003569	42.22584
7 WALNUT ST	rmp_1251	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	7	1.4	2.6	3	5.3	Compliant	-71.012248	42.21548
139 HOLLIS AV	rmp_1252	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	4	1.6	3.8	2	1.8	Compliant	-71.009495	42.21679
452 ELM ST	rmp_1253	Fail	3	Good	Present	Good	Compliant	Compliant	2.7	4.1	7.5	5	3.8	Compliant	-70.991219	42.22698
434 ELM ST	rmp_1254	Fail	1	Good	Present	Good	Compliant	Compliant	3.9	0.1	1.8	3	5.6	Compliant	-70.991387	42.22691
25 ADAMS ST	rmp_1255	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	0	2.1	0	6	0.2	Compliant	-70.996503	42.22483
25 ADAMS ST	rmp_1256	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1	0.4	4	0	2	Compliant	-70.996396	42.22486
98 CEDAR ST	rmp_1257	Fail	1	Good	Present	Good	Compliant	Compliant	0.9	1.3	3.4	4	1.1	Compliant	-71.000796	42.22668
140 SCHOOL ST	rmp_1258	Pass	0	Good	Present	Good	Compliant	Compliant	4.7	0.2	4.3	4	1.6	Compliant	-71.000053	42.22603
108 CEDAR ST	rmp_1259	Pass	0	Good	Present	Good	Compliant	Compliant	2.9	1	3.4	5	0.1	Compliant	-71.000918	42.22677
587 WASHINGTON ST	rmp_1260	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.3	0.3	2.1	0	2.2	Compliant	-71.004674	42.21283
220 FORBES RD	rmp_1261	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	2.4	1.3	0	0	0.7	Compliant	-71.035651	42.21959
745 WASHINGTON ST	rmp_1262	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.9	0.1	2.7	4	1	Compliant	-71.004016	42.20745
392 FRANKLIN ST	rmp_1263	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	3	1.4	0.9	4	1.1	Compliant	-71.019578	42.21167
551 GRANITE ST	rmp_1264	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	1.9	0.3	4.7	3	1.8	Compliant	-71.01983	42.21179
551 GRANITE ST	rmp_1265	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	1.4	3.7	3.2	6	0.7	Compliant	-71.019925	42.21191
551 GRANITE ST	rmp_1266	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	5.2	2.3	6.6	3	0.1	Compliant	-71.019828	42.21163
969 WASHINGTON ST	rmp_1267	Pass	0	Good	Present	Good	Compliant	Compliant	4.4	0.5	0	0	2.3	Compliant	-71.005928	42.20223
29 ELMWOOD AV	rmp_1268	Pass	0	Good	Present	Good	Compliant	Compliant	3	0.5	1.8	4	1.1	Compliant	-71.011035	42.22085
30 ELMWOOD AV	rmp_1269	Pass	0	Good	Present	Good	Compliant	Compliant	2.4	0.6	4.2	2	2.7	Compliant	-71.011059	42.20835
20 GRANITE ST	rmp_1270	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	1.1	3.3	1	5	6.6	Compliant	-71.031162	42.22704
773 WASHINGTON ST	rmp_1271	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.3	0.4	2.6	3	0.5	Compliant	-71.004354	42.20693
287 GRANITE ST	rmp_1272	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	8.5	0.4	6.9	10	1.5	Compliant	-71.027126	42.21944
149 HANCOCK ST	rmp_1273	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3.6	1.4	3.9	4	1	Compliant	-71.005223	42.19778
1060 WASHINGTON ST	rmp_1274	Pass	0	Good	Present	Good	Compliant	Compliant	0.7	0.7	4.1	1	2	Compliant	-71.007336	42.19993
382 COMMERCIAL ST	rmp_1275	Pass	0	Good	Present	Good	Compliant	Compliant	2.1	0.5	3	4	2.4	Compliant	-70.983617	42.22237
364 COMMERCIAL ST	rmp_1276	Pass	0	Good	Present	Good	Compliant	Compliant	1.5	0.2	4	3	0.6	Compliant	-70.983343	42.22202
387 COMMERCIAL ST	rmp_1277	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	6.5	3.1	8.9	1	0.7	Compliant	-70.983699	42.22278
382 COMMERCIAL ST	rmp_1278	Fail	1	Good	Present	Good	Compliant	Compliant	1.3	1.5	3.8	4	2.3	Compliant	-70.983571	42.22236
385 COMMERCIAL ST	rmp_1279	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	1.3	2.9	0.2	4	4.5	Compliant	-70.983615	42.22265
364 COMMERCIAL ST	rmp_1280	Fail	1	Good	Present	Good	Compliant	Compliant	3.4	1.9	4.1	4	2.1	Compliant	-70.983421	42.22218
437 COMMERCIAL ST	rmp_1281	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	2	0.1	1.7	2	2.3	Compliant	-70.985611	42.22473
625 UNION ST	rmp_1282	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	3.8	0.1	2.4	3	1.5	Compliant	-70.982427	42.2197
8 BEECHWOOD RD	rmp_1283	Fail	1	Good	Present	Good	Compliant	Compliant	3.3	0.6	3.2	2	4	Compliant	-70.969243	42.22637
2089 WASHINGTON ST	rmp_1284	Pass	0	Good	Present	Good	Compliant	Compliant	1.6	0.2	1.6	2	1.8	Compliant	-71.00842	42.16999
1969 WASHINGTON ST	rmp_1285	Pass	0	Good	Present	Good	Compliant	Compliant	4.6	0.3	3.3	4	1	Compliant	-71.011651	42.17358
141 ALIDA RD	rmp_1286	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	1	1.6	8.9	3	0.3	Compliant	-70.999334	42.18908
247 RIVER ST	rmp_1287	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	4.4	4	2.3	6	1.2	Compliant	-70.992424	42.22056
247 RIVER ST	rmp_1288	Fail	2	Poor	Not Present	Not Present	Compliant	Compliant	4.6	0	4.4	5	0	Compliant	-70.992325	42.22058
248 RIVER ST	rmp_1289	Fail	2	Poor	Not Present	Not Present	Compliant	Compliant	2.2	0.5	4.8	4	1.5	Compliant	-70.992325	42.22076
233 RIVER ST	rmp_1290	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	4.7	1.9	5.8	3	1.3	Compliant	-70.992611	42.22056
165 ELMWOOD RD	rmp_1291	Fail	1	Good	Present	Fair	Compliant	Compliant	3	0.6	1.3	3	3.2	Compliant	-70.997215	42.23097
1024 LIBERTY ST	rmp_1292	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	4.6	5.1	2.2	9	1.4	Compliant	-70.987621	42.18812
100 GROSSMAN DR	rmp_1293	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	9.9	0.2	3.7	4	1.3	Compliant	-70.99936	42.211
100 GROSSMAN DR	rmp_1294	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	7.2	1.5	3	4	1.5	Compliant	-70.999433	42.21081
142 UNION ST	rmp_1295	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	2.5	1.8	2.6	6	1.8	Compliant	-70.99915	42.21079
108 UNION ST	rmp_1296	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	8.3	0.4	5.1	5	0.7	Compliant	-71.000327	42.20927
108 UNION ST	rmp_1297	Fail	5	Poor	Not Present	Not Present	Compliant	Not Compliant	3.3	3.2	0.2	7	1.8	Compliant	-70.999965	42.20931
180 PEARL ST	rmp_1298	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	7.8	1	8.2	6	2	Compliant	-70.999778	42.20494

**Braintree, MA - ADA Ramp Assessment  
2018**

4 8 FRENCH AV	rmp_1299	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	4	0.1	1.9	4	1	Compliant	-71.002784	42.20277
4 8 FRENCH AV	rmp_1300	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	4.5	1.1	3.2	2	1.1	Compliant	-71.002827	42.20347
4 8 FRENCH AV	rmp_1301	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	1.2	0	0	4	1.8	Compliant	-71.002727	42.20328
145 PEARL ST	rmp_1302	Pass	0	Good	Present	Poor	Compliant	Not Compliant	1.4	0.4	1.6	1	0.8	Compliant	-70.998289	42.20051
107 PLAIN ST	rmp_1303	Pass	0	Good	Present	Good	Compliant	Compliant	0.6	0.3	0.7	2	2.7	Compliant	-70.999696	42.19648
250 GRANITE ST	rmp_1304	Pass	0	Good	Present	Good	Compliant	Compliant	4.5	0.4	2.2	0	0.9	Compliant	-71.021943	42.21493
50 FORBES RD	rmp_1305	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	3.4	0.6	1	5	3.2	Compliant	-71.029523	42.22187
150 GRANITE ST	rmp_1306	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	3.6	0.2	2.5	2	2.5	Compliant	-71.031727	42.22366
150 GRANITE ST	rmp_1307	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	3.3	1	1.4	2	4.6	Compliant	-71.031665	42.22372
95 HOWARD ST	rmp_1308	Fail	5	Good	Not Present	Not Present	Compliant	Not Compliant	5.8	1.6	6.1	2	0.8	Compliant	-70.980121	42.23286
269 PEACH ST	rmp_1309	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	4.6	0.2	3.5	3	0.5	Compliant	-70.99637	42.18326
250 GRANITE ST	rmp_1310	Fail	1	Good	Present	Good	Compliant	Compliant	5.1	0.7	3.5	2	2	Compliant	-71.021774	42.21462
50 FORBES RD	rmp_1311	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	4.4	1.3	5.7	3	3	Compliant	-71.029639	42.22185
50 FORBES RD	rmp_1312	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	6.1	0.9	3.8	4	4	Compliant	-71.029843	42.22188
50 FORBES RD	rmp_1313	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	2.1	0.6	1.9	4	1.7	Compliant	-71.029772	42.22194
50 FORBES RD	rmp_1314	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	4.3	0.7	3.7	3	2.1	Compliant	-71.029876	42.22178
50 FORBES RD	rmp_1315	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	3.2	2.5	7.1	2	2.2	Compliant	-71.029974	42.22169
50 FORBES RD	rmp_1316	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	5.6	1	2.2	5	1.7	Compliant	-71.030112	42.22178
50 FORBES RD	rmp_1317	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	4.6	0.4	3.8	5	1.4	Compliant	-71.030334	42.22198
50 FORBES RD	rmp_1318	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	3.1	0.6	2.2	4	3.8	Compliant	-71.030439	42.22198
150 GRANITE ST	rmp_1319	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	3.7	2.7	4.3	1	0.9	Compliant	-71.031387	42.22404
150 GRANITE ST	rmp_1320	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	2.6	0.3	2.3	3	1.3	Compliant	-71.031719	42.22391
565 GRANITE ST	rmp_1321	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	5	2.7	0	0	2.5	Compliant	-71.019854	42.21153
43 SOUTH ST	rmp_1322	Fail	2	Poor	Not Present	Not Present	Compliant	Compliant	1.5	0.3	2.6	4	2.4	Compliant	-71.013569	42.17379
7 POULOS RD	rmp_1323	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	7.5	0.4	5.2	0	7.9	Compliant	-70.984789	42.19716
245 GROVE ST	rmp_1324	Pass	0	Good	Present	Good	Compliant	Compliant	0.7	0.1	3.4	3	1.3	Compliant	-70.989657	42.19146
1890 WASHINGTON ST	rmp_1325	Pass	0	Good	Present	Good	Compliant	Compliant	0.2	0.9	1.2	2	0.2	Compliant	-71.013275	42.17569
1891 WASHINGTON ST	rmp_1326	Pass	0	Good	Present	Good	Compliant	Compliant	2.1	0.3	1.3	4	0.7	Compliant	-71.013401	42.17566
6 LINDA RD	rmp_1327	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	1.2	1.2	4	0.7	Compliant	-71.005049	42.18834
250 GRANITE ST	rmp_1328	Fail	2	Poor	Present	Good	Compliant	Compliant	2.1	1.8	0	0	1.1	Compliant	-71.021782	42.21467
509 LIBERTY ST	rmp_1329	Pass	0	Good	Present	Poor	Compliant	Compliant	1.2	0.1	3.2	3	1.1	Compliant	-70.984578	42.20415
509 LIBERTY ST	rmp_1330	Pass	0	Good	Present	Good	Compliant	Compliant	0.5	0.4	3.5	4	0.5	Compliant	-70.984499	42.20407
98 STETSON ST	rmp_1331	Pass	0	Good	Present	Good	Compliant	Compliant	1.2	0.9	1.6	5	2.4	Compliant	-70.973948	42.21744
5 CLAREMONT ST	rmp_1332	Fail	2	Good	Present	Good	Compliant	Compliant	3.2	2.7	8.2	3	2.2	Compliant	-70.978461	42.21697
51 COMMERCIAL ST	rmp_1333	Fail	1	Good	Present	Good	Compliant	Compliant	3	0.6	3.3	2	3.7	Compliant	-70.969903	42.22094
98 STETSON ST	rmp_1334	Fail	1	Good	Present	Good	Compliant	Compliant	1.4	2.9	0	0	1.8	Compliant	-70.973988	42.21741
94 LIBERTY ST	rmp_1335	Fail	2	Good	Present	Good	Compliant	Compliant	3.6	4.5	0.7	10	0.3	Compliant	-70.978433	42.21706
51 COMMERCIAL ST	rmp_1336	Fail	3	Good	Present	Good	Compliant	Compliant	2.9	1.3	6.3	6	0	Compliant	-70.97019	42.22091
109 BELLEVUE RD	rmp_1337	Fail	2	Good	Present	Good	Compliant	Compliant	0.8	5.2	0.9	9	1.7	Compliant	-70.973271	42.21717
3 LINCOLN ST	rmp_1338	Fail	2	Good	Present	Good	Compliant	Compliant	2	1.3	6.2	2	1	Compliant	-70.978744	42.21594
509 LIBERTY ST	rmp_1339	Pass	0	Good	Present	Good	Compliant	Compliant	0.2	0.7	3.6	4	2.5	Compliant	-70.984867	42.20424
128 STETSON ST	rmp_1340	Fail	3	Good	Present	Good	Compliant	Compliant	6.9	1.1	7.3	0	3.5	Compliant	-70.972565	42.21661
139 STETSON ST	rmp_1341	Pass	0	Good	Present	Good	Compliant	Compliant	2.3	0.3	4	0	1.7	Compliant	-70.972344	42.21645
74 COMMERCIAL ST	rmp_1342	Pass	0	Good	Present	Good	Compliant	Compliant	3.6	0.8	0.7	5	1	Compliant	-70.970765	42.22061
85 STERLING ST	rmp_1343	Fail	3	Fair	Present	Good	Compliant	Compliant	0.8	3.7	7.6	0	5	Compliant	-70.971856	42.21516
86 STERLING ST	rmp_1344	Fail	3	Poor	Present	Good	Compliant	Compliant	0.5	2.3	1	1	3.4	Compliant	-70.971874	42.21498
98 COMMERCIAL ST	rmp_1345	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	8.6	7.3	0.2	9	1	Compliant	-70.972202	42.22094
118 COMMERCIAL ST	rmp_1346	Fail	7	Poor	Not Present	Not Present	Compliant	Not Compliant	6.2	3.5	7	5	8.4	Compliant	-70.972393	42.221
5 PEARL PL	rmp_1347	Pass	0	Good	Present	Good	Compliant	Compliant	0.1	0.1	5.5	4	0.7	Compliant	-70.985069	42.20427
5 CANAL ST	rmp_1348	Fail	5	Poor	Not Present	Not Present	Compliant	Not Compliant	6.3	0.8	3.9	6	0.9	Compliant	-71.014725	42.20031
392 FRANKLIN ST	rmp_1349	Fail	1	Good	Present	Poor	Compliant	Not Compliant	0.5	0.5	0	0	0.4	Compliant	-71.019988	42.21034
550 LIBERTY ST	rmp_1350	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	0.8	1.1	4.8	0	2.4	Compliant	-70.976386	42.19965
8 WILLARD ST	rmp_1351	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	5	1.1	1.3	8	2.3	Compliant	-70.976618	42.21799
115 COMMERCIAL ST	rmp_1352	Fail	3	Poor	Not Present	Not Present	Compliant	Not Compliant	2.5	0.5	0.9	2	2.8	Compliant	-70.97215	42.22108
42 STETSON ST	rmp_1353	Fail	3	Good	Present	Good	Compliant	Compliant	2.7	6.7	11	5	5.2	Compliant	-70.976185	42.21804
46 LINCOLN ST	rmp_1354	Fail	1	Good	Present	Good	Compliant	Compliant	1	0.5	2.4	3	3.7	Compliant	-70.976419	42.21676
4 TOMPSON RD	rmp_1355	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	4.4	1.7	6.1	0	2.8	Compliant	-70.972386	42.22113
76 FAXON ST	rmp_1356	Fail	2	Good	Present	Good	Compliant	Compliant	0.9	2.1	0.6	3	5.7	Compliant	-70.976064	42.21801
43 CLAREMONT ST	rmp_1357	Fail	5	Poor	Present	Good	Compliant	Not Compliant	0.9	6	5.8	0	0.1	Not Compliant	-70.976479	42.21668
5 PEARL PL	rmp_1358	Pass	0	Good	Present	Good	Compliant	Compliant	0.3	0.5	1.1	5	0.5	Compliant	-70.985248	42.20408
112 BELLEVUE RD	rmp_1359	Fail	4	Fair	Present	Good	Compliant	Not Compliant	5.2	7	5.2	2	4	Compliant	-70.973137	42.21707
4 LINCOLN ST	rmp_1360	Fail	2	Fair	Present	Good	Compliant	Compliant	1.7	4.7	0.1	8	1.3	Compliant	-70.978796	42.21609
5 PEARL PL	rmp_1361	Fail	1	Good	Present	Good	Compliant	Compliant	1.4	1.6	4	2	0.6	Compliant	-70.985238	42.20395
67 ELLIOT ST	rmp_1362	Fail	3	Good	Present	Good	Compliant	Compliant	0.8	4.5	0.8	13	5.1	Compliant	-70.971889	42.2161
198 LIBERTY ST	rmp_1363	Fail	3	Good	Present	Good	Compliant	Not Compliant	2.4	1.3	4.4	4	4.3	Compliant	-70.979502	42.21373

landing compliant because of flares

**Braintree, MA - ADA Ramp Assessment  
2018**

16 PRESCOTT LN	rmp_1364	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	6.3	0.6	4.8	5	1.2	Compliant	-70.97311	42.22102
70 ELLIOT ST	rmp_1365	Fail	2	Good	Present	Good	Compliant	Compliant	2.5	1.6	0	0	3	Compliant	-70.971773	42.21599
208 LIBERTY ST	rmp_1366	Fail	4	Poor	Present	Good	Compliant	Not Compliant	4.7	0.6	3	4	4.4	Not Compliant	-70.979599	42.21357
7 PRESCOTT LN	rmp_1367	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	0.2	3.1	8.8	1	0.8	Not Compliant	-70.973261	42.22103
522 LIBERTY ST	rmp_1368	Pass	0	Good	Present	Good	Compliant	Compliant	1	0.5	4.3	2	0.1	Compliant	-70.984981	42.20372
169 COMMERCIAL ST	rmp_1369	Fail	5	Good	Not Present	Not Present	Compliant	Not Compliant	4.1	4.4	5.1	9	4.3	Compliant	-70.974643	42.22093
2 ELM KNOLL RD	rmp_1370	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	5.4	1.6	7.3	2	2.8	Compliant	-70.974138	42.22091
90 WALNUT AV	rmp_1371	Fail	5	Poor	Not Present	Not Present	Not Compliant	Not Compliant	0	0	0	0	0	Not Compliant	-70.971956	42.21439
550 LIBERTY ST	rmp_1372	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	0.6	0.5	2	4	0.5	Compliant	-70.976296	42.19962
268 LIBERTY ST	rmp_1373	Fail	1	Fair	Present	Poor	Compliant	Compliant	1.4	2.8	0.1	4	0.5	Compliant	-70.980709	42.21166
7 ELM KNOLL RD	rmp_1374	Fail	5	Poor	Not Present	Not Present	Compliant	Not Compliant	3.2	5.5	9.5	2	1.4	Compliant	-70.974304	42.22088
285 LIBERTY ST	rmp_1375	Pass	0	Good	Present	Good	Compliant	Compliant	2.1	1	0.9	4	1.5	Compliant	-70.981128	42.21097
309 LIBERTY ST	rmp_1376	Fail	1	Good	Present	Good	Compliant	Compliant	4.3	2	3.2	4	1	Compliant	-70.981074	42.21029
550 MIDDLE ST	rmp_1377	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	0.6	3.2	4.6	2	0	Compliant	-70.986342	42.20839
72 BROOKSIDE RD	rmp_1378	Fail	1	Good	Present	Good	Compliant	Compliant	0.7	1	0	4	3.6	Compliant	-70.970777	42.21831
69 BROOKSIDE RD	rmp_1379	Fail	2	Good	Present	Good	Compliant	Compliant	1.6	1.4	0	2	3.9	Compliant	-70.970884	42.21834
6 COMMERCIAL ST	rmp_1380	Pass	0	Good	Present	Good	Compliant	Compliant	3.4	0.6	4	3	0.1	Compliant	-70.968815	42.21998
6 COMMERCIAL ST	rmp_1381	Pass	0	Fair	Present	Good	Compliant	Compliant	2.5	0.6	1.3	3	1.4	Compliant	-70.968797	42.22001
540 MIDDLE ST	rmp_1382	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	3	3.1	5.8	1	2.1	Compliant	-70.986329	42.20851
8 BROOKSIDE RD	rmp_1383	Pass	0	Good	Present	Good	Compliant	Compliant	3.4	0.1	4.7	2	2.3	Compliant	-70.968065	42.21941
169 COMMERCIAL ST	rmp_1384	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	4	0.3	4.5	2	5.2	Compliant	-70.974792	42.22091
44 COMMERCIAL ST	rmp_1385	Pass	0	Good	Present	Good	Compliant	Compliant	3.9	0.5	0.5	5	0.8	Compliant	-70.96955	42.22059
28 COMMERCIAL ST	rmp_1386	Fail	1	Good	Present	Good	Compliant	Compliant	4.3	0.8	8.3	0	0.6	Compliant	-70.969432	42.22066
15 ANDREA DR	rmp_1387	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	1.5	1.7	0.2	6	1.1	Compliant	-70.985654	42.2084
25 COMMERCIAL ST	rmp_1388	Fail	2	Good	Present	Good	Compliant	Compliant	4.9	0.4	0	6	0.1	Compliant	-70.969271	42.22067
25 COMMERCIAL ST	rmp_1389	Pass	0	Good	Present	Good	Compliant	Compliant	1.3	0.1	0.7	2	1.8	Compliant	-70.969082	42.22107
39 TREFTON DR	rmp_1390	Fail	2	Poor	Not Present	Not Present	Compliant	Compliant	2.1	0.7	0	0	0	Compliant	-70.969147	42.22977
29 QUINCY AV	rmp_1391	Fail	2	Good	Present	Good	Compliant	Not Compliant	2	1.8	0	4	2	Compliant	-70.968933	42.22194
470 LIBERTY ST	rmp_1392	Pass	0	Good	Present	Good	Compliant	Compliant	1.7	1	4.1	1	1.8	Compliant	-70.982617	42.20517
55 CHERRY LN	rmp_1393	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	0.1	0.3	2	1.2	Compliant	-70.987149	42.20222
95 HOWARD ST	rmp_1394	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	5.4	1.7	4.7	1	0.7	Compliant	-70.980101	42.23282
32 DORIS RD	rmp_1395	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	1.2	1.3	0	4	4	Compliant	-70.985385	42.20841
89 WALNUT AV	rmp_1396	Fail	5	Poor	Not Present	Not Present	Compliant	Not Compliant	2.8	2.3	0	0	0.6	Not Compliant	-70.97191	42.21453
522 LIBERTY ST	rmp_1397	Pass	0	Good	Present	Good	Compliant	Compliant	1	0.9	3.3	4	0.9	Compliant	-70.98482	42.20373
258 LIBERTY ST	rmp_1398	Fail	1	Good	Present	Poor	Compliant	Compliant	1.5	1.5	3.5	1	2.5	Compliant	-70.980701	42.21175
258 LIBERTY ST	rmp_1399	Fail	1	Good	Present	Poor	Compliant	Compliant	1.5	1.5	3.5	1	2.5	Compliant	-70.980701	42.21175
509 LIBERTY ST	rmp_1400	Pass	0	Good	Present	Good	Compliant	Compliant	0	0.7	0	0	0	Compliant	-70.98495	42.20425
301 LIBERTY ST	rmp_1401	Fail	2	Good	Present	Good	Compliant	Compliant	2	2.7	2.4	0	3.2	Compliant	-70.981136	42.2109
313 LIBERTY ST	rmp_1402	Fail	3	Good	Present	Poor	Compliant	Not Compliant	2.1	2.9	3.7	5	5.2	Compliant	-70.981044	42.21017
1 COMMERCIAL ST	rmp_1403	Pass	0	Good	Present	Good	Compliant	Compliant	2.8	0.2	2.5	0	0.4	Compliant	-70.968601	42.2201
550 LIBERTY ST	rmp_1404	Fail	1	Good	Present	Good	Compliant	Compliant	1.9	1.5	2.9	3	1.8	Compliant	-70.984355	42.20252
6 BROOKSIDE RD	rmp_1405	Pass	0	Good	Present	Good	Compliant	Compliant	2.5	0	0.1	2	0.9	Compliant	-70.968708	42.21988
350 LIBERTY ST	rmp_1406	Pass	0	Good	Present	Good	Compliant	Compliant	1.8	1	1.5	4	1.3	Compliant	-70.981206	42.20852
720 UNION ST	rmp_1407	Fail	1	Good	Present	Good	Compliant	Compliant	2.2	2.2	2.5	1	0	Compliant	-70.977479	42.22061
366 LIBERTY ST	rmp_1408	Fail	2	Fair	Present	Good	Compliant	Compliant	3.8	1.3	3	5	5	Compliant	-70.98113	42.20834
550 LIBERTY ST	rmp_1409	Fail	1	Good	Present	Good	Compliant	Compliant	0.6	1.1	3.1	3	4.1	Compliant	-70.984393	42.20236
25 COMMERCIAL ST	rmp_1410	Pass	0	Good	Present	Good	Compliant	Compliant	3.4	0.4	4.8	2	0.5	Compliant	-70.969089	42.22069
550 LIBERTY ST	rmp_1411	Fail	1	Good	Present	Good	Compliant	Compliant	0.5	2.6	2.1	5	0.9	Compliant	-70.984728	42.20228
25 COMMERCIAL ST	rmp_1412	Pass	0	Good	Present	Good	Compliant	Compliant	1.6	0.6	4.5	3	0.9	Compliant	-70.96902	42.22122
221 COMMERCIAL ST	rmp_1413	Fail	1	Good	Present	Good	Compliant	Compliant	3.9	0.5	2.7	4	1.3	Compliant	-70.97729	42.22066
221 COMMERCIAL ST	rmp_1414	Fail	1	Good	Present	Good	Compliant	Compliant	3.9	0.5	2.7	4	1.3	Compliant	-70.97729	42.22066
2026 WASHINGTON ST	rmp_1415	Pass	0	Good	Present	Good	Compliant	Compliant	2.4	1.2	1.5	4	0.3	Compliant	-71.010039	42.17198
720 UNION ST	rmp_1416	Fail	1	Good	Present	Good	Compliant	Compliant	4.1	1.4	4.5	0	2.4	Compliant	-70.977565	42.22059
571 LIBERTY ST	rmp_1417	Fail	1	Good	Present	Good	Compliant	Compliant	0.5	2.8	3.5	2	0.4	Compliant	-70.984947	42.20224
720 UNION ST	rmp_1418	Fail	1	Good	Present	Good	Compliant	Compliant	5.5	0	2.5	3	0.6	Compliant	-70.977517	42.22051
571 LIBERTY ST	rmp_1419	Pass	0	Good	Present	Good	Compliant	Compliant	1.2	0.4	3.2	3	0.3	Compliant	-70.985146	42.20248
1807 WASHINGTON ST	rmp_1420	Fail	1	Good	Present	Good	Compliant	Compliant	2.2	1.7	4.2	1	0.1	Compliant	-71.014626	42.17831
555 LIBERTY ST	rmp_1421	Pass	0	Good	Present	Good	Compliant	Compliant	1.3	0.4	2.8	3	0.1	Compliant	-70.985081	42.20261
194 TOWN ST	rmp_1422	Pass	0	Fair	Present	Good	Compliant	Compliant	1.3	0.4	2.9	2	0.9	Compliant	-71.021785	42.20523
29 QUINCY AV	rmp_1423	Pass	0	Good	Present	Good	Compliant	Compliant	0.8	0.3	1.3	0	1.3	Compliant	-70.968918	42.22207
182 COMMERCIAL ST	rmp_1424	Fail	3	Poor	Not Present	Not Present	Compliant	Not Compliant	0.7	0.2	0.5	3	0.4	Compliant	-70.975561	42.22068
467 LIBERTY ST	rmp_1425	Fail	3	Good	Present	Good	Compliant	Not Compliant	1.3	3.2	5.2	4	3.6	Compliant	-70.982696	42.20527
36 EILEEN DR	rmp_1426	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	1.7	0.7	3.3	3	0.3	Compliant	-70.984865	42.20741
457 LIBERTY ST	rmp_1427	Pass	0	Good	Present	Good	Compliant	Compliant	4.1	1	4.6	2	2.3	Compliant	-70.982475	42.20542
196 COMMERCIAL ST	rmp_1428	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	4.8	2.4	3.4	5	0.6	Compliant	-70.975766	42.22068

**Braintree, MA - ADA Ramp Assessment  
2018**

191 COMMERCIAL ST	rmp_1429	Pass	0	Good	Present	Good	Compliant	Compliant	0.4	0	1.2	4	2.1	Compliant	-70.975719	42.22078
68 CHERRY LN	rmp_1430	Fail	2	Good	Present	Good	Compliant	Compliant	1.4	1.3	4.6	4	5	Compliant	-70.98724	42.20258
550 LIBERTY ST	rmp_1431	Pass	0	Good	Present	Good	Compliant	Compliant	0.4	1.1	1.8	4	0.8	Compliant	-70.984685	42.2027
4 STRATHDEE CR	rmp_1432	Fail	1	Good	Present	Good	Compliant	Compliant	0.7	0.7	1.3	3	3.4	Compliant	-70.987133	42.20231
720 UNION ST	rmp_1433	Fail	1	Good	Present	Good	Compliant	Compliant	5	0.1	3.2	5	0.5	Compliant	-70.977419	42.22053
32 ORCHARD ST	rmp_1434	Fail	4	Poor	Not Present	Not Present	Not Compliant	Not Compliant	0	0	0	0	0	Compliant	-70.97719	42.22689
221 COMMERCIAL ST	rmp_1435	Pass	0	Good	Present	Poor	Compliant	Compliant	3.8	1.1	3.6	2	2	Compliant	-70.97727	42.22054
8 DORIS RD	rmp_1436	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.4	0.4	2.9	2	0.1	Compliant	-70.983422	42.20875
555 LIBERTY ST	rmp_1437	Fail	1	Good	Present	Good	Compliant	Compliant	1.7	2.8	4.7	2	0.8	Compliant	-70.984905	42.20276
57 LIBERTY ST	rmp_1438	Fail	2	Fair	Present	Fair	Compliant	Compliant	4.1	5	10.6	0	0.1	Compliant	-70.978331	42.21859
37 HELEN RD	rmp_1439	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	2.2	0.3	4.1	4	0.3	Compliant	-70.983448	42.20893
3 CHERRY LN	rmp_1440	Fail	1	Good	Present	Good	Compliant	Compliant	4.5	2.4	0	0	0.9	Compliant	-70.986968	42.20095
4 CHERRY LN	rmp_1441	Pass	0	Good	Present	Good	Compliant	Compliant	3.5	0.2	1.8	4	2.5	Compliant	-70.98701	42.20033
12 ABBY RD	rmp_1442	Pass	0	Good	Present	Good	Compliant	Compliant	3.7	0.9	1.6	5	1	Compliant	-70.987307	42.1997
191 LISLE ST	rmp_1443	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	0.8	1.1	2	2	0.2	Compliant	-70.981193	42.2138
178 POND ST	rmp_1444	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	6.7	1	8.1	11	1.1	Compliant	-71.015387	42.20002
51 COMMERCIAL ST	rmp_1445	Pass	0	Good	Present	Good	Compliant	Compliant	1.1	0.7	2.9	5	2.2	Compliant	-70.969339	42.22118
2 SUNSET RD	rmp_1446	Fail	5	Good	Not Present	Not Present	Compliant	Not Compliant	5.2	2.7	1.8	6	1.6	Compliant	-71.014326	42.20045
47 LIBERTY ST	rmp_1447	Fail	1	Good	Present	Good	Compliant	Compliant	1.4	2.4	3.4	0	2.3	Compliant	-70.978306	42.2187
1 OLD VALLEY RD	rmp_1448	Fail	2	Good	Present	Good	Compliant	Compliant	2.7	1.3	0.3	4	4.6	Compliant	-70.987271	42.19984
143 POND ST	rmp_1449	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	8.7	0.1	3.8	5	0.5	Compliant	-71.014178	42.20047
48 NORFOLK RD	rmp_1450	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.3	1.2	4.4	5	1.4	Compliant	-70.982981	42.21031
10 WAYNE AV	rmp_1451	Fail	5	Poor	Not Present	Not Present	Compliant	Not Compliant	6.6	2	3.4	4	1.6	Compliant	-71.015277	42.20003
11 WAYNE AV	rmp_1452	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	6.5	1	6	1	0.5	Compliant	-71.015032	42.19933
509 LIBERTY ST	rmp_1453	Pass	0	Good	Present	Poor	Compliant	Compliant	0.8	0.8	0	0	0.5	Compliant	-70.984981	42.20425
165 POND ST	rmp_1454	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	8.8	1.7	2.8	6	0.9	Compliant	-71.014907	42.20026
132 POND ST	rmp_1455	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	4.6	2.5	7	4	5	Compliant	-71.013466	42.20045
522 LIBERTY ST	rmp_1456	Pass	0	Good	Present	Good	Compliant	Compliant	0.6	0.8	0	0	1.5	Compliant	-70.984949	42.20381
3 FAIRVIEW AV	rmp_1457	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	8.1	1.9	4.5	6	2.4	Compliant	-71.012918	42.20048
3 FAIRVIEW AV	rmp_1458	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	8.1	1.9	4.5	6	2.4	Compliant	-71.012918	42.20048
522 LIBERTY ST	rmp_1459	Pass	0	Good	Present	Good	Compliant	Compliant	0.2	0.5	0	0	0.1	Compliant	-70.984867	42.20384
115 POND ST	rmp_1460	Fail	4	Poor	Not Present	Not Present	Compliant	Not Compliant	2.2	0.7	5.8	3	1.2	Compliant	-71.012772	42.20047
10 GRAZIANO DR	rmp_1461	Fail	3	Poor	Not Present	Not Present	Compliant	Not Compliant	1	0.7	5.5	5	2.2	Compliant	-71.018029	42.19935
244 POND ST	rmp_1462	Fail	5	Poor	Not Present	Not Present	Compliant	Not Compliant	1	1	7.9	8	1.6	Compliant	-71.018159	42.19929
250 POND ST	rmp_1463	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	1	3.8	12.1	6	2	Compliant	-71.018618	42.199
250 POND ST	rmp_1464	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	1	5.9	5.2	13	5.6	Compliant	-71.018672	42.19896
250 POND ST	rmp_1465	Fail	5	Poor	Not Present	Not Present	Compliant	Not Compliant	1	8	13.6	1	2.5	Compliant	-71.018983	42.19876
250 POND ST	rmp_1466	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	1	7.5	0.8	16	5.3	Compliant	-71.019017	42.19874
4 LAKE ST	rmp_1467	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	9.6	0.6	8.3	8	1.1	Compliant	-71.02235	42.19817
348 POND ST	rmp_1468	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	1	1.2	7	11	5.9	Compliant	-71.023155	42.19812
54 LIBERTY ST	rmp_1469	Fail	2	Fair	Present	Good	Compliant	Compliant	2.1	3	0.2	6	2.5	Compliant	-70.978127	42.21845
45 NORFOLK RD	rmp_1470	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	2.3	0.2	3	6	0.5	Compliant	-70.982964	42.21046
6 ATHERTON ST	rmp_1471	Fail	2	Good	Present	Good	Compliant	Compliant	2.8	3.2	1.6	6	0.9	Compliant	-70.978297	42.21775
8 TOWER HILL RD	rmp_1472	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	1	1.8	14.4	14	0.6	Compliant	-71.01905	42.19884
5 ATHERTON ST	rmp_1473	Fail	1	Good	Present	Good	Compliant	Compliant	2.8	0.3	6.6	4	2.8	Compliant	-70.978322	42.21764
661 LIBERTY ST	rmp_1474	Pass	0	Good	Present	Good	Compliant	Compliant	2.7	0.2	2.2	3	1.2	Compliant	-70.985273	42.19923
1070 LIBERTY ST	rmp_1475	Pass	0	Good	Present	Good	Compliant	Compliant	0.9	0.1	3.6	3	0.6	Compliant	-70.988863	42.18762
194 TOWN ST	rmp_1476	Pass	0	Good	Present	Good	Compliant	Compliant	0.9	0.2	2.3	4	1.9	Compliant	-71.021784	42.2051
247 RIVER ST	rmp_1477	Fail	2	Poor	Not Present	Not Present	Compliant	Compliant	4.6	0	4.4	5	0	Compliant	-70.992325	42.22058
77 LOUISE RD	rmp_1478	Fail	5	Poor	Not Present	Not Present	Compliant	Not Compliant	3.1	4.4	0.2	8	2.1	Compliant	-70.982943	42.21278
272 LISLE ST	rmp_1479	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	3	2.1	2.4	4	2.8	Compliant	-70.983208	42.21284
301 POND ST	rmp_1480	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	7.2	0.5	7.5	7	1.1	Compliant	-71.020832	42.19845
178 POND ST	rmp_1481	Fail	5	Poor	Not Present	Not Present	Compliant	Not Compliant	5.2	2.7	4.7	3	0.9	Compliant	-71.01534	42.19981
11 WAYNE AV	rmp_1482	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	9.3	1.8	1.5	5	2.8	Compliant	-71.015251	42.1997
95 ROBBIE RD	rmp_1483	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.9	0.1	4.3	2	2	Compliant	-70.981321	42.21361
616 MIDDLE ST	rmp_1484	Pass	0	Good	Present	Good	Compliant	Compliant	1.7	0.3	3.5	3	1.5	Compliant	-70.98625	42.20587
8 BUTLER RD	rmp_1485	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	5.2	2.4	4.9	5	0.3	Compliant	-71.014936	42.19922
624 MIDDLE ST	rmp_1486	Fail	1	Good	Present	Good	Compliant	Compliant	2.5	0.1	3.2	2	3.5	Compliant	-70.986165	42.20569
6 SUN VALLEY DR	rmp_1487	Fail	5	Poor	Not Present	Not Present	Compliant	Not Compliant	2.1	2.6	7.9	2	1	Compliant	-70.980607	42.21569
140 LISLE ST	rmp_1488	Fail	4	Good	Not Present	Not Present	Compliant	Not Compliant	1.4	3	1.2	7	1.8	Compliant	-70.980416	42.21567
18 ROYAL LAKE DR	rmp_1489	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	1	1.4	8.9	13	0.3	Compliant	-71.015511	42.20015
133 LISLE ST	rmp_1490	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	0.6	3	5.7	0	0.5	Compliant	-70.980626	42.21583
18 ROYAL LAKE DR	rmp_1491	Fail	5	Poor	Not Present	Not Present	Compliant	Not Compliant	9.6	2.2	2.1	0	0.1	Compliant	-71.015358	42.20019
188 TOWN ST	rmp_1492	Pass	0	Good	Present	Good	Compliant	Compliant	1.8	0.5	2.8	3	1.3	Compliant	-71.021788	42.20496
1 STETSON ST	rmp_1493	Fail	2	Poor	Present	Fair	Compliant	Compliant	4.2	0.3	2.8	6	2	Compliant	-70.978149	42.21837

**Braintree, MA - ADA Ramp Assessment  
2018**

31 NORFOLK RD	rmp_1494	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	1.7	0.9	0.9	7	2.6	Compliant	-70.982779	42.21039	
73 LIBERTY ST	rmp_1495	Fail	1	Good	Present	Good	Compliant	Compliant	1.5	0.4	1.7	1	5.2	Compliant	-70.978514	42.21792	
81 LIBERTY ST	rmp_1496	Fail	1	Fair	Present	Good	Compliant	Compliant	4.2	3.1	5.5	1	2.3	Compliant	-70.978556	42.21782	
410 PLAIN ST	rmp_1497	Fail	1	Good	Present	Good	Compliant	Compliant	0.1	0	2.9	4	7.8	Compliant	-70.987293	42.19901	
44 TINGLEY RD	rmp_1498	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	3.3	1.1	4.5	6	0.6	Compliant	-70.981961	42.22451	
420 PLAIN ST	rmp_1499	Fail	2	Good	Present	Good	Compliant	Compliant	1.6	1.3	5.1	3	4.7	Compliant	-70.987145	42.19898	
32 NORFOLK RD	rmp_1500	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	1.5	6	8.9	0	0.5	Compliant	-70.982795	42.21024	
660 LIBERTY ST	rmp_1501	Fail	1	Good	Present	Good	Compliant	Compliant	6	0.1	3.5	4	1.3	Compliant	-70.985122	42.19923	
20 PERRY RD	rmp_1502	Pass	0	Good	Present	Good	Compliant	Compliant	3.1	0.2	0	0	1.3	Compliant	-70.993884	42.22879	
501 MIDDLE ST	rmp_1503	Fail	2	Good	Present	Good	Compliant	Compliant	0.5	1.3	1.5	3	4.2	Compliant	-70.986532	42.21017	
550 LIBERTY ST	rmp_1504	Fail	1	Fair	Present	Good	Compliant	Compliant	0.7	1.7	0	0	0.7	Compliant	-70.98477	42.20232	
571 LIBERTY ST	rmp_1505	Pass	0	Fair	Present	Good	Compliant	Compliant	0.1	0.2	0	0	1.8	Compliant	-70.984837	42.20231	
571 LIBERTY ST	rmp_1506	Pass	0	Fair	Present	Good	Compliant	Compliant	0.5	0.6	0	0	1	Compliant	-70.985091	42.20252	flat passthru
30 LOUISE RD	rmp_1507	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.7	0.3	3.5	3	0.7	Compliant	-70.98242	42.21145	
555 LIBERTY ST	rmp_1508	Pass	0	Fair	Present	Good	Compliant	Compliant	0.5	0.3	0	0	2.4	Compliant	-70.985097	42.20256	flat passthru
12 LOUISE RD	rmp_1509	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.6	0.2	4.5	4	1.8	Compliant	-70.982377	42.21127	
555 LIBERTY ST	rmp_1510	Fail	1	Good	Present	Good	Compliant	Compliant	1.2	1.8	0	0	0.8	Compliant	-70.984847	42.20272	
550 LIBERTY ST	rmp_1511	Fail	1	Good	Present	Good	Compliant	Compliant	0.7	2.9	0	0	2.3	Compliant	-70.984764	42.20272	
92 LOUISE RD	rmp_1512	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	1.1	5	5.5	1	0.3	Compliant	-70.983212	42.21302	
259 LISLE ST	rmp_1513	Fail	4	Poor	Not Present	Not Present	Compliant	Not Compliant	1.9	0.4	4.3	3	3.5	Compliant	-70.982967	42.21297	
225 POND ST	rmp_1514	Fail	5	Poor	Not Present	Not Present	Compliant	Not Compliant	1	1	11.2	6	1.2	Compliant	-71.01765	42.19962	
305 POND ST	rmp_1515	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	5.5	0	7.9	8	0.5	Compliant	-71.021004	42.19843	
215 POND ST	rmp_1516	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	1	3.5	13.3	1	4.2	Compliant	-71.017525	42.19967	
226 POND ST	rmp_1517	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	1	6.8	6.2	8	0.2	Compliant	-71.017437	42.1996	
298 POND ST	rmp_1518	Fail	6	Poor	Not Present	Not Present	Compliant	Not Compliant	10	2.8	0	7	0.6	Compliant	-71.020968	42.19834	
182 TOWN ST	rmp_1519	Pass	0	Good	Present	Good	Compliant	Compliant	1.5	0.6	1.4	4	2.8	Compliant	-71.021783	42.20479	
536 GRANITE ST	rmp_1520	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	5.8	1.1	2.7	3	3.6	Compliant	-71.0201	42.2127	
216 POND ST	rmp_1521	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	1	1	2.7	12	1.3	Compliant	-71.017262	42.19965	
306 POND ST	rmp_1522	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	1	1.5	4.5	4	2.6	Compliant	-71.02147	42.19828	
320 POND ST	rmp_1523	Fail	5	Fair	Not Present	Not Present	Compliant	Not Compliant	1	1.7	13.5	14	1.3	Compliant	-71.021581	42.19826	
12 LOUISE RD	rmp_1524	Fail	2	Good	Present	Good	Compliant	Compliant	1.5	3.9	0	3	3	Compliant	-70.981746	42.21086	
11 LOUISE RD	rmp_1525	Fail	3	Good	Present	Good	Compliant	Compliant	0.9	5.9	4.5	8	4.2	Compliant	-70.98171	42.21096	
3 LAKE ST	rmp_1526	Fail	4	Fair	Not Present	Not Present	Compliant	Not Compliant	1	0.6	11.3	9	0.6	Compliant	-71.022522	42.19816	
348 POND ST	rmp_1527	Fail	5	Poor	Not Present	Not Present	Compliant	Not Compliant	1	5.2	15.2	5	0.7	Compliant	-71.023374	42.19818	
105 NORFOLK RD	rmp_1528	Fail	1	Good	Present	Good	Compliant	Compliant	1.3	0.9	1.5	2	3.3	Compliant	-70.98655	42.21022	
411 POND ST	rmp_1529	Fail	4	Poor	Not Present	Not Present	Compliant	Compliant	1	0.4	0.4	6	0.3	Not Compliant	-71.026015	42.19888	
6 KING HILL RD	rmp_1530	Fail	4	Poor	Not Present	Not Present	Compliant	Not Compliant	7	0.9	3.5	6	2.8	Compliant	-71.026108	42.19892	
1 HAZEL CT	rmp_1531	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	1.8	0.6	3.1	5	0.6	Compliant	-70.983245	42.20966	
27 HELEN RD	rmp_1532	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	1	2.8	3	4	0.6	Compliant	-70.983314	42.20955	
6 ROME DR	rmp_1533	Pass	0	Good	Present	Good	Compliant	Compliant	1.5	0.6	4.7	2	0.8	Compliant	-71.030715	42.19891	
5 FABIANO DR	rmp_1534	Pass	0	Good	Present	Good	Compliant	Compliant	1.6	0.5	2.6	0	2.7	Compliant	-71.030771	42.19885	
6 ROME DR	rmp_1535	Pass	0	Good	Present	Good	Compliant	Compliant	2.6	0.1	3.1	4	2.1	Compliant	-71.030275	42.19941	
95 KING HILL RD	rmp_1536	Fail	2	Good	Present	Good	Compliant	Compliant	3.1	0.2	4.2	2	3.6	Not Compliant	-71.030253	42.19949	
250 GRANITE ST	rmp_1537	Pass	0	Good	Present	Good	Compliant	Compliant	0.9	0.6	4.5	1	1.9	Compliant	-71.028146	42.22072	
250 GRANITE ST	rmp_1538	Pass	0	Good	Present	Good	Compliant	Compliant	0.7	0.8	0.7	4	0.1	Compliant	-71.027854	42.22047	
7 ADDISON ST	rmp_1539	Fail	2	Good	Present	Good	Compliant	Compliant	1.7	1.7	3.6	0	4.7	Compliant	-71.027017	42.21192	
8 BURTON RD	rmp_1540	Fail	1	Good	Present	Good	Compliant	Compliant	0.3	3.2	1.9	4	0.3	Compliant	-71.02599	42.21189	
550 GRANITE ST	rmp_1541	Fail	2	Fair	Not Present	Not Present	Compliant	Compliant	0.5	1.5	3.8	1	0.9	Compliant	-71.019577	42.21219	
495 POND ST	rmp_1542	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	2	0.2	1.4	5	0.8	Compliant	-71.027971	42.19595	
6 CAMEO RD	rmp_1543	Pass	0	Good	Present	Good	Compliant	Compliant	1.7	0	3.7	3	1.3	Compliant	-71.021321	42.20306	
10 REGIS RD	rmp_1544	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	1.2	0.1	2.5	0	3.6	Compliant	-71.028003	42.19588	
6 CAMEO RD	rmp_1545	Pass	0	Good	Present	Good	Compliant	Compliant	1.1	0.3	4.3	3	1.7	Compliant	-71.021417	42.20303	
550 GRANITE ST	rmp_1546	Fail	3	Good	Not Present	Not Present	Compliant	Not Compliant	3.8	2.7	3.7	2	2.8	Compliant	-71.019691	42.21222	
5 CAMEO RD	rmp_1547	Pass	0	Good	Present	Good	Compliant	Compliant	1.1	0.8	1.3	4	2.3	Compliant	-71.021462	42.20317	
467 GRANITE ST	rmp_1548	Fail	1	Good	Present	Fair	Compliant	Compliant	4.3	0.1	4.7	3	4.3	Compliant	-71.021949	42.21464	
579 GRANITE ST	rmp_1549	Fail	5	Poor	Not Present	Not Present	Compliant	Not Compliant	1.4	1.5	0	8	1.3	Compliant	-71.020008	42.21063	
7 BURTON RD	rmp_1550	Fail	1	Good	Present	Good	Compliant	Compliant	1	1.7	3.1	3	1.4	Compliant	-71.025714	42.21186	
61 REGIS RD	rmp_1551	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	0.9	0.1	2	2	1.1	Compliant	-71.030329	42.19636	
62 REGIS RD	rmp_1552	Fail	1	Good	Not Present	Not Present	Compliant	Compliant	1.4	0.3	4	4	2.1	Compliant	-71.030345	42.19625	
512 POND ST	rmp_1553	Fail	1	Good	Present	Good	Compliant	Compliant	0	0.9	3.4	0	3.6	Compliant	-71.027856	42.19541	
46 REGIS RD	rmp_1554	Fail	2	Fair	Not Present	Not Present	Compliant	Not Compliant	1.8	0.2	4.5	3	2.2	Compliant	-71.030211	42.19622	
45 REGIS RD	rmp_1555	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	1.7	0.3	2.6	1	1.9	Compliant	-71.030181	42.19634	
522 POND ST	rmp_1556	Fail	3	Good	Present	Good	Compliant	Not Compliant	3.1	0.5	0.3	7	3.2	Compliant	-71.027883	42.1953	
500 POND ST	rmp_1557	Fail	1	Good	Present	Good	Compliant	Compliant	3.6	0.7	1.5	2	4.4	Compliant	-71.027771	42.19601	
490 POND ST	rmp_1558	Pass	0	Good	Present	Good	Compliant	Compliant	1.8	1.2	3.2	1	2.1	Compliant	-71.027738	42.19608	

**Braintree, MA - ADA Ramp Assessment  
2018**

483 POND ST	rmp_1559	Pass	0	Good	Present	Good	Compliant	Compliant	4.3	0.2	5.1	1	0.6	Compliant	-71.027773	42.19665
473 POND ST	rmp_1560	Fail	1	Good	Present	Good	Compliant	Compliant	2.6	0.3	4.3	4	4.2	Compliant	-71.027731	42.19673
614 POND ST	rmp_1561	Fail	1	Good	Present	Good	Compliant	Not Compliant	1.2	0.3	2.2	0	2.1	Compliant	-71.029155	42.19242
5 ANDERSEN RD	rmp_1562	Fail	4	Good	Not Present	Not Present	Compliant	Compliant	5.1	1.3	1.3	4	3.6	Compliant	-71.020666	42.20899
4 ANDERSEN RD	rmp_1563	Fail	3	Fair	Not Present	Not Present	Compliant	Compliant	7.1	3	5.4	5	1.2	Compliant	-71.0206	42.20907
695 GRANITE ST	rmp_1564	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	0.4	0.1	3.3	4	0.8	Compliant	-71.02196	42.20674
618 GRANITE ST	rmp_1565	Fail	2	Good	Present	Good	Compliant	Compliant	1.3	1.6	0.9	2	3	Compliant	-71.02021	42.20993
732 GRANITE ST	rmp_1566	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	1.8	0.5	3	5	0.4	Compliant	-71.022048	42.20639
618 GRANITE ST	rmp_1567	Fail	2	Good	Present	Good	Compliant	Not Compliant	0.2	0.8	3	2	4.5	Compliant	-71.020179	42.20998
128 TOWN ST	rmp_1568	Pass	0	Good	Present	Good	Compliant	Compliant	1.3	0.4	2	2	0.9	Compliant	-71.021765	42.20598
618 GRANITE ST	rmp_1569	Pass	0	Good	Present	Good	Compliant	Compliant	0.6	0.6	3.8	0	1.6	Compliant	-71.02004	42.21023
128 TOWN ST	rmp_1570	Pass	0	Good	Present	Good	Compliant	Compliant	1.1	0.2	1.4	3	1.4	Compliant	-71.021789	42.20589
540 GRANITE ST	rmp_1571	Fail	4	Poor	Not Present	Not Present	Compliant	Not Compliant	4	2.4	3.1	5	0.4	Compliant	-71.019946	42.21256
536 GRANITE ST	rmp_1572	Fail	2	Good	Not Present	Not Present	Compliant	Compliant	3.2	1	5.8	4	0.9	Compliant	-71.020434	42.21307
28 EMERALD AV	rmp_1573	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	1.1	0.9	3.8	2	1.3	Compliant	-71.022889	42.20254
536 GRANITE ST	rmp_1574	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	4.2	4.7	0.2	7	0	Compliant	-71.020543	42.2132
16 EMERALD AV	rmp_1575	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	2.4	0.4	3.1	4	0.3	Compliant	-71.023003	42.2026
485 GRANITE ST	rmp_1576	Fail	3	Fair	Not Present	Not Present	Compliant	Not Compliant	1.3	2.3	0	0	2.6	Compliant	-71.021337	42.21378
485 GRANITE ST	rmp_1577	Fail	3	Poor	Not Present	Not Present	Compliant	Not Compliant	3.2	0.8	0	0	1.6	Compliant	-71.021431	42.21389
485 GRANITE ST	rmp_1578	Fail	4	Poor	Not Present	Not Present	Compliant	Not Compliant	4.2	1.4	0	0	0.3	Compliant	-71.021596	42.21418
485 GRANITE ST	rmp_1579	Fail	2	Good	Not Present	Not Present	Compliant	Not Compliant	3.6	1.2	0	1	2.3	Compliant	-71.021645	42.21425
467 GRANITE ST	rmp_1580	Fail	2	Good	Present	Good	Compliant	Compliant	0.1	1.4	0	0	3.7	Compliant	-71.021999	42.21469
467 GRANITE ST	rmp_1581	Pass	0	Good	Present	Good	Compliant	Compliant	0.3	0.3	0	0	2	Compliant	-71.022041	42.21474
467 GRANITE ST	rmp_1582	Fail	1	Fair	Not Present	Not Present	Compliant	Compliant	1.1	0.7	3.5	4	0.6	Compliant	-71.022113	42.21482
551 GRANITE ST	rmp_1583	Fail	3	Good	Not Present	Not Present	Compliant	Compliant	3.2	3.4	7.9	0	0.3	Compliant	-71.019863	42.21209

**Braintree, MA - Cross Slope + Width Assessment  
2018**

StreetName	FromStreetName	ToStreetName	SS_ID	Orientation	Avg. Slope	Confidence	Avg. Width	Slope Compliant	Width Compliant	Length (ft)
Abby Rd	Plain St	Cherry Ln	697	E	3.34	1.41	5.27	No	Yes	529.66
Woodedge Lane	Woodedge Avenue	Woodedge Avenue	138	N/A	2.33	0.70	4.98	No	Yes	705.77
Woodedge Circle	Woodedge Avenue	Woodedge Avenue	140	N/A	2.33	0.74	6.1	No	Yes	433.78
Spring Glen Circle	Spring Glen Circle	Old Country Way	167	E	2.84	0.73	5.13	No	Yes	300.42
Alida Road	Marjorie Road	Grace Road	28	E	1.46	0.89	4.45	Yes	Yes	269.88
Teaberry Lane	McAndrew Road	Teaberry Lane	5	W	1.90	0.61	5.59	Yes	Yes	554.20
Teaberry Lane	Teaberry Lane	100 Teaberry Lane	6	W	1.46	0.51	5.04	Yes	Yes	663.33
Teaberry Lane	Angela Road	Teaberry Lane	8	E	1.43	0.53	5.19	Yes	Yes	506.12
Liberty St	Sidewalk Island	Sidewalk Island	19	E	1.42	0.77	3.38	Yes	No	12.19
Shaw St	Sidewalk Island	Sidewalk Island	4	W	0.89	0.69	5.72	Yes	Yes	13.74
Bayberry Lane	Old Country Way	Old Country Way	164	N/A	2.10	0.65	5.2	No	Yes	495.56
Kenmore Road	32-28 Kenmore Road	Amherst Road	27	N	1.88	0.46	4.64	Yes	Yes	144.73
Pond St	Sidewalk Island	Sidewalk Island	3	E	2.62	0.86	3.5	No	No	12.67
Hoover Avenue	32 Hoover Avenue	38 Hoover Avenue	29	E	0.57	0.50	4.35	Yes	Yes	86.26
Crawford Street	Pearl St	34ft NE Pearl St	1	E	2.58	0.51	5.08	No	Yes	34.14
Kensington Street	135 Kensington Street	126 Kensington Street	2	S	0.49	1.30	3.3	Yes	No	30.00
Teaberry Lane	95 Teaberry Lane	65 Teaberry Lane	9	S	1.69	0.53	4.79	Yes	Yes	595.20
Teaberry Lane	65 Teaberry Lane	95 Teaberry Lane	10	N	1.94	0.65	6.15	Yes	Yes	717.75
Catherine Drive	140 Catherine Drive	1891 Washington Street	25	S	2.70	0.75	5.98	No	Yes	834.82
Washington Street	Main Street	Lincoln Street	75	W	0.43	1.17	4.36	Yes	Yes	223.30
Liberty Street	Liberty Street	Liberty Street	44	W	0.97	0.86	5.85	Yes	Yes	235.99
Washington Street	Lincoln Street	Roosevelt Street	74	W	1.66	0.51	5.82	Yes	Yes	246.40
Roosevelt Street	Roosevelt Street	2089 Washington Street	67	N	1.35	0.57	5.47	Yes	Yes	277.46
Cain Avenue	Summit Ridge Drive	59 Cain Avenue	119	E	1.47	0.70	4.95	Yes	Yes	407.28
Elliot St	Stetson St	Townline	1104	N	1.71	0.52	4.75	Yes	Yes	957.90
Lawson Lane	Cain Avenue	Paul Street	37	N	2.54	0.81	6.08	No	Yes	374.70
Washington Street	Roosevelt Street	Holbrook Town Line	66	W	0.83	0.49	5.79	Yes	Yes	587.94
Livoli Avenue	East Division Street	Water Street	68	W	1.22	0.56	5.18	Yes	Yes	678.39
Water Street	Washington Street	33 Water Street	69	S	0.82	0.56	5.49	Yes	Yes	435.60
Water Street	33 Water Street	63 Water Street	70	S	0.90	1.49	3.2	Yes	No	398.34
Water Street	63 Water Street	Livoli Avenue	71	S	1.16	1.06	5.32	Yes	Yes	247.27
Livoli Avenue	57 Livoli Avenue	52 East Division Street	72	E	1.29	0.54	4.99	Yes	Yes	692.27
Water Street	Washington Street	Cain Avenue	73	N	0.82	0.51	5.07	Yes	Yes	436.96
Water Street	Cain Avenue	Paul Street	76	N	1.19	0.58	5.09	Yes	Yes	368.86
Water Street	Paul Street	Livoli Avenue	77	N	0.82	0.52	5.37	Yes	Yes	233.50
Hancock St	Hancock Ave	Frederick Rd	698	W	2.21	0.44	5.75	No	Yes	894.07
Old Valley Rd	Abby Rd	Abby Rd	1657	N/A	3.82	1.41	4.59	No	Yes	615.53
Albee Drive	Liberty Street	Canavan Drive	81	N	2.88	0.78	5.48	No	Yes	2075.48
South Street	Unnamed Road	Old Country Way	101	W	2.08	0.79	6.19	No	Yes	213.85
Liberty St	Jonas Perkins Park Path (Union St)	Lisle St	1168	W	1.06	0.49	5.67	Yes	Yes	634.50
Liberty St	Stetson St	Commercial St	1169	W	1.26	0.47	6.07	Yes	Yes	805.62
Joseph Rd	Francine Rd	65 Joseph Rd	1239	N	1.35	0.64	5.18	Yes	Yes	543.74
Washington Street	Boylston St	Main St	89	E	0.81	0.43	5.48	Yes	Yes	212.01
Washington Street	Virginia Road	Boylston St	100	W	1.24	0.46	6.15	Yes	Yes	230.86
Livoli Avenue	Paul Street	151 Livoli Avenue	114	N/A	1.63	0.57	6	Yes	Yes	453.86
Old Country Way	Woodside Avenue	South Street	103	N	2.95	0.59	5.2	No	Yes	259.97
Old Country Way	Leehaven Terrace	Woodside Avenue	111	N	2.73	0.75	4.66	No	Yes	230.92
Cain Avenue	Lawson Lane	Water Street	83	E	1.48	0.97	4.75	Yes	Yes	228.99
Lawson Lane	Cain Avenue	Paul Street	84	S	2.41	0.86	5.51	No	Yes	373.73
Paul Street	Lawson Lane	Water Street	85	W	0.89	0.79	4.94	Yes	Yes	235.67
Cain Avenue	20 Cain Avenue	Water Street	86	W	1.92	0.83	5.46	Yes	Yes	243.30
Washington Street	Boylston Street	Main Street	87	W	1.62	0.51	5.74	Yes	Yes	180.55
Cain Avenue	Deigan Avenue	Lawson Lane	92	E	1.93	0.82	5.16	Yes	Yes	222.34
Old Country Way	14 Old Country Way	South Street	102	S	2.18	0.66	5.08	No	Yes	260.49
Cain Avenue	Milton Road	38 Cain Avenue	104	W	2.14	0.62	5.21	No	Yes	240.20
Virginia Road	Washington Street	Milton Road	105	S	1.01	0.90	5.77	Yes	Yes	290.27
Old Country Way	38 Old Country Way	14 Old Country Way	107	S	2.69	0.61	5.1	No	Yes	261.84
Cain Avenue	59 Cain Avenue	Deigan Avenue	108	E	1.90	0.83	6.18	Yes	Yes	240.19
Paul Street	Deigan Avenue	Livoli Avenue	109	W	2.77	1.01	5.33	No	Yes	222.52

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Paul Street	Livoli Avenue	43 Paul Street	110	E	1.99	0.84	5.46	Yes	Yes	237.19
Washington Street	Milton Road	Virginia Road	112	E	1.99	0.61	6.16	Yes	Yes	1248.88
Virginia Road	Washington Street	Milton Road	113	N	1.58	0.74	5.13	Yes	Yes	285.15
Woodside Avenue	Old Country Way	44 Woodside Avenue	116	W	1.37	0.51	5.25	Yes	Yes	543.59
Liberty Street	Liberty Park Avenue	Oakden Avenue	212	W	1.59	0.47	5.97	Yes	Yes	1270.91
Drake Street	Mann Street	Wildwood Avenue	216	W	1.02	0.59	4.17	Yes	Yes	423.38
Wildwood Avenue	Evelyn Lane	Liberty Park Avenue	219	N	1.70	0.38	4.66	Yes	Yes	1055.54
Foster Road	Foster Road	Washington Street	220	S	2.28	0.49	5.86	No	Yes	380.49
Massachusetts Avenue	Arbutus Avenue	Brewster Avenue	275	W	0.93	0.81	5.8	Yes	Yes	748.07
Massachusetts Avenue	Arbutus Avenue	Brewster Avenue	276	E	1.00	0.87	6.12	Yes	Yes	739.13
Whites Hill Drive	Liberty Street	Liberty Street	1516	N/A	2.03	0.73	5.3	No	Yes	872.24
Bradford Road	Alden Road	Cain Avenue	248	S	2.53	0.96	5.54	No	Yes	546.05
Bradford Road	Cain Avenue	Wildwood Avenue	256	S	1.50	0.80	5.21	Yes	Yes	254.45
Wildwood Avenue	Bradford Road	Mann Street	257	S	1.49	0.49	4.63	Yes	Yes	782.13
Arbutus Avenue	Hayward Avenue	Plymouth Avenue	259	S	1.95	0.50	6.11	Yes	Yes	258.54
Arbutus Avenue	Plymouth Avenue	Winthrop Avenue	263	S	1.90	0.54	4.99	Yes	Yes	213.73
Winthrop Avenue	Arbutus Avenue	Brewster Avenue	264	W	0.64	0.53	5.98	Yes	Yes	828.77
Winthrop Avenue	Arbutus Avenue	Brewster Avenue	265	E	0.74	0.49	5.3	Yes	Yes	818.86
Washington Street	Hill View Road	15ft to Wampatuck Road	266	W	1.80	0.52	5.73	Yes	Yes	237.89
Arbutus Avenue	Winthrop Avenue	Massachusetts Avenue	274	S	0.77	0.47	4.79	Yes	Yes	214.20
Washington Street	Wampatuck Road	15ft to Plymouth Road	284	W	1.66	0.39	6.39	Yes	Yes	247.66
Washington Street	20ft from Plymouth Avenue	Winthrop Avenue	285	E	2.36	0.48	5.3	No	Yes	264.17
Arbutus Avenue	Standish Avenue	Brewster Avenue	290	S	0.94	0.40	5.28	Yes	Yes	208.06
Winthrop Avenue	Washington Street	Arbutus Avenue	298	W	1.41	0.77	5.43	Yes	Yes	622.31
Arbutus Avenue	Brewster Avenue	Wildwood Avenue	299	S	0.97	0.56	4.18	Yes	Yes	451.00
Arbutus Avenue	44 Arbutus Avenue	Massachusetts Avenue	277	N	0.87	0.62	4.59	Yes	Yes	126.47
Brewster Avenue	Standish Avenue	144 Brewster Avenue	278	W	2.93	0.97	5.01	No	Yes	577.30
Hatch Avenue	Robbie Road	Robbie Road	1085	N/A	0.49	0.34	5.99	Yes	Yes	671.26
Plymouth Avenue	Arbutus Avenue	Brewster Avenue	261	E	0.74	0.43	5	Yes	Yes	844.43
Massachusetts Avenue	25 Massachusetts Avenue	Arbutus Avenue	300	W	1.23	0.80	5.26	Yes	Yes	482.23
Massachusetts Avenue	Washington Street	25 Massachusetts Avenue	301	W	1.54	0.71	5	Yes	Yes	280.51
Massachusetts Avenue	Marion Avenue	Arbutus Avenue	302	E	1.91	0.87	5.43	Yes	Yes	467.22
Winthrop Avenue	Washington Street	Arbutus Avenue	304	E	1.23	0.71	4.85	Yes	Yes	642.01
Washington Road	Plymouth Road	20ft to Beals Road	305	W	2.13	0.50	5.98	No	Yes	332.75
Wildwood Avenue	Arbutus Avenue	Sheraton Avenue	308	W	0.52	0.59	5.08	Yes	Yes	208.91
Shaw St	Cedarcliff Rd	Thayer Rd	1246	E	2.16	1.00	5.59	No	Yes	409.13
Standish Avenue	Park Avenue	Arbutus Avenue	316	E	1.72	0.80	5.7	Yes	Yes	699.25
Washington Street	Winthrop Avenue	Massachusetts Avenue	318	E	1.80	0.38	6.26	Yes	Yes	243.34
Saint Claire Street	McAndrew Road	265 St Claire St	319	E	1.95	0.59	5.05	Yes	Yes	185.31
Massachusetts Avenue	Washington Street	Marion Avenue	320	E	2.67	0.99	5.92	No	Yes	281.71
Washington Street	Beals Road	1701 Washington Street	321	W	1.52	0.46	5.86	Yes	Yes	170.99
Shaw St	Cedarcliff Rd	Allen St	1248	W	2.01	0.91	6.06	No	Yes	417.02
Laurel Road	Park Avenue	Arbutus Avenue	325	W	1.43	0.72	6.22	Yes	Yes	386.61
Washington Street	Massachusetts Avenue	Park Avenue	327	E	1.82	0.72	5.2	Yes	Yes	87.52
Standish Avenue	Park Avenue	21 Standish Avenue	329	W	1.31	0.67	5.37	Yes	Yes	144.29
Brewster Avenue	Park Avenue	Arbutus Avenue	331	W	2.13	0.52	3.4	No	No	556.08
Brewster Avenue	Park Avenue	Arbutus Avenue	332	E	2.04	0.55	5.5	No	Yes	536.27
McAndrew Road	Saint Claire Street	Teaberry Lane	335	S	3.72	0.84	5.75	No	Yes	1636.03
McAndrew Road	Saint Claire Street	Forest Street	336	N	3.43	0.89	4.63	No	Yes	1643.01
Park Ave	Standish Ave	Sheraton Ave	314	N	0.85	0.50	5.61	Yes	Yes	1321.09
Washington St	Sidewalk Island	Sidewalk Island	334	N/A	1.61	0.56	4.71	Yes	Yes	280.70
Angela Road	Teaberry Lane	Birch Street	326	E	1.99	0.68	5.21	Yes	Yes	1569.81
Park Avenue	Washington Avenue	Standish Avenue	328	S	1.89	0.61	4.46	Yes	Yes	168.29
Standish Avenue	Arbutus Avenue	Brewster Avenue	158	E	1.55	0.57	5.76	Yes	Yes	668.55
Saint Claire Street	McAndrew Road	Saint Lawrence Street	337	E	2.17	1.05	5.44	No	Yes	685.64
Wildwood Avenue	Mann Street	Olofson Street	202	S	0.99	0.50	5.01	Yes	Yes	305.43
Birchcroft Rd	Sterling St	Town Line	1044	W	2.11	0.74	4.21	No	Yes	728.73
Devon Wood Dr	Bradford Commons Ln	Devon Club Ln	207	N	0.76	0.46	5.2	Yes	Yes	194.31
Howie Rd	Acorn Cir	Winthorthing Cir	1255	N	3.45	0.56	5.29	No	Yes	229.21
Sheffield Dr	Parkside Ave	Parkside Ave	1559	N/A	2.03	0.76	4.98	No	Yes	1624.61

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Evelyn Lane	Wildwood Avenue	Wildwood Avenue	241	N/A	1.75	0.75	4.94	Yes	Yes	685.67
Standish Avenue	Washington Street	Park Avenue	339	E	1.45	0.46	5.81	Yes	Yes	160.15
Forest Street	Daniel Road	Angela Road	340	E	2.08	1.28	4.01	No	Yes	295.57
Wildwood Avenue	84 Wildwood Avenue	Evelyn Lane	196	N	2.91	0.42	5.25	No	Yes	1143.81
Louise Rd	Lisle St	Lisle St	1025	N/A	0.90	0.43	5.32	Yes	Yes	883.18
Alden Road	Brewster Avenue	Bradford Road	242	W	1.32	0.88	5.05	Yes	Yes	236.25
Alden Road	Brewster Avenue	Bradford Road	243	N	1.05	0.69	5.17	Yes	Yes	235.75
Francine Rd	Nicholas Rd	Joseph Rd	1234	E	1.59	0.85	5.75	Yes	Yes	228.59
Liberty St	Pond Meadows Park	Bunker Corner Ln	916	E	1.14	0.45	4.65	Yes	Yes	1274.85
Lakeview Ave	Ray Ln	Tremont St	930	N	2.61	0.65	4.78	No	Yes	317.96
Sumner Ave	Hollingsworth Ave	Elmwood Ave	940	W	0.90	0.42	5.87	Yes	Yes	527.37
Elmwood Ave	Ray Ln	Tremont St	942	S	1.92	0.51	5.67	Yes	Yes	417.47
Kendall Ave	E. Boscobel St	20 Kendall Ave	763	E	2.77	0.84	3.22	No	No	434.37
Webb St/Boscobel St	Stevens Ave	54 Boscobel St	765	N/A	0.91	1.19	4.47	Yes	Yes	339.98
Olofson Street	Mann Street	Wildwood Avenue	221	E	0.68	0.62	5.39	Yes	Yes	471.70
Mann Street	Wildwood Avenue	Bramblewood Lane	223	W	0.89	0.60	4.29	Yes	Yes	292.95
Richard Road	Celia Road	176 Richard Road	432	E	1.77	0.48	5.35	Yes	Yes	594.88
Bradford Road	Milton Road	Alden Road	230	N	1.75	0.95	4.7	Yes	Yes	1038.47
Court Road	Cranmore Road	Cain Avenue	233	S	2.50	0.66	4.66	No	Yes	287.55
Cain Avenue	Court Road	Belknap Road	234	W	2.60	0.76	6.13	No	Yes	1274.61
Washington Street	20ft from Waldron Road	Foster Road	235	W	2.08	0.32	5.98	No	Yes	241.72
Court Road	Alden Road	Cain Avenue	237	N	1.43	0.75	5.16	Yes	Yes	413.38
Washington Street	20ft from Hill View Road	Waldron Road	246	W	1.98	0.46	6.26	Yes	Yes	252.98
Fountain St	Columbus Ave	Boscobel St	766	E	4.08	0.74	3.1	No	No	209.99
Boscobel St	Fountain St	End	767	S	2.39	0.80	4.83	No	Yes	564.07
Alden Road	Bradford Road	Court Road	229	S	2.32	0.78	5.54	No	Yes	257.31
Alden Road	Bradford Road	Court Road	231	N	1.59	0.58	4.99	Yes	Yes	257.15
Stevens Ave	Webb St	Pearl St	768	E	2.26	1.40	4.74	No	Yes	412.91
Kendall Ave	E. Boscobel St	Pearl St	769	W	0.80	0.76	5.32	Yes	Yes	641.39
Washington Street	Franklin St	Tremont St	772	N	1.18	0.52	5.72	Yes	Yes	188.36
Congress St	Spring St	Spring St	773	W	1.14	0.80	4.58	Yes	Yes	1129.69
Hancock St	Pearl St	Thayer Ave	780	E	1.23	0.80	5.71	Yes	Yes	225.81
Crescent Ave	Pearl St	Thayer Ave	781	W	2.29	0.53	5.14	No	Yes	212.11
Cherry Ln	Strathdee Cir	Abby Rd	783	E	2.96	1.37	4.13	No	Yes	773.78
Pearl St	Pearl St @ Washington St Bus Stop	Randall Ave	784	N	0.66	0.25	4.83	Yes	Yes	385.86
Cherry Ln	Surry Ln	Abby Rd	785	W	3.17	1.20	3.69	No	No	957.08
Proctor Road	Trainer Drive	1107 Liberty Street	247	N	1.53	0.34	5.87	Yes	Yes	172.81
Arbutus Avenue	Massachusetts Avenue	Standish Avenue	280	S	0.95	0.54	5.1	Yes	Yes	213.65
Wildwood Avenue	Sheraton Avenue	Bradford Road	294	W	2.10	0.51	5.53	No	Yes	773.53
Wildwood Avenue	Sheraton Avenue	84 Wildwood Avenue	295	E	1.38	0.38	4.98	Yes	Yes	789.70
Old Coach Road	Saint Lawrence Street	Forest Street	373	N	1.77	1.11	5.04	Yes	Yes	813.20
Victoria Ave	Fountain St	End	791	S	2.57	0.90	5.23	No	Yes	442.73
French Ave	French Ave	Pearl St	807	E	1.97	0.59	5.58	Yes	Yes	316.63
Randall Ave	Randall Ave	Pearl St	809	W	0.70	0.26	6.25	Yes	Yes	123.65
Surry Ln	Cherry Ln	Cherry Ln	814	N/A	2.66	1.27	4.08	No	Yes	487.09
Liberty St	Pearl Place Exit Road	Liberty St	815	W	1.11	1.01	4.15	Yes	Yes	525.53
Summer St	Tremont St	Washington St	846	S	1.07	0.33	5.84	Yes	Yes	490.33
Cherry Ln	Surry Ln	Pearl St	818	W	0.70	1.15	4.35	Yes	Yes	100.22
Washington Street	Summer St	Washington St	820	W	1.05	0.58	6.43	Yes	Yes	420.43
Fountain St	Victoria Ave	Pearl St	823	W	3.43	0.69	5.44	No	Yes	224.00
Pearl St	Crawford St	Crawford Rd	828	N	3.04	0.83	5.16	No	Yes	507.90
Pearl St	Kendall Ave	Cherry Ln	831	S	1.56	0.92	5.75	Yes	Yes	1193.04
Tremont St	Summer St	Washington St	833	W	0.92	0.40	6.1	Yes	Yes	502.84
Tremont St	Summer St	Washington St	834	E	1.12	0.46	5.41	Yes	Yes	497.55
Summer St	Franklin St	Tremont St	839	N	2.29	0.50	5.04	No	Yes	174.06
Pearl St	Hammett Pl	Fountain St	840	S	1.75	1.06	5.52	Yes	Yes	464.99
Pearl St	John W. Mahar Hwy	Hammett Pl	844	S	1.30	1.19	4.02	Yes	Yes	315.09
French Ave	Meadowbrook Rd	Holbrook Ave	849	W	1.69	0.48	5.47	Yes	Yes	226.10
Pearl St	96 Pearl St	92 Pearl St	802	S	2.33	0.66	5.33	No	Yes	335.56
Pearl St	351 Pearl St	419 Pearl St	803	N	1.48	1.13	5.45	Yes	Yes	973.71

**Braintree, MA - Cross Slope + Width Assessment  
2018**

French Ave	Washington Park Rd	French Ave	850	E	1.08	0.65	6.15	Yes	Yes	873.73
Tenney Rd	Driveway of 10 Meadowbrook Rd	French Ave	852	S	1.91	0.89	5.12	Yes	Yes	168.86
Taylor St	Franklin St	Tremont St	857	S	1.22	0.48	5.26	Yes	Yes	246.41
Central Ave	Franklin St	Tremont St	874	S	3.24	0.70	5.38	No	Yes	366.56
French Ave	Meadowbrook Rd	Washington Park Rd	876	W	1.21	0.55	4.8	Yes	Yes	561.31
Washington Park Rd	Tenney Rd	French Ave	877	S	1.96	0.62	5.39	Yes	Yes	158.48
Washington Park Rd	Tenney Rd	French Ave	878	N	1.99	0.63	6.02	Yes	Yes	155.68
Middle St	Woodland Rd	Liberty St Rotary Entrance	879	E	1.65	0.63	5.81	Yes	Yes	711.65
Middle St	639 Middle St	Pearl Pl Rotary Exit	880	W	1.78	0.62	4.65	Yes	Yes	634.48
Gilbert L. Bean Dr	Washington St	Thayer Public Library Exit Road	884	S	0.75	0.62	6.09	Yes	Yes	107.63
Central Ave	Franklin St	Tremont St	886	N	2.65	0.65	5.42	No	Yes	367.37
Washington Street	Central St	JFK Memorial Dr	900	W	2.44	0.61	5.61	No	Yes	527.45
Eileen Dr	Andrea Dr	17 Eileen Dr	901	N/A	1.48	0.55	6.05	Yes	Yes	694.03
Union Pl	Washington St	Tenney Rd	902	S	0.92	0.48	6.15	Yes	Yes	249.22
French Ave	Washington Park Rd	Union Pl	904	W	1.33	0.54	5.08	Yes	Yes	762.59
Middle St	581 Middle St	Apartment Entrance Road	905	W	1.56	0.79	5.41	Yes	Yes	240.22
Azel Rd	Lakeview Ave	35 Azel Rd	906	E	1.66	0.55	5.16	Yes	Yes	420.88
Lakeview Ave	Franklin St	Sumner Ave	908	N	1.81	0.53	5.64	Yes	Yes	264.35
French Ave	Washington Park Rd	Union Pl	914	E	0.74	0.70	5.73	Yes	Yes	810.11
Helen Rd	Doris Rd	79 Helen Rd	935	W	0.68	0.57	4.28	Yes	Yes	408.49
Doris Rd	Middle St	Helen Rd	936	N	0.98	0.59	5.14	Yes	Yes	901.34
Ray Ln	39 Ray Ln	29 Elmwood Ave	937	N	1.68	0.55	5.08	Yes	Yes	297.53
Tremont St	Hobart Ave	Lakeview Ave	943	W	2.63	0.51	5.54	No	Yes	254.28
Grossman Dr	Union St	111 Grossman Dr	949	E	2.44	0.61	5.57	No	Yes	676.39
Helen Rd	Hazel Ct	Doris Rd	950	W	1.01	0.53	5.21	Yes	Yes	261.42
Helen Rd	Doris Rd	Norfolk Rd	951	E	1.19	0.59	3.4	Yes	No	538.81
Union St	Grossman Dr	70ft to Union St Exit Ramp	953	N	1.44	0.53	5.12	Yes	Yes	343.01
Middle St	Norfolk Rd	Doris Rd	954	E	2.18	0.86	5.26	No	Yes	628.15
Kensington St	126 Kensington St	Kirby St	955	E	1.24	0.37	5.1	Yes	Yes	421.48
Norfolk Rd	Helen Rd	Liberty St	960	N	0.98	0.43	5.22	Yes	Yes	486.27
Norfolk Rd	Middle St	Helen Rd	963	N	1.02	0.35	5.6	Yes	Yes	992.74
Academy St	Hollingsworth Ave	Tremont St	965	N	2.32	0.72	4.69	No	Yes	413.37
Academy St	Hollingsworth Ave	Tremont St	966	S	2.24	0.54	5.09	No	Yes	499.98
Kirby St	Logan Dr	Kensington St	967	W	0.79	0.31	4.75	Yes	Yes	216.73
Kirby St	Logan Dr	Kensington St	968	E	1.42	0.39	5.7	Yes	Yes	209.18
Helen Rd	Norfolk Rd	Louise Rd	975	E	0.68	0.49	5.78	Yes	Yes	418.33
Louise Rd	Helen Rd	Liberty St	976	S	1.35	0.43	5.1	Yes	Yes	416.28
Logan Dr	Kirby St	Kensington St	977	S	2.47	0.77	5.88	No	Yes	443.96
Kensington St	Kirby St	Logan Dr	978	N	1.15	0.37	6.06	Yes	Yes	797.11
Grossman Dr	117 Grossman Dr	143 Grossman Dr	969	W	1.99	0.46	6.13	Yes	Yes	459.05
Kensington St	Kirby St	Logan Dr	980	S	1.55	0.37	5.65	Yes	Yes	854.82
Union St	Union St Rotary @ Pilgrim Highway Exit	Union St Rotary @ Pilgram Highway Entrance	983	N	2.72	0.63	4.68	No	Yes	323.72
Logan Dr	Kensington St	Middle St	994	S	1.22	0.69	5.25	Yes	Yes	298.54
Liberty St	Louise Rd	Miller Ave	996	W	0.80	0.49	5.2	Yes	Yes	2352.64
Union St	Williams Ct	Logan Dr	997	S	0.71	0.55	6.14	Yes	Yes	228.55
Logan Dr	Union St	Kirby St	998	W	2.07	0.68	5.95	No	Yes	565.04
Union St	Logan Dr	Middle St	1000	S	0.69	0.52	5.76	Yes	Yes	983.57
Middle St	Union St	Logan Dr	1003	W	1.50	0.63	5.3	Yes	Yes	518.89
Winslow Rd	Bradley Rd Ext	Union St	1008	W	1.37	0.79	5.92	Yes	Yes	210.60
Winslow Rd	27 Winslow Rd	Union St	1009	E	1.53	0.82	3.95	Yes	No	381.99
John Paul Cir	Commercial St	70 John Paul Cir	2710	N	4.51	0.96	6.11	No	Yes	707.27
Howard St	Howard Ct	Skyline Dr Exit	2711	N	1.59	0.81	5.2	Yes	Yes	519.99
Commercial St	Quincy/Braintree Town Line	John Paul Cir	2713	W	2.55	1.27	5.56	No	Yes	731.72
Linda Road	Alida Road	Richard Road	446	N	1.28	0.43	4.98	Yes	Yes	1030.11
Shaw St	Howard St	Dewey Rd	2714	E	1.20	0.88	5.6	Yes	Yes	818.13
Howard St	Skyline Dr Entrance	Howard St	2715	N	0.78	0.60	4.62	Yes	Yes	121.70
Skyline Dr	35 Skyline Dr	Howard St	2717	E	0.76	0.59	5.1	Yes	Yes	337.16
Skyline Dr	Skyline Dr	50 Skyline Dr	2718	W	1.01	0.63	5.24	Yes	Yes	149.73
Skyline Dr	50 Skyline Dr	42 Skyline Dr	2719	W	0.94	0.60	6.05	Yes	Yes	165.95
Skyline Dr	55 Skyline Dr	35 Skyline Dr	2721	E	0.76	1.09	4.73	Yes	Yes	182.79

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Shaw St	133 Howard St	Shaw St	2722	E	1.34	0.78	6.27	Yes	Yes	455.52
Alida Road	46 Alida Road	70 Alida Road	481	W	1.77	0.81	5.73	Yes	Yes	302.93
Cross Road	76 Kimball Road	Kimball Road	457	S	0.97	0.51	4.68	Yes	Yes	110.58
Kimball Road	Cross Road	Richard Road	455	N	1.13	0.44	5.96	Yes	Yes	525.85
Howard St	141 W Howard St	Howard st	2720	W	1.00	0.75	4.81	Yes	Yes	462.34
Liberty Street	1107 Liberty Street	Hickory Road	456	N	1.96	0.58	5.12	Yes	Yes	1173.87
Washington Street	Peach Street	1450 Washington Street	458	E	1.50	0.68	5.37	Yes	Yes	912.70
Otoole Terrace	31 Otoole Terrace	Grove Street	460	W	2.21	0.61	5.35	No	Yes	422.84
Alida Road	Linda Road	Marjorie Road	461	E	2.27	0.68	4.48	No	Yes	266.66
Alida Road	Linda Road	46 Alida Road	463	W	1.62	0.99	3.81	Yes	No	283.71
Liberty Street	Forest Street	Sycamore Road	464	S	1.17	0.62	5.07	Yes	Yes	330.38
Washington Street	1450 Washington Street	Hancock Street	480	E	4.15	0.93	6.12	No	Yes	516.60
Grove Street	Liberty Street	462 Grove Street	482	N	2.37	0.67	5.67	No	Yes	1488.34
Hannah Niles Way/Grove St	Hemlock St	120 Hannah Niles Way	507	N/A	2.53	0.71	5.68	No	Yes	1935.26
Skyline Dr	30 Skyline Dr	Howard St	2723	W	1.24	0.87	6.1	Yes	Yes	299.94
Howard St	Quincy/Braintree Town Line	133 Howard St	2725	E	3.60	0.85	6.21	No	Yes	575.09
Commercial St	Magnolia St	Nickerson Rd	2778	N	2.22	0.61	5.7	No	Yes	732.39
Liberty Street	Liberty Street	1746 Liberty Street	20	N	0.95	0.79	4.76	Yes	Yes	1203.72
Holly Road	40 Holly Road	Hickory Road	56	W	1.26	0.64	4.35	Yes	Yes	583.84
Hickory Road	Hemlock Street	Holly Road	58	W	1.77	0.72	4.43	Yes	Yes	195.35
Hemlock Street	End	Grove Street	500	W	1.69	0.83	4.75	Yes	Yes	681.40
Hemlock Street	Hickory Road	Grove Street	505	E	2.48	1.01	4.2	No	Yes	309.48
Richard Road	Alida Road	Grace Road	488	W	1.92	0.61	5.36	Yes	Yes	274.34
Liberty Street	Liberty Street	Grove Street	489	E	1.61	0.67	6.17	Yes	Yes	148.46
Alida Road	Evergreen Avenue	Fern Road	490	S	3.63	0.71	6.1	No	Yes	443.89
Fern Road	Alida Road	Evergreen Avenue	491	S	3.22	0.60	5.57	No	Yes	489.31
Fern Road	Alida Road	Evergreen Avenue	492	N	1.78	0.70	5.89	Yes	Yes	464.67
Liberty St	Grove St	RR Bridge	508	W	2.24	1.41	4.2	No	Yes	866.88
Liberty Park Avenue	Wildwood Ave	End	203	E	1.24	0.57	5.83	Yes	Yes	639.97
Ida Road	Pond Rd	Barstow Dr	524	S	2.76	0.78	5.03	No	Yes	305.99
Barstown Dr	50 Barstow Road	40 McCue Drive	531	E	1.34	0.92	5.27	Yes	Yes	1030.66
Barstown Dr	Ida Rd	McCue Dr	559	N	1.85	1.12	5.97	Yes	Yes	487.59
Howle Rd	Acorn Cir	Acorn Cir	1242	N	3.51	0.57	5.24	No	Yes	497.95
Oak Ledge Drive	51 Oak Ledge Drive	Christina Drive	342	W	0.46	0.45	5.18	Yes	Yes	745.17
Peach Street	Moreland Avenue	Liberty Street	343	N	2.16	0.83	4.97	No	Yes	1220.16
Washington Street	Standish Avenue	1652 Washington Street	345	E	1.89	0.50	5.19	Yes	Yes	270.18
Helen Rd	Doris Rd	End	1527	E	1.86	0.72	4.01	Yes	Yes	440.64
Arthur St	Arborway Dr	Beechwood Rd	1341	W	2.93	0.90	5.63	No	Yes	482.83
Joseph Rd	Alfred Rd	Common St	1289	W	1.33	1.01	4.32	Yes	Yes	758.49
Liberty Park Ave	Wildwood Ave	End	1402	W	1.69	0.38	4.46	Yes	Yes	496.73
Vernon Street	Bellevue Avenue	End	347	E	1.27	0.68	5.26	Yes	Yes	246.12
Saint Lawrence Street	Saint Claire Street	Old Coach Road	344	N	2.02	0.93	6.04	No	Yes	373.65
Bellevue Avenue	Vernon Street	Phillips Street	348	S	1.11	0.65	4.86	Yes	Yes	209.38
Ida Road	Pond Rd	Barstow Dr	552	N	3.48	0.73	4.98	No	Yes	300.25
Bellevue Avenue	2 Bellevue Avenue	16 Bellevue Avenue	352	N	1.63	0.91	6.04	Yes	Yes	221.52
Summit Rige Dr	Cain Ave	End	1600	S	2.09	0.68	5.22	No	Yes	1250.14
Forest Street	150 Forest Street	Daniel Road	355	E	0.94	0.60	5.52	Yes	Yes	221.18
Forest Street	120 Forest Street	150 Forest Street	356	E	1.36	1.05	5.96	Yes	Yes	457.86
Livoli Avenue	Paul Street	82 Water Street	80	W	1.95	0.58	5.49	Yes	Yes	982.90
Milton Road	Washington Street	Virginia Road	157	W	2.70	0.73	5.15	No	Yes	1404.73
Forest Street	Winter Street	120 Forest Street	357	E	1.64	1.05	5.08	Yes	Yes	253.90
Mann Street	Wildwood Avenue	Olofson Street	188	E	1.29	0.65	5.88	Yes	Yes	733.49
Lunar Avenue	39 Lunar Avenue	7 Altair Avenue	551	N/A	2.53	0.94	6.02	No	Yes	1105.47
Altair Avenue	45 Oregon Avenue	8 Altair Avenue	576	N	2.23	0.82	5.31	No	Yes	394.30
Liberty Park Avenue	245 Wildwood Avenue	1523 Liberty Street	191	E	1.87	0.66	6.08	Yes	Yes	170.93
Armstrong Circle	522 Pond Street	78 Armstrong Circle	573	S	3.37	0.84	5.64	No	Yes	585.88
Christina Drive	1300 Liberty Street	Oak Ledge Drive	359	S	1.74	0.46	4.49	Yes	Yes	775.47
Candlewood Ln	Peach St	Peach St	1628	N/A	3.21	0.90	6	No	Yes	1690.24
Barstown Dr	15 Ida Road	101 Barstow Road	1645	W	2.42	0.80	5.77	No	Yes	627.56
St. Lawrence St	Old Coach Road	Forest Street	358	N	3.04	0.69	6.01	No	Yes	779.92

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Cranmore Rd	Belknap Rd	Court Rd	1612	S	1.20	0.69	5	Yes	Yes	857.81
Liberty Street	Proctor Road	20ft to Proctor Road	428	W	1.61	0.55	5.59	Yes	Yes	1182.99
Grove Street	Grove Circle	Grove Circle	579	S	1.58	0.98	5.39	Yes	Yes	238.03
Evergreen Avenue	Alida Road	Fern Road	475	N	2.81	0.73	4.83	No	Yes	1304.45
Grove Street	Hemlock Street	Liberty Street	506	S	2.39	0.61	5.39	No	Yes	770.73
Oregon Ave	Pine Ave	70 Oregon Ave	578	E	0.77	0.63	5.27	Yes	Yes	566.81
Solar Avenue	55 Solar Avenue	85 Solar Avenue	595	W	1.07	0.67	4.62	Yes	Yes	328.57
Altair Avenue	7 Altair Avenue	27 Altair Avenue	577	S	2.89	0.81	4.71	No	Yes	388.87
Washington Street	1209 Washington Street	1251 Washington Street	584	N	1.42	0.43	6.08	Yes	Yes	695.59
Liberty St	Poulos Rd	Plain St	626	E	0.79	0.79	5.49	Yes	Yes	747.19
Margaret Dr	Pond St	Pond St	627	N/A	2.46	0.98	5.16	No	Yes	2289.66
Washington Street	Bellevue Avenue	Cocheto Street	362	E	1.60	0.40	6.05	Yes	Yes	1422.14
Liberty Street	Oakden Avenue	269 Peach Street	363	W	1.77	0.57	6.07	Yes	Yes	1475.86
Grove Street	Hannah Niles Way	Hannah Niles Way	533	S	1.78	0.56	4.81	Yes	Yes	405.14
McCue Drive	Barstow Dr	Hingston Cir	547	E	1.78	0.78	5.91	Yes	Yes	356.50
McCue Drive	Barstow Dr	Barstow Dr	548	W	2.75	0.90	5.72	No	Yes	574.79
McCue Drive	Hingston Cir	End	557	E	1.37	1.03	5.55	Yes	Yes	258.16
Liberty Street	269 Peach Street	Peach Street	364	W	1.52	0.47	4.74	Yes	Yes	72.31
Messina Woods Drive	10 Jensen Farm Road	Messina Woods Drive	605	S	2.06	0.63	5.45	No	Yes	1215.93
Evergreen Avenue	Evergreen Avenue	Grove Circle	558	E	2.84	0.70	5.23	No	Yes	310.75
Liberty Street	Poulos Road	Messina Woods Drive	625	E	0.70	0.80	4.95	Yes	Yes	293.19
Boscobel St	Fountain St	End	631	N	4.18	0.76	5.68	No	Yes	562.58
Regis Rd	Pond St	Pond St	1651	N/A	1.65	0.58	5.71	Yes	Yes	2581.25
Liberty Street	Christina Drive	Michele Lane	366	E	2.33	0.59	5.15	No	Yes	1632.29
Solar Avenue	320 Pond Street	55 Solar Avenue	652	W	1.20	0.87	5.19	Yes	Yes	727.75
Solar Avenue	50 Solar Avenue	306 Pond Street	653	E	1.52	0.92	5.48	Yes	Yes	716.09
Wayne Avenue	70 Wayne Avenue	Logan Road	657	E	2.19	0.68	4.64	No	Yes	281.82
Sherman Road	26 Sherman Road	11 Wayne Avenue	692	S	3.67	1.99	3.1	No	No	354.78
St Michael Road	30 St Michael Road	25 Hoover Avenue	636	S	2.33	0.28	6.14	No	Yes	169.38
Washington Street	161 Hancock Street	1150 Washington Street	634	N/A	3.16	0.75	5.08	No	Yes	895.61
Washington Street	1142 Washington Street	1120 Washington Street	654	E	2.22	0.65	6.09	No	Yes	302.56
Washington Street	Jefferson St	Hancock St	635	W	2.38	0.76	5.28	No	Yes	817.22
Hancock St	Hancock Ave	Plain St	638	E	1.39	0.60	6.95	Yes	Yes	576.59
Commercial St	Taber Ct	229 Commercial St	639	N	1.67	0.43	5.09	Yes	Yes	55.47
Jefferson St	Shepard Rd	Washington St	647	S	2.56	0.83	5.11	No	Yes	596.23
Cardinal Court	Oakden Avenue	Peach Street	367	E	2.85	1.02	5.43	No	Yes	1667.81
Peach Street	Cardinal Court	Liberty Street	368	S	2.40	0.82	5.93	No	Yes	688.44
Cardinal Court	Oakden Avenue	Peach Street	370	W	2.64	0.96	5.18	No	Yes	1709.30
Old Coach Road	Saint Lawrence Street	Forest Street	371	S	1.61	1.07	5.65	Yes	Yes	766.01
Forest Street	Old Coach Road	Saint Lawrence Street	372	W	1.54	0.96	5.78	Yes	Yes	422.30
Geraldine Lane	Michele Lane	Geraldine Lane	374	N/A	2.43	0.94	5.11	No	Yes	460.59
Royal Lake Drive	18 Royal Lake Drive	Sidewalk End	787	S	0.65	0.49	4.84	Yes	Yes	375.82
Daniel Road	Forest Street	Winter Street	375	W	1.98	0.87	4.76	Yes	Yes	752.70
Daniel Road	Forest Street	Birch Street	378	E	1.41	0.76	5.45	Yes	Yes	1029.67
Graziano	244 Pond Street	73 Kelley Drive	679	S	1.49	1.09	6.04	Yes	Yes	896.78
Graziano	72 Graziano Drive	10 Graziano Drive	682	N	2.36	1.05	5.36	No	Yes	745.28
Wayne Avenue	Logan Road	22 Wayne Avenue	667	E	2.38	0.58	5.08	No	Yes	384.52
Butler Road	11 Wayne Avenue	23 Butler Road	681	N	2.58	0.94	6.14	No	Yes	454.96
Fairview Avenue	3 Fairview Avenue	21 Fairview Avenue	685	W	3.59	0.82	5.18	No	Yes	582.34
Winter Street	Forest Street	Daniel Road	379	S	2.06	0.56	5.25	No	Yes	671.26
Liberty Street	Peach Street	Kenmore Road	380	W	0.99	0.61	6.06	Yes	Yes	532.36
Forest Street	Saint Claire Street	Old Coach Road	381	W	1.49	0.81	6.05	Yes	Yes	344.44
Winter Street	Forest Street	Daniel Road	382	N	1.04	0.72	4.5	Yes	Yes	692.98
Peach Street	Phyllis Avenue	Moreland Avenue	384	N	1.98	0.84	5.36	Yes	Yes	599.91
Washington Street	Pond St	Jefferson St	695	W	2.38	0.64	6.01	No	Yes	641.99
Saint Claire Street	Saint Lawrence Street	Forest Street	385	S	0.94	1.07	6.02	Yes	Yes	1037.29
Congress St	Kendall Ave	Spring St	707	N	2.09	0.79	3.72	No	No	457.94
Birch Street	Daniel Road	Angela Road	387	S	1.84	1.96	3.77	Yes	No	331.97
Glendale Road	14 Porter Avenue	225 Pond Street	710	W	1.95	0.72	5.19	Yes	Yes	225.94
Wayne Avenue	178 Pond Street	178 Pond Street	705	W	2.16	0.57	4.73	No	Yes	89.49

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Congress St	130 Congress St	Spring St	694	E	2.69	0.88	4.43	No	Yes	1001.49
Washington Street	1102 Washington Street	1074 Washington Street	696	E	2.03	0.62	5.75	No	Yes	642.04
Liberty Street	Kenmore Road	Proctor Road	386	W	1.11	1.34	4.31	Yes	Yes	70.84
Evergreen Avenue	Evergreen Avenue	Grove Circle	560	W	1.64	0.62	4.67	Yes	Yes	359.27
Frederick Rd	Washington St	Hancock St	712	S	1.28	0.40	6.05	Yes	Yes	627.65
Frederick Rd	Washington St	Hancock St	715	N	2.33	0.49	5.86	No	Yes	587.00
Abby Rd	Old Valley Rd	Cherry Ln	721	W	3.50	1.31	4.2	No	Yes	211.73
Washington Street	Pond St	1021 Washington St	716	W	2.17	0.76	5.49	No	Yes	708.50
Fountain St	Sagamore St	Columbus Ave	747	W	2.17	0.65	4.88	No	Yes	201.36
Saint Claire Street	85 Saint Claire Street	Forest Street	388	N	1.55	1.00	6.16	Yes	Yes	1062.68
Kenmore Road	18 Kenmore Road	Liberty Street	390	S	1.61	0.48	6.09	Yes	Yes	264.51
Poulos Rd	Liberty St	Liberty St	1654	N/A	2.01	0.67	5.2	No	Yes	1858.66
Grove Circle	Evergreen Avenue	Grove Street	561	E	3.67	0.95	4.81	No	Yes	549.28
Kenmore Road	End	18 Kenmore Road	391	S	1.19	0.50	5.09	Yes	Yes	157.96
Sunset Road	143 Pond Street	19 Sunset Road	746	E	4.43	0.36	5.6	No	Yes	282.90
Tower Hill Road	68 Tower Hill Road	8 Tower Hill Road	735	W	1.47	0.84	4.71	Yes	Yes	878.37
Washington Street	1060 Washington Street	1050 Washington Street	730	E	2.10	0.62	5.33	No	Yes	323.43
Washington Street	1030 Washington Street	1010 Washington Street	757	E	1.36	0.65	5.34	Yes	Yes	256.54
Spring St	Congress St	E. Boscobel St	727	W	1.97	0.82	3.9	Yes	No	319.91
Hancock St	Hall Ave	Frederick Rd	728	W	1.36	0.56	4.66	Yes	Yes	185.52
Kendall Ave	Congress St	E. Boscobel St	732	E	2.28	0.67	5.55	No	Yes	330.99
E. Boscobel St	Kendall Ave	Spring St	733	S	2.10	0.86	3.84	No	No	378.51
E. Boscobel St	Kendall Ave	Spring St	736	N	1.97	0.79	3.98	Yes	No	372.20
Webb St/Boscobel St	Stevens Ave	Kendall Ave	751	N/A	1.06	1.14	3.78	Yes	No	514.06
McCusker Dr	30 McCusker Dr	20 McCusker Dr	1570	N	1.20	0.64	4.68	Yes	Yes	399.08
Peach Street	Kimball Road	Phyllis Avenue	393	N	2.02	0.95	4.84	No	Yes	603.67
McCusker Dr	42 McCusker Dr	46 McCusker Dr	1571	S	2.43	0.58	5.28	No	Yes	421.69
McCusker Dr	56 McCusker Dr	56 McCusker Dr	1573	S	1.86	0.53	5.09	Yes	Yes	79.45
Emerald Avenue	5 Emerald Avenue	35 Emerald Avenue	790	S	1.89	0.60	4.96	Yes	Yes	489.27
Washington Street	1010 Washington Street	974 Washington Street	764	S	0.74	0.52	6.5	Yes	Yes	382.93
Tremont St	Weston Ave	West St	2155	E	0.70	0.50	4.05	Yes	Yes	860.01
Tremont St	320 Termont St	352 Tremont St	2156	W	0.46	0.53	5.79	Yes	Yes	404.49
Victoria Ave	Fountain St	End	795	N	2.54	0.81	3.6	No	No	443.87
Pearl St	Stevens Ave	Kendall Ave	797	S	0.54	0.79	4.53	Yes	Yes	181.33
Pearl St	Cherry Ln	Liberty St	799	S	1.35	0.79	3.91	Yes	No	579.84
Kenmore Road	Amherst Road	Liberty Street	395	N	1.59	0.41	5.56	Yes	Yes	261.12
Congress St	Spring St	17 Congress St	800	W	1.79	0.84	4.44	Yes	Yes	244.26
Peach Street	20ft from Arlington Avenue	Candlewood Lane	396	S	4.25	0.82	5.4	No	Yes	991.72
Pearl St	Fountain St	Stevens Ave	801	S	1.61	0.92	4.65	Yes	Yes	860.20
Strathdee Cir	Cherry Ln	Cherry Ln	1667	N/A	2.37	1.04	4.55	No	Yes	666.83
Woodland Rd	Middle St	Middle St	1681	N/A	1.20	1.50	4.49	Yes	Yes	1242.25
Emerald Avenue	16 Emerald Avenue	6 Emerald Avenue	813	N	1.93	0.54	5.85	Yes	Yes	262.64
Washington Street	928 Washington Street	908 Washington Street	819	E	0.68	0.59	6.09	Yes	Yes	275.42
Andersen Rd	Granite St	Granite St	1693	N/A	1.20	0.87	4.54	Yes	Yes	1841.25
Birch Street	Forest Street	Grove Street	394	N	1.35	0.75	5.9	Yes	Yes	2710.63
Grove Circle	Grove Street	Grove Street	570	N/A	1.33	0.70	4.81	Yes	Yes	1093.35
Liberty St	Liberty St	Lenox St	816	E	1.04	1.15	4.87	Yes	Yes	675.93
Cherry Ln	Strathdee Cir	Pearl St	806	E	2.89	1.45	3.76	No	No	234.49
Moreland Avenue	Peach Street	Celia Road	397	E	2.70	0.50	4.67	No	Yes	334.52
Celia Road	Moreland Avenue	129 Celia Road	398	S	2.81	0.50	5.41	No	Yes	327.82
Summer St	Safford St	Franklin St	824	S	3.03	1.00	5.12	No	Yes	177.89
Safford St	37 Safford St	Franklin St	829	N/A	1.32	0.47	5.11	Yes	Yes	602.80
Holbrook Ave	Washington St	French Ave	830	N	1.79	0.75	4.75	Yes	Yes	572.70
Summer St	Franklin St	Tremont St	832	S	0.88	0.33	4.96	Yes	Yes	174.57
Geraldine Lane	Michele Lane	74 Geraldine Lane	403	N	2.17	1.11	5.97	No	Yes	716.70
Moreland Avenue	Peach Street	Celia Road	399	W	2.02	0.50	5.7	No	Yes	331.93
Celia Road	Moreland Avenue	126 Celia Road	400	N	2.56	0.45	4.71	No	Yes	327.56
Phyllis Avenue	Peach Street	Celia Road	404	E	2.17	0.57	5.88	No	Yes	313.09
John W. Mahar Hwy	Pearl St	542 John W. Mahar Highway	836	W	1.29	0.76	5.34	Yes	Yes	1073.39
Grossman Dr	143 Grossman Dr	250 Grossman Dr	987	W	2.04	0.56	6.16	No	Yes	444.58

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Granite Street	536 Granite Street	Rossway St	1043	E	1.99	0.79	5.73	Yes	Yes	649.16
Granite Street	South Shore Plaza Rd	536 Granite Street	1078	E	2.18	0.61	5.2	No	Yes	1667.50
Grandview Road	Forbes Rd	100 Grandview Road	1162	E	1.39	0.64	5.67	Yes	Yes	554.63
Granite Street	On-Ramp	250 Granite Street	1207	E	1.89	0.70	4.75	Yes	Yes	210.51
Marcia Rd	Worthington Cir	Marcia Rd	1275	N	2.76	0.78	3.89	No	No	314.41
Celia Road	Phyllis Avenue	Moreland Avenue	405	S	2.58	0.44	4.84	No	Yes	617.19
Phyllis Avenue	Peach Street	Celia Road	407	W	1.97	0.33	6.01	Yes	Yes	315.11
Geraldine Ln	27 Geraldine Ln	79 Geraldine Ln	1368	S	2.83	1.11	5.88	No	Yes	758.96
Stafford St	37 Safford St	Franklin St	859	S	2.05	0.41	5.35	No	Yes	225.70
Liberty St	Liberty Street Rotary Exit	Pond Meadows Park	868	S	1.75	0.46	5.08	Yes	Yes	642.07
Walnut Ave	67 Walnut Ave	Weymouth Town Line	1040	N	2.28	0.56	4.49	No	Yes	472.77
Town Street	732 Granite Street	5 Cameo Road	865	W	1.17	0.46	5.4	Yes	Yes	1220.80
Town Street	128 Town Street	128 Town Street	881	E	1.24	0.38	4.39	Yes	Yes	235.70
Granite Street	Off-Ramp SB	On-Ramp NB	1531	W	1.42	0.67	5.21	Yes	Yes	31.57
Franklin Street	83 Franklin Street	99 Franklin Street	863	E	1.86	0.91	6.05	Yes	Yes	326.71
Washington Street	856 Washington Street	798 Washington Street	883	E	1.08	0.48	5.25	Yes	Yes	844.60
Franklin Street	188 Franklin Street	94 Franklin Street	871	W	1.84	0.81	5.7	Yes	Yes	1198.24
Franklin Street	121 Central Avenue	123 Franklin Street	887	E	2.79	0.74	5.91	No	Yes	275.98
Granite Street	Off-Ramp	On-Ramp	1533	E	1.44	0.81	6.08	Yes	Yes	48.99
Granite Street	4 Granite Street	2 Adams Place	1547	W	1.15	0.67	5.44	Yes	Yes	371.39
Forbes Road	140ft W Grandview Rd	Grandview Rd	1551	S	1.74	0.65	5.73	Yes	Yes	140.36
Liberty St	Louise Rd	Louise Rd	1562	W	1.01	0.49	4.84	Yes	Yes	254.38
McCusker Dr	2 McCusker Dr	Union St	1565	E	0.88	0.39	5.3	Yes	Yes	309.83
McCusker Dr	5/7 McCusker Dr	Union St	1566	W	1.28	0.42	5.87	Yes	Yes	299.14
McCusker Dr	56 McCusker Dr	2 McCusker Dr	1567	E	0.58	0.34	5.72	Yes	Yes	43.85
McCusker Dr	56 McCusker Dr	28 McCusker Dr	1568	N	1.05	0.55	4.69	Yes	Yes	198.00
Washington Street	Taylor St	JFK Memorial Dr	873	W	1.55	0.60	5.23	Yes	Yes	200.86
Forest Street	Liberty Street	Saint Claire Street	409	W	1.22	0.90	5.45	Yes	Yes	1196.46
Elmwood Ave	Franklin St	Sumner Ave	917	N	1.27	0.37	6.02	Yes	Yes	263.15
McCusker Dr	20 McCusker Dr	16 McCusker Dr	1569	N	1.54	0.59	5.12	Yes	Yes	133.19
Elmwood Ave	Franklin St	Sumner Ave	918	S	1.02	0.31	6.02	Yes	Yes	264.23
Sumner Ave	Elmwood Ave	30ft past 20 Sumner Ave	919	W	1.46	0.53	5.53	Yes	Yes	113.79
McCusker Dr	46 McCusker Dr	56 McCusker Dr	1572	S	1.78	0.56	5.4	Yes	Yes	49.39
Franklin Street	161 Franklin Street	175 Franklin Street	896	E	2.88	0.81	4.84	No	Yes	313.37
Washington Street	Sidewalk Island	Sidewalk Island	912	E	2.11	0.84	5.4	No	Yes	24.41
Gray Terr	Albee Dr	50 Gray Terrace	1593	E	3.40	0.65	4.79	No	Yes	643.71
Milton Rd	Virginia Rd	Cain Ave	1598	S	2.57	0.56	5.55	No	Yes	599.60
Livoli Ave	Paul St	Water St	1599	E	1.45	0.60	5.24	Yes	Yes	1060.97
Liberty St	Danielle Ln	Grove St	1639	E	1.70	1.45	5.85	Yes	Yes	1234.71
Evergreen Ave	Evergreen Ave	Fern Rd	1640	W	2.24	0.53	6.14	No	Yes	2153.27
Middle St	Doris Rd	Woodland Rd	889	E	1.61	0.75	4.68	Yes	Yes	926.06
Azel Rd	Marshfield Rd	Azel Rd	893	W	0.66	0.52	5.36	Yes	Yes	347.18
Marshfield Rd	Franklin St	Azel Rd	894	S	0.75	0.53	5.5	Yes	Yes	257.82
Marshfield Rd	Franklin St	Azel Rd	895	N	0.98	0.59	5.95	Yes	Yes	340.72
Sumner Ave	Elmwood Ave	Lakeview Ave	920	E	2.57	0.65	5.19	No	Yes	267.36
Lakeview Ave	Sumner Ave	Ray Ln	922	N	1.77	0.66	5.34	Yes	Yes	195.60
Elmwood Ave	Sumner Ave	Ray Ln	927	S	1.48	0.63	5.73	Yes	Yes	212.00
Doris Rd	Middle St	Andrea Dr	931	S	1.11	0.55	6.01	Yes	Yes	202.06
Grossman Dr	50ft from Union St	Grossman Dr	946	W	2.30	0.64	4.7	No	Yes	222.16
Fabiano Drive	5 Fabiano Drive	6 Rome Drive	1641	N/A	0.75	0.39	5.04	Yes	Yes	842.88
Hingston Circle	21 McCue Drive	31 McCue Drive	1644	N/A	2.09	0.94	5.89	No	Yes	634.22
Logan Dr	Union St	Middle St	1702	N	2.56	0.77	5.14	No	Yes	1337.24
Ivory St	Union St	Braintree Station Entrance (S Ivory St)	932	W	1.42	0.62	5.03	Yes	Yes	859.99
Doris Rd	Andrea Dr	Helen Rd	933	S	1.03	0.50	5.49	Yes	Yes	581.17
Grove Cir	Evergreen Ave	Grove St	1648	W	2.07	0.67	5.31	No	Yes	612.24
Liberty St	Lenox Dr	Plain St	1662	E	0.63	0.75	4.18	Yes	Yes	1288.86
Pearl St	170 Pearl St	Ivory St	812	N	1.91	0.66	5.7	Yes	Yes	571.18
Pearl St	165 Pearl St	John W. Mahar Highway	835	S	1.99	0.70	5.19	Yes	Yes	392.53
Birch Street	Forest Street	Daniel Road	410	S	0.89	0.65	5.22	Yes	Yes	977.71
Kensington St	135 Kensington St	Kirby St	956	W	0.81	0.34	5.97	Yes	Yes	444.60

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Tremont St	Academy St	Hobart Ave	957	W	1.71	0.48	4.02	Yes	Yes	295.50
Liberty St	Bunker Corner Ln	Louise Rd	958	E	1.28	0.47	6.02	Yes	Yes	1206.20
Norfolk Rd	Helen Rd	Liberty St	959	S	0.71	0.39	5.78	Yes	Yes	493.77
Liberty St	Louise Rd	Norfolk Rd	972	W	1.31	0.38	4.64	Yes	Yes	219.71
Mayflower Rd	Pilgrim Rd	Pilgrim Rd	1708	N/A	2.40	0.90	5.27	No	Yes	2848.04
Lisle St	Rosewood Dr	Louise Rd	1713	S	1.52	0.72	5.43	Yes	Yes	611.78
Connelly Circle	Lisle St	Lisle St	1717	N/A	2.58	0.88	4.7	No	Yes	1144.24
Franklin Street	377 Franklin Street	405 Franklin Street	974	N	1.14	0.56	6.11	Yes	Yes	422.69
Helen Rd	Norfolk Rd	Louise Rd	982	W	0.77	0.58	5.43	Yes	Yes	457.78
Celia Road	Kimball Road	Moreland Avenue	411	N	2.40	0.51	4.83	No	Yes	1229.17
Union St	Cleveland Ave	Winslow Rd	984	N	0.39	0.49	6.18	Yes	Yes	1287.10
Kimball Road	Peach Street	Carolyne Avenue	413	W	1.90	0.48	5.33	Yes	Yes	223.22
Kimball Road	Peach Street	Celia Road	414	E	1.56	0.38	5.84	Yes	Yes	276.04
Williams Ct	Union St	32 Williams Ct	989	E	1.20	0.35	5.39	Yes	Yes	710.59
Moreland Avenue	Celia Road	Richard Road	416	E	2.18	0.42	5.15	No	Yes	249.70
Franklin Street	400 Franklin Street	368 Franklin Street	990	S	1.21	0.56	6.14	Yes	Yes	545.58
West Street	550 Washington Street	290 West Street	1005	S	2.55	0.63	6.06	No	Yes	626.26
West Street	335 West Street	520 Granite Street	1006	N	2.31	0.79	5.21	No	Yes	392.83
Moreland Avenue	Celia Road	Richard Road	417	W	2.24	0.36	5.78	No	Yes	248.79
Peach St/Washington St	Cocheto St	Arlington Ave	412	S	2.17	0.56	6.18	No	Yes	481.81
Parkside Ave	Walnut St	Sheffield Dr	1741	N	2.60	0.45	5.39	No	Yes	1001.96
Shaw St	Mill Ln	59 Shaw St	1743	N	1.07	0.64	5.89	Yes	Yes	390.62
Joseph Rd	Alfred Rd	Common St	1755	E	1.54	0.96	4.41	Yes	Yes	768.88
Alfred Rd	Francine Rd	Joseph Rd	1746	S	1.30	1.18	4.79	Yes	Yes	774.27
Howie Rd	Walnut St	Acorn St	1745	S	3.31	0.61	5.45	No	Yes	1050.83
Edgemont Rd	57 Edgemont Rd	Quincy Ave	1339	N	3.64	0.93	5.85	No	Yes	654.75
Addison St	Eleanor Dr	West St	1015	W	2.30	0.99	4.7	No	Yes	654.23
Middle St	Union St	Lisle St	1012	E	0.81	0.59	5.18	Yes	Yes	226.74
Lisle St	Louise Rd	Robbie Rd	1020	W	1.32	0.48	5.27	Yes	Yes	741.22
Celia Road	Kimball Road	Phyllis Avenue	419	S	2.31	0.54	5.82	No	Yes	581.71
Carolyne Avenue	26 Carolyne Avenue	Kimball Road	421	S	1.49	0.49	5.15	Yes	Yes	320.48
Michele Lane	Liberty Street	Geraldine Lane	423	W	2.81	0.87	5.29	No	Yes	917.18
Liberty St	Whites Hill Dr	Lincoln St	1027	E	1.45	0.52	5.46	Yes	Yes	856.81
Middle St	Totnes Rd	Union St	1031	W	0.99	0.59	5.3	Yes	Yes	428.21
Addison St	Eleanor Dr	West St	1016	E	1.93	0.77	4.66	Yes	Yes	668.22
Union St	Middle St	Powder Hill Dr	1026	S	0.80	0.48	5.22	Yes	Yes	364.39
Powder Hill Dr	Union St	Robbie Rd	1037	E	0.70	0.40	5.15	Yes	Yes	1253.05
Louise Rd	Lisle Rd	Helen Rd	1007	W	1.40	0.41	5.88	Yes	Yes	756.01
Brow Ave	Academy St	School Lot	2086	E	0.86	0.50	4.67	Yes	Yes	237.43
Academy St	Tremont St	Brow Ave	2088	N	2.03	0.42	4.94	No	Yes	1092.29
Richard Road	Moreland Avenue	72 Richard Road	420	E	4.35	0.60	5.28	No	Yes	433.67
Bradley Rd Ex	Winslow Rd	End	1011	S	1.68	0.75	5.13	Yes	Yes	364.82
Academy St	Tremont St	77 Academy St	2089	S	1.15	0.42	6.17	Yes	Yes	735.65
Strathmore Rd	33 Strathmore Circle	33 Strathmore Circle	1052	E	1.44	0.43	3.72	Yes	No	63.46
Amherst Road	Kenmore Road	Portland Road	424	E	1.16	0.52	4.86	Yes	Yes	566.32
Davis Rd	Fallon Cir	Granite St	1072	S	2.38	0.53	6.09	No	Yes	103.76
Portland Road	Amherst Road	Proctor Road	425	S	1.15	0.52	5.73	Yes	Yes	216.57
Trefton Rd	Quincy Ave	Spencer St	1912	W	2.95	0.53	5.13	No	Yes	408.61
Sun Valley Drive	Robbie Road	133 Lisle Street	1080	N	1.40	0.82	6.14	Yes	Yes	725.36
Sun Valley Drive	Robbie Road	Lisle Street	1073	S	2.36	0.76	5.99	No	Yes	695.79
Lisle Street	6 Sun Valley Drive	Robbie Road	1074	W	1.07	0.54	5.55	Yes	Yes	730.57
Middle Street	20ft from Harrison Avenue	335 Middle Street	1069	W	1.10	0.60	5.68	Yes	Yes	311.32
Middle Street	314 Middle Street	340 Middle Street	1071	E	1.50	0.59	5.22	Yes	Yes	321.05
Strathmore Circle	30 Penniman Terrace	57 Strathmore Circle	1067	N	2.03	0.50	5.36	No	Yes	149.83
Union Street	1 Strathmore Road	15ft to Miller Street	1068	W	1.42	0.49	5.34	Yes	Yes	712.00
Union Street	Powder Hill Drive	Robbie Road	1066	E	0.90	0.50	5.12	Yes	Yes	992.92
Strathmore Circle	4 Strathmore Circle	26 Strathmore Circle	1063	W	0.75	0.39	3.58	Yes	No	422.88
Sterling Street	10ft from Sterling Park	39 Sterling Street	1059	N	1.40	0.57	5.37	Yes	Yes	403.56
Strathmore Circle	26 Strathmore Circle	4 Strathmore Circle	1062	E	1.22	0.36	5.2	Yes	Yes	287.68
Sterling Street	Elliot Street	10ft to Sterling Park	1060	N	1.58	0.56	5.55	Yes	Yes	234.06

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Elliot Street	89 Walnut Avenue	86 Sterling Street	1058	E	1.26	0.84	4.13	Yes	Yes	169.78
Strathmore Circle	25 Strathmore Circle	33 Strathmore Circle	1051	W	2.50	0.48	5.82	No	Yes	97.89
Middle Street	335 Middle Street	365 Middle Street	1053	W	1.18	0.60	5.31	Yes	Yes	279.47
Middle Street	340 Middle Street	Kew Road	1054	E	0.86	0.54	4.64	Yes	Yes	287.72
Michele Lane	Liberty Street	Geraldine Lane	426	E	2.23	1.13	5.77	No	Yes	914.47
Amherst Road	Kenmore Road	Portland Road	427	W	1.59	0.51	5.31	Yes	Yes	573.13
Portland Road	Amherst Road	Proctor Road	429	N	2.31	0.37	5.75	No	Yes	223.09
Robbie Road	521 Union Street	Powder Hill Drive	1084	W	0.71	0.56	4.56	Yes	Yes	269.18
Walnut Street	Hollis Avenue	Monatiquot Avenue	1087	E	1.54	0.47	5.68	Yes	Yes	303.59
Pilgrim Road	130 Mayflower Road	93 Stetson Street	1114	W	4.08	0.94	4.66	No	Yes	1756.39
Marshall Street	20ft from 60 Marshall Street	15ft from Hamilton Street	1111	N	4.06	0.55	5.45	No	Yes	428.35
Claremont Street	94 Liberty Street	27 Willard Street	1110	N	0.97	0.51	5.29	Yes	Yes	408.25
Marshall Street	Miller Street	30 Hamilton Street	1107	S	2.83	0.65	4.7	No	Yes	373.71
Hamilton Street	Marshall Street	22 Hamilton Street	1108	W	3.11	0.77	4.43	No	Yes	204.69
Stetson Street	112 Bellevue Road	25ft from Brookside Road	1105	E	1.47	0.58	4.77	Yes	Yes	224.28
Marshall Street	40 Marshall Street	60 Marshall Street	1103	N	4.76	0.54	5.67	No	Yes	331.45
Liberty Street	Lincoln Street	Claremont Street	1106	E	1.81	0.51	4.85	Yes	Yes	345.43
Claremont Street	Liberty Street	43 Claremont Street	1100	S	2.81	0.62	5.26	No	Yes	581.25
Claremont Street	28 Willard Street	30ft from Unnamed Road	1102	N	1.28	0.59	5.85	Yes	Yes	134.92
Marshall Street	Watson Street	Miller Street	1097	S	1.78	0.51	6.06	Yes	Yes	295.02
Watson Street	Marshall Street	56 Watson Street	1095	E	2.61	0.66	5.13	No	Yes	711.01
Marshall Street	26 Marshall Street	50ft from 40 Marshall Street	1096	N	3.26	0.50	5.12	No	Yes	115.15
Watson Street	33 Marshall Street	56 Watson Street	1093	W	3.01	0.59	4.53	No	Yes	768.95
Penniman Terrace	Marshall Street	Strathmore Circle	1091	E	1.17	0.45	5.57	Yes	Yes	444.34
Marshall Street	Penniman Terrace	Watson Street	1092	S	2.00	0.39	4.71	Yes	Yes	96.58
Stetson Street	40ft from Brookside Road	35ft to Elliot Street	1088	E	1.90	0.60	4.99	Yes	Yes	188.76
Miller Avenue	Liberty St	End	1127	S	1.24	0.58	5.1	Yes	Yes	399.78
Richard Road	176 Richard Road	Moreland Avenue	430	S	3.30	0.58	4.84	No	Yes	872.82
Kimball Road	Carolyne Avenue	32 Kimball Road	433	W	0.83	0.44	6.14	Yes	Yes	246.70
Liberty Street	Michele Lane	Forest Street	435	S	1.51	0.48	5.18	Yes	Yes	992.29
Sycamore Road	Thetford Avenue	80 Sycamore Road	436	N	1.60	0.56	4.72	Yes	Yes	416.40
Brookside Road	72 Brookside Road	13 Washington Street	1131	E	1.70	0.43	5.23	Yes	Yes	951.93
Lisle Street	140 Lisle Street	Liberty Street	1141	E	1.33	0.48	5.31	Yes	Yes	1697.10
Richard Road	Alida Road	Linda Road	431	N	2.93	0.58	5.11	No	Yes	1259.05
Walnut Street	Storrs Avenue	Hollis Avenue	1139	E	1.55	0.44	4.79	Yes	Yes	809.69
Liberty Street	Miller Avenue	Lisle Street	1133	W	1.26	0.47	5.37	Yes	Yes	256.10
Walnut Street	142 Walnut Street	124 Walnut Street	1150	W	2.29	0.50	4.19	No	Yes	369.86
Walnut Street	114 Walnut Street	211 Hollis Avenue	1137	W	1.74	0.49	4.17	Yes	Yes	811.06
Bellevue Road	Stetson Street	Hewmason Road	1148	W	3.78	0.78	5.71	No	Yes	1118.69
Walnut Street	Parkside Avenue	Storrs Avenue	1151	E	1.11	0.49	5.61	Yes	Yes	400.28
Alexander Road	Union Street	58 Alexander Road	1143	E	1.40	0.78	5.3	Yes	Yes	930.53
Liberty Street	Stetson Street	Atherton Street	1132	E	0.83	0.46	5.07	Yes	Yes	243.90
Stetson Street	Liberty Street	Faxon Street	1134	N	1.51	0.57	4.78	Yes	Yes	565.80
Atherton Street	Liberty Street	Willard Street	1123	N	0.61	0.47	4.57	Yes	Yes	424.12
Stetson Street	Faxon Street	98 Stetson Street	1125	N	1.27	0.54	4.64	Yes	Yes	614.37
Storrs Avenue	152 Parkside Avenue	124 Walnut Street	1140	N	2.95	0.65	4.65	No	Yes	172.07
Proctor Road	20ft from Doucette Drive	20ft to Doucette Drive	439	N	1.79	1.38	5.5	Yes	Yes	353.27
Alida Road	Richard Road	Linda Road	441	E	1.62	0.58	5.6	Yes	Yes	266.21
Howle Rd	Lakeside Dr	Acorn St	1181	N	3.82	0.59	4.66	No	Yes	1419.06
Brow Ave	Tremont St	School Lot	2097	N	1.41	0.51	5.69	Yes	Yes	1127.90
Bellevue Rd	Hewmason Rd	Commercial St	1188	E	3.70	0.80	5.21	No	Yes	270.52
Thetford Ave	Sycamore Rd	Sycamore Rd	440	N	1.28	0.65	6.13	Yes	Yes	1365.38
Quincy Ave	Commercial St Exit Road	Brookside Rd	1163	W	1.06	0.51	5.25	Yes	Yes	314.26
Union St	Alexander Rd	Jonas Perkins Park Path (Union St)	1164	S	0.59	0.53	5.98	Yes	Yes	1349.43
Quincy Ave	Wright Connector	Brookside Rd	1165	E	2.31	0.66	6.25	No	Yes	416.55
Union St	Jonas Perkins Park Path	Liberty St	1167	S	1.60	0.54	6.12	Yes	Yes	146.41
Common Street	250 Granite Street	End	1154	W	0.59	0.59	4.8	Yes	Yes	536.69
Lakeside Drive	48 Lakeside Dr	2 Lakeside Dr	1184	S	1.48	0.70	3.69	Yes	No	634.31
Monatiquot Ave	Ash St	Washington St	2191	S	1.55	0.66	5.59	Yes	Yes	533.67
Lakeside Drive	1 Lakeside Drive	25 Lakeside Drive	1186	N	1.16	0.85	4.38	Yes	Yes	518.40

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Walnut Street	162 Walnut Street	152 Walnut Street	1176	W	1.25	0.39	3.49	Yes	No	291.34
Walnut Street	Howie Road	Parkside Avenue	1178	E	2.39	0.49	3.55	No	No	373.69
Ash St	Monatiquot Ave	West St	2189	W	2.14	0.55	6.13	No	Yes	408.02
Ash St	Monatiquot Ave	West St	2190	E	1.10	0.57	5.6	Yes	Yes	395.28
Brookside Road	69 Brookside Road	Commercial Street	1156	W	1.81	0.39	5.31	Yes	Yes	976.45
Bellevue Rd	Hewmason Rd	Commercial St	1191	W	2.91	0.64	6.12	No	Yes	276.35
Prescott Ln	Commercial St	Hewmason Rd	1193	W	1.42	0.74	4.38	Yes	Yes	269.84
Parkside Ave	Walnut St	Sheffield Dr	1206	S	1.28	0.43	4	Yes	No	999.57
Alfred Rd	Francine Rd	64 Alfred Rd	1210	N/A	1.20	0.91	4.41	Yes	Yes	405.57
Shaw St	59 Shaw St	Commercial St	1212	N	0.89	0.51	5.54	Yes	Yes	762.99
Mill Ln	Commercial St	Shaw St	1213	E	1.90	1.56	3.79	Yes	No	518.60
Allen St	168 Allen St	Sheppard Ave	1221	S	1.89	0.75	4.77	Yes	Yes	252.73
Linda Road	Alida Road	Richard Road	442	S	1.56	1.20	3.93	Yes	No	1029.56
Allen St	Commercial St	196 Allen St	1208	S	2.94	0.52	5.95	No	Yes	496.76
Allen St	Hobart St	Sheppard Ave	1222	N	3.71	0.77	5.73	No	Yes	550.14
Joseph Rd/Francine Rd	Alfred Rd	Alfred Rd	1223	N	1.37	0.81	4.4	Yes	Yes	761.66
Alida Road	Richard Road	Linda Road	444	W	0.99	0.56	4.56	Yes	Yes	267.38
Portland Road	Amherst Road	Amherst Road	445	N	1.63	0.57	5.81	Yes	Yes	476.09
Richard Road	Linda Road	Marjorie Road	449	W	2.10	0.48	5.37	No	Yes	259.83
Walnut Street	14 Blake Road	1 Lakeside Drive	1217	W	1.43	0.80	4.58	Yes	Yes	696.45
Walnut Street	Francine Road	215 Walnut Street	1218	E	1.32	0.90	5.98	Yes	Yes	1047.29
Ash St	Hollis Ave	Monatiquot Ave	2210	W	1.62	0.54	5.96	Yes	Yes	341.33
Ash St	Hollis Ave	Monatiquot Ave	2211	E	1.09	0.46	5.34	Yes	Yes	478.94
Monatiquot Ave	Oak St	Ash St	2192	N	1.71	0.50	6.15	Yes	Yes	806.47
Monatiquot Ave	Ash St	Maple St	2193	N	1.32	0.49	5.21	Yes	Yes	401.26
Hollis Ave	Oak St	Ash St	2209	S	2.14	0.49	5.76	No	Yes	807.74
Sheppard Ave	25 Sheppard Ave	Allen St	1237	E	3.14	1.11	5.35	No	Yes	340.21
Birch Street	Angela Road	Grove Street	450	S	1.74	0.78	4.71	Yes	Yes	1356.02
Francine Rd	Walnut St	Alfred Rd	1224	W	1.41	0.93	4.11	Yes	Yes	692.00
Marjorie Road	Alida Road	Richard Road	451	S	2.99	0.52	4.77	No	Yes	1013.39
Marjorie Road	Alida Road	Richard Road	452	N	0.93	0.44	5.19	Yes	Yes	1007.57
Cleveland Ave	Putnam Ave	Townsend Ave	2213	E	1.33	0.38	4.86	Yes	Yes	287.86
Allen St	Sheppard Ave	134 Allen St	1225	S	1.72	0.83	5.93	Yes	Yes	99.13
Kimball Road	Cross Road	32 Kimball Road	453	S	0.44	0.47	4.7	Yes	Yes	541.81
Francine Road	22 Francine Road	228 Common Street	1245	E	2.19	0.95	5.16	No	Yes	351.27
Allen St	134 Allen St	Shaw St	1227	S	2.61	0.82	5.79	No	Yes	285.06
Shaw St	Allen St	Mill Lane	1229	E	1.64	0.75	5.95	Yes	Yes	234.76
Beechwood Rd	Quincy Ave	Arthur St	1332	N	4.11	1.16	4.55	No	Yes	341.00
Allen St	Sheppard Ave	Shaw St	1231	N	2.29	0.89	6.19	No	Yes	368.19
Middle St	Green House Way	Marshall St	2218	E	2.11	0.54	5.07	No	Yes	532.79
Wyman Rd	Clark St	Webster Rd	2222	W	4.01	0.58	5.18	No	Yes	476.43
Hollis Ave	Oak St	Cochato Rd	2212	N	2.02	0.50	4.67	No	Yes	548.24
Judson St	Oak St	End	2220	N	1.09	0.47	4.04	Yes	Yes	567.83
Putnam Ave	Cleveland Ave	End	2215	S	2.02	0.48	5.96	No	Yes	319.94
Oak St	Judson St	Hollis Ave	2216	W	1.35	0.56	4.32	Yes	Yes	226.18
Forest Street	Liberty Street	Birch Street	454	E	1.50	0.44	5.7	Yes	Yes	818.13
Sycamore Road	1024 Liberty Street	Thetford Avenue	466	E	1.86	0.61	4.69	Yes	Yes	521.31
Linda Road	Cross Road	Alida Rd	470	N	0.95	0.46	5.71	Yes	Yes	724.37
Shaw St	Haley Ave	Cedarcliff Rd	1263	W	2.35	1.10	4.73	No	Yes	169.69
Richard Road	22 Richard Road	46 Richard Road	468	E	1.82	0.70	4.96	Yes	Yes	327.18
Common Street	238 Common Street	230 Common Street	1261	S	1.22	0.83	4.68	Yes	Yes	292.14
Shaw St	Edgemont Rd	159 Shaw St	1268	E	2.12	0.66	5.15	No	Yes	84.76
Shaw St	Edgemont Rd	159 Shaw St	1269	W	1.42	0.73	5.7	Yes	Yes	82.47
Cross Road	Kimball Road	Linda Road	467	S	0.85	0.50	5.95	Yes	Yes	266.83
Cross Road	74 Cross Road	82 Cross Road	471	N	0.82	0.55	3.81	Yes	No	126.33
Worthington Cir	Common St	Howie Rd	1271	W	2.90	0.90	4.42	No	Yes	590.89
Liberty Street	Hickory Road	Grove Street	483	W	1.90	1.51	3.66	Yes	No	354.80
Marcia Rd	Worthington Circle	Marcia Rd	1265	S	1.56	1.18	5.7	Yes	Yes	234.47
Worthington Cir	Marcia Rd	Common St	1281	N	3.15	1.02	5.13	No	Yes	300.00
Crawford St	Pearl St	11 Crawford St	1421	W	2.79	0.60	4.23	No	Yes	35.10

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Edgemont Rd	Shaws St	114 Edgemont Rd	1280	S	3.01	2.12	2.91	No	No	321.42
Edgemont Rd	111 Edgemont Rd	101 Edgemont Rd	1286	N	2.24	1.54	3.38	No	No	112.03
Shaw St	159 Shaw St	Cedarcliff Rd	1266	E	2.24	1.08	5.91	No	Yes	164.73
Nicholas Rd	Francine Rd	Common St	1277	N	1.15	0.99	5.4	Yes	Yes	822.05
Trainor Drive	Proctor Road	53 Trainor Drive	484	E	1.45	0.54	5.56	Yes	Yes	682.17
Alida Road	142 Alida Road	166 Alida Road	485	N	1.09	0.66	5.92	Yes	Yes	325.72
Alida Road	Richard Road	Evergreen Avenue	487	S	2.85	0.72	4.82	No	Yes	297.60
Saint Claire Street	167 St Claire Street	McAndrew Road	307	W	1.40	0.74	6.09	Yes	Yes	455.82
Edgemont Rd	98 Edgemont Rd	52 Edgemont Rd	1310	S	1.74	0.87	5.42	Yes	Yes	631.21
Worthington Cir	Common St	Marcia Rd	1299	E	3.28	0.70	5.9	No	Yes	298.32
Arthur St	Edgehill Rd	Gordon Rd	1320	E	3.10	0.63	4.1	No	Yes	220.60
Brickford Rd	Newton St	60 Bickford Rd	1312	S	1.89	0.54	5.64	Yes	Yes	527.75
Marisa Dr	Wildwood Ave	End	311	W	2.35	0.64	4.66	No	Yes	973.83
Common Street	138 Common Street	132 Common Street	1298	S	2.55	0.50	4.2	No	Yes	186.96
Common Street	122 Common Street	68 Common Street	1296	S	1.86	0.61	4.51	Yes	Yes	705.33
Richard Road	Alida Road	22 Richard Road	486	E	2.67	0.58	6.12	No	Yes	285.84
Shaw St	Sheppard Ave	Edgemont Rd	1303	W	2.63	0.81	5.18	No	Yes	448.73
Shaw St	Sheppard Ave	Edgemont Rd	1304	E	3.38	0.86	5.78	No	Yes	459.56
Arthur St	Beechwood Rd	Edgehill Rd	1331	W	2.59	0.84	4.08	No	Yes	232.12
Holly Rd	End	Hickory Rd	1382	E	2.80	0.71	5.38	No	Yes	412.20
Columbian St	6 Columbian St	Town Line	1366	W	1.47	0.93	5.59	Yes	Yes	198.91
Canavan Dr	Albee Dr	79 Canavan Dr	1370	S	2.74	0.67	5.44	No	Yes	318.21
Canavan Dr	Albee Dr	70 Canavan Dr	1371	N	2.08	0.76	6.2	No	Yes	330.79
Gray Terr	Albee Dr	29 Gray Terrace	1372	W	3.14	0.63	6	No	Yes	604.47
Primrose St	16 Primrose St	Arborway Dr	1360	W	3.88	0.80	5.13	No	Yes	248.10
O'Toole Terr	Grove St	30 O'Toole Terrace	1365	W	2.47	0.56	5.29	No	Yes	426.67
Beechwood Rd	Aurthur St	Argyle Rd	1344	N	3.33	0.89	4.57	No	Yes	573.62
Old Ledge Dr	Fox Hill Dr	End	1369	E	0.29	0.44	6.06	Yes	Yes	33.84
St. Claire St	167 St Claire St	End	1363	N	2.61	0.59	4.18	No	Yes	172.10
Walkway 1	Kenmore Rd	Proctor Rd	1376	N/A	0.93	0.50	6.55	Yes	Yes	110.43
Beechwood Rd	Arthur St	Argyle Rd	1345	S	3.89	1.28	5.42	No	Yes	535.35
Portland Rd	Amherst Road	Amherst Road	1374	S	2.95	0.55	5.16	No	Yes	501.41
Arthur St	Arborway Dr	Ardmore St	1346	E	2.92	0.90	6.2	No	Yes	181.10
Ardmore St	Aurthur St	Argyle Rd	1347	S	2.06	0.75	5.59	No	Yes	607.64
Spencer St	Arborway Dr	5 Spencer St	1357	E	3.92	0.91	5.9	No	Yes	124.46
Proctor Rd	Doucette Dr	Trainor Dr	1379	N	2.28	0.25	5.76	No	Yes	144.95
Ardmore St	Aurthur St	Argyle Rd	1348	N	2.65	0.88	5.53	No	Yes	595.63
Arthur St	77 Arthur St	Arborway Dr	1351	E	4.15	0.80	4.57	No	Yes	270.02
Washington Street	1701 Washington Street	20ft to Bellevue Avenue	322	W	1.63	0.55	6.03	Yes	Yes	566.01
Christina Drive	Liberty Street	Oak Ledge Drive	360	N	0.65	0.47	4.62	Yes	Yes	779.08
Washington Street	20ft from Bellevue Avenue	40ft to Peach Street	365	W	2.55	0.47	6.17	No	Yes	1599.81
Alida Road	166 Alida Road	208 Alida Road	493	N	1.27	0.58	5.56	Yes	Yes	452.35
Washington Street	Braxton Street	Washington Street	498	W	3.89	0.80	5.59	No	Yes	494.58
Teaberry Lane	100 Teaberry Lane	Teaberry Lane	7	E	2.45	0.69	5.29	No	Yes	852.95
Unnamed Drive	Columbian St	End	26	N	0.40	0.48	6.72	Yes	Yes	838.10
Washington Street	20ft from Union Street	Hobart Avenue	34	W	0.79	0.53	7.05	Yes	Yes	342.91
Washington Street	South Street	Virginia Road	106	W	1.18	0.51	6.05	Yes	Yes	1360.15
Washington Street	Unnamed Road	Braxton Street	469	W	2.49	0.94	5.42	No	Yes	194.45
Hancock Street	Myrtle Avenue	Unnamed Road	496	E	1.65	0.45	5.87	Yes	Yes	692.67
Hickory Road	Hemlock Street	Liberty Street	497	E	2.17	0.85	6.17	No	Yes	806.33
Braxton St	Hancock St	42ft W Hancock St	1408	S	2.80	0.38	5.9	No	Yes	42.34
Vernon St	Bellevue Ave	Dead End	1405	W	1.89	0.76	3.85	Yes	No	245.30
Hemlock St	50 Hemlock Street	Hickory Road	499	E	2.66	0.93	5.21	No	Yes	347.23
Grove St	Plain St	20 Grove St	1414	E	1.51	0.78	5.69	Yes	Yes	102.30
Fountain St	62 Fountain St	62 Fountain St	1418	E	5.85	0.62	4.1	No	Yes	52.83
Hancock Street	Washington Street	Highland Avenue	515	W	1.84	1.63	5.54	Yes	Yes	739.20
Hancock Street	Washington Street	Highland Avenue	519	E	3.33	0.78	5.85	No	Yes	780.94
Highland Avenue	Jefferson Street	Washington Street	520	N	2.54	0.51	4.5	No	Yes	215.03
Highland Avenue	Washington Street	Hancock Street	522	N	2.34	0.56	4.76	No	Yes	430.32
Pearl St	120 Ivory St	170 Pearl St	1456	N	2.38	0.62	4.99	No	Yes	392.13

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Pearl St	Sidewalk Island	Sidewalk Island	1457	N	1.85	0.44	5.99	Yes	Yes	57.35
Pearl St	92 Pearl St	165 Pearl St	1459	S	1.28	0.48	6.01	Yes	Yes	162.20
Pearl St	French Ave	120 Ivory St	1460	N	1.54	0.65	5.66	Yes	Yes	123.77
Union St	Grossman Dr	Grossman Dr Right Turn Lane	1453	N	1.91	0.75	5.96	Yes	Yes	13.34
Alida Road	208 Alida Road	Evergreen Avenue	511	W	1.82	0.65	5.44	Yes	Yes	1637.68
Grove St	219 Grove St	247 Grove St	521	E	1.53	0.62	5.8	Yes	Yes	363.73
Ivory St	240 Ivory St	240 Ivory St	1448	W	2.46	0.62	5.6	No	Yes	170.01
Ivory St	Braintree Station Entrance (S Ivory St)	240 Ivory St	1450	W	2.39	0.56	5.87	No	Yes	426.90
Ivory St	240 Ivory St	Pearl St	1458	E	1.49	0.57	6.15	Yes	Yes	578.98
Lake Street	61 Lake Street	81 Lake Street	1488	W	1.89	0.85	5.21	Yes	Yes	331.24
Solar Avenue	90 Solar Avenue	70 Solar Avenue	1485	E	1.70	0.71	5.03	Yes	Yes	356.91
Wayne Avenue	11 Wayne Avenue	11 Wayne Avenue	1464	W	5.57	0.83	5.29	No	Yes	68.24
Wayne Avenue	16 Wayne Avenue	10 Wayne Avenue	1472	E	2.84	0.51	4.67	No	Yes	287.19
St Michael Road	15 Hoover Avenue	37 St. Michael Road	1474	N	1.95	0.50	6.02	Yes	Yes	199.74
Torrey Road	30 Torrey Road	24 Torrey Road	1480	S	1.24	1.47	4.69	Yes	Yes	110.92
Winslow Road	26 Winslow Road	Bradley Road Extension	1451	W	1.16	0.93	5.08	Yes	Yes	168.67
Union Place	4 Tenney Road	33 Union Place	1455	S	3.11	0.93	3.71	No	No	94.12
Hannah Niles Way	111 Hannah Niles Way	Grove Street	525	N	2.84	0.52	5.38	No	Yes	1259.06
Hancock Street	Highland Avenue	Smith Street	536	W	3.30	0.83	5.16	No	Yes	419.85
Hancock Street	Highland Avenue	Smith Street	540	E	2.39	0.92	5.68	No	Yes	449.18
Bunker Corner Lane	Liberty Street	Driveway of 20 Bunker Corner Lane	1514	N/A	1.43	0.69	5.23	Yes	Yes	698.64
Commercial St	Quincy Ave	Commercial St	1520	S	2.55	0.54	6.86	No	Yes	24.19
Andrea Dr	Doris Rd	Eileen Dr	1526	E	1.39	0.57	5.66	Yes	Yes	524.11
Washington Street	Brookside Road	47 Washington Street	1519	W	1.19	0.46	6.88	Yes	Yes	229.67
Rosewood Dr	Lisle St	End	1529	W	1.31	0.54	5.03	Yes	Yes	452.54
Sycamore Road	81 Sycamore Road	121 Sycamore Road	1508	S	2.62	0.64	6.04	No	Yes	699.40
Smith Street	21 Smith Street	Hancock Street	541	N	1.45	0.84	4.25	Yes	Yes	316.49
Liberty Street	Danielle Lane	Liberty Street	549	E	1.11	0.98	5	Yes	Yes	571.23
Grove Street	Stone Crest Drive	Sunnyside Lane	563	S	2.78	0.62	6.15	No	Yes	617.61
Grove Street	Grove Circle	Stone Crest Drive	568	S	2.73	0.72	5.65	No	Yes	427.44
Union St	McCusker Dr	645 Union Street	1564	N	0.45	0.58	5.76	Yes	Yes	182.25
Paul St	Lawson Ln	Water St	1560	W	2.09	0.75	5.2	No	Yes	251.17
Clark St	Washington St	Wyman Rd	2227	S	2.17	0.71	4.87	No	Yes	328.85
Dean St	Oak St	Cochato Rd	2233	N	1.12	0.60	4.33	Yes	Yes	521.00
Grove Street	20ft from Sunnyside Lane	Hannah Niles Way	546	S	1.11	0.44	5.18	Yes	Yes	290.44
Common Street	250 Granite Street	250 Granite Street	1535	S	1.36	0.70	4.76	Yes	Yes	98.02
Reservoir Avenue	9 Reservoir Circle	8 Reservoir Avenue	1556	E	1.60	0.91	4.7	Yes	Yes	121.89
Walnut Street	Lakeside Drive	162 Walnut Street	1558	S	1.79	0.69	4.68	Yes	Yes	459.29
Granite Street	Granite St	Granite St	1536	N	0.80	0.66	5.92	Yes	Yes	13.67
Liberty Street	Liberty Street	15ft to Matthew Lane	572	E	1.57	0.84	5.26	Yes	Yes	339.22
Pearl Street	Hancock Street	Crescent Avenue	575	S	1.37	0.55	7.17	Yes	Yes	193.04
McCusker Dr	Bridge	Commercial St	1575	N	3.11	0.83	5.73	No	Yes	175.38
Prescott Ln	Commercial St	6 Prescott Ln	1577	E	3.57	1.17	3.9	No	No	113.06
Worthington Cir	Marcia Rd	Howie Rd	1585	E	1.39	0.90	5.73	Yes	Yes	237.48
Hancock Street	Smith Street	15ft to Washington Street	582	W	3.40	1.04	5.09	No	Yes	811.21
Worthington Cir	Howie Rd	Marcia Rd	1586	N	1.12	0.52	4.49	Yes	Yes	144.09
Faxon St	Commercial St	182 Commercial St	1576	E	1.99	0.62	4.55	Yes	Yes	146.60
Marcia Rd	Marcia Rd	Worthington Cir	1584	E	1.35	0.87	4.21	Yes	Yes	202.69
Marcia Rd	Marcia Rd	Worthington Cir	1587	E	1.76	0.66	4.53	Yes	Yes	211.49
JFK Memorial Dr	Briantree Town Hall	Washington St	1588	S	1.45	0.64	5.61	Yes	Yes	179.73
Washington St	Main St	Water St	1594	E	1.20	0.46	5	Yes	Yes	334.51
Liberty St	Albee Dr	E. Division St	1592	W	1.47	0.89	6.08	Yes	Yes	879.43
Alfred Rd	Francine Rd	Joseph Rd	1578	N	1.69	0.96	5.57	Yes	Yes	742.75
Acorn Cir	55 Howie Rd	10 Acorn Cir	1580	W	1.82	0.56	4.19	Yes	Yes	76.68
Summit Ridge Dr/Maplewood Ter	19 Summit Ridge Dr	5 Maplewood Terrace	1601	N/A	1.86	0.69	5.15	Yes	Yes	1966.34
Acorn Cir	41 Acorn Cir	21 Howie Rd	1581	W	1.29	0.73	4.72	Yes	Yes	185.00
Acorn Cir	52 Acorn Cir	66 Acorn Cir	1582	E	1.51	0.58	5.56	Yes	Yes	67.85
McCusker Dr	54 McCusker Dr	340 Commercial St	1574	S	1.98	0.68	5.18	Yes	Yes	316.49
Wildwood Ave	Olofson St	Drake St	1607	S	1.42	0.46	5.19	Yes	Yes	224.20
Bradford Rd	Bradford Rd	Wildwood Ave	1603	N	2.82	1.01	4.83	No	Yes	839.84

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Peach St	Washington St	Richard Rd	1604	N	1.73	0.91	5.65	Yes	Yes	969.34
Old Country Way	Woodside Ave	Spring Glen Cir	1608	N	2.07	0.72	4.62	No	Yes	438.40
Oldson St	Mann St	Wildwood Ave	1611	W	0.89	0.58	5.67	Yes	Yes	475.55
Proctor Rd	Liberty St	Portland Rd	1629	W	0.57	0.59	5.46	Yes	Yes	478.26
Mann St	Bramblewood Ln	End	1610	S	1.24	0.69	4.41	Yes	Yes	876.09
Union Pl	Tenney Rd	End	1684	N	1.44	0.46	4.99	Yes	Yes	484.69
Bradford Rd	Milton Rd	Alden Rd	1615	S	1.79	0.94	5.15	Yes	Yes	1026.40
Richard Rd	Kimball Rd	Alida Rd	1632	N	3.53	0.55	6.17	No	Yes	395.66
Brewster Ave	Sheraton Ave	111 Brewster Ave	1620	E	2.39	0.61	5.81	No	Yes	423.51
Washington Street	Parkingway	Hollis Ave	2248	W	1.25	0.52	6.73	Yes	Yes	522.83
St. Claire St	McAndrew Road	Saint Lawrence Street	1625	W	1.96	0.68	5.35	Yes	Yes	741.30
Braxton St	Hancock St	End	1634	N	1.77	0.49	5.63	Yes	Yes	887.53
Marisa Dr	Sherton Ave	End	1624	E	1.69	0.59	6.09	Yes	Yes	662.58
Forest St	St. Lawrence St	Forest St	1626	W	2.11	0.71	4.43	No	Yes	516.58
Linda Rd	Cross Road	Alida Rd	1633	S	0.77	0.46	6.15	Yes	Yes	714.04
Oak St	Storrs Ave	Dean St	2262	E	1.39	0.61	6.16	Yes	Yes	662.85
Washington St	Plymouth Ave	Arbutus Ave	1619	E	2.25	0.39	5.66	No	Yes	507.95
Grace Rd	Alida Road	Richard Rd	1635	N	1.30	0.66	4.68	Yes	Yes	781.10
Christina Dr/Fox Hill Dr	Oak Ledge Dr	Oak Ledge Dr	1623	E	0.91	0.48	4.95	Yes	Yes	1465.87
Storrs Ave	Walnut St	Windemere Cir	2252	S	1.23	0.48	5.14	Yes	Yes	175.42
Storrs Ave	Windemere Cir	Windemere Cir	2255	S	1.06	0.35	4.68	Yes	Yes	218.28
Storrs Ave	Windemere Cir	Oak St	2258	S	1.30	0.54	4.41	Yes	Yes	280.79
Prospect St N.	Abbot St	Bestick Rd	2317	S	2.78	0.87	5.57	No	Yes	202.26
Parkside Ave	Sheffield Dr	Abbot St	2329	S	1.15	0.41	5.31	Yes	Yes	412.04
Washington Street	Washington Street	Washington Street	588	W	1.27	0.66	6.08	Yes	Yes	153.89
Union Pl	Union St	Tenney Rd	1683	N	0.74	0.53	5.78	Yes	Yes	259.26
Storrs Ave	Walnut St	Oak St	2265	N	0.98	0.38	5.92	Yes	Yes	868.10
Plain Street	Garden Park	John W. Mahar Highway	589	S	1.48	0.83	5.42	Yes	Yes	1223.60
Plain Street	Washington Street	Garden Park	593	S	1.57	0.93	5.4	Yes	Yes	219.51
Plain Street	Hancock Street	Unnamed Road	594	N	1.17	0.74	6.17	Yes	Yes	305.57
Plain Street	Unnamed Road	Prentiss Road	597	N	1.53	0.75	6.15	Yes	Yes	606.52
Armstrong Circle	500 Pond Street	39 Armstrong Circle	1649	S	2.67	0.78	6.12	No	Yes	566.19
Liberty St	Messina Woods Dr	Matthew Ln	591	W	2.72	0.57	5.73	No	Yes	501.20
Liberty St	Messina Woods Dr	Matthew Ln	592	E	0.97	0.83	4.88	Yes	Yes	550.45
Hancock St	Plain St	Smith St	1646	E	3.09	0.83	5.95	No	Yes	1099.86
River St	Washington St	Shaw Ave	2271	S	1.52	0.85	5.55	Yes	Yes	344.59
Storrs Ave	Oak St	Abbot St	2287	N	0.92	0.44	5.32	Yes	Yes	634.68
Holbrook Avenue	Washington Street	French Avenue	600	S	2.40	0.67	5.76	No	Yes	587.58
Parkside Ave/Abbott St	Bestick Rd	55 Abbott St	2338	S	1.36	0.46	4.26	Yes	Yes	289.10
Bestick Rd	Staten Rd	Prospect St N.	2339	W	2.54	0.68	5.65	No	Yes	543.78
Staten Rd	Bestick Rd	Common St	2345	S	1.66	0.50	4.84	Yes	Yes	803.59
Butler Road	34 Butler Road	8 Butler Road	1655	S	4.36	1.52	5.82	No	Yes	480.38
Messina Woods Drive	160 Messina Woods Drive	90 Messina Woods Drive	601	E	1.93	0.54	5.17	Yes	Yes	1014.20
Tingley Rd	Linden St	Nickerson Rd	2371	S	2.13	0.65	5.47	No	Yes	266.36
Staten Rd	Bestick Rd	Common St	2373	N	2.54	0.53	4.43	No	Yes	779.87
Tingley Rd	Nickerson Rd	Cypress St	2412	S	1.86	0.43	5.93	Yes	Yes	405.00
Tingley Cir	Tingley Cir	Tingley Cir	2428	N/A	2.24	0.76	5.6	No	Yes	579.02
Messina Woods Drive	90 Messina Woods Drive	160 Messina Woods Drive	602	W	2.20	0.57	5.72	No	Yes	978.13
Messina Woods Drive	Messina Woods Drive	Liberty Street	603	S	2.13	0.58	4.65	No	Yes	296.74
Oakland St	Hobart St	End	2477	E	2.54	0.55	5.76	No	Yes	638.79
Cameo Road	5 Cameo Road	16 Emerald Avenue	1670	N	2.29	0.50	5.99	No	Yes	526.31
Granite Street	721 Granite Street	741 Granite Street	1680	W	1.33	0.93	6.05	Yes	Yes	441.53
French Ave	Holbrook Ave	Pearl St	1669	W	2.00	0.81	5.2	No	Yes	375.90
Elm St	Lawview Dr	Elmlawn Rd	2499	N	2.34	0.70	5.17	No	Yes	213.86
Chestnut Ave/Raleigh Rd	15 Chestnut Ave	Coolidge Ave	1851	N/A	2.63	0.65	5.69	No	Yes	576.98
Poplar St	Cypress St	End	2436	N	2.85	0.62	5.21	No	Yes	274.92
School St	Pleasant St	Cedar St	2476	N	1.62	0.58	4.69	Yes	Yes	784.12
Shaw St	Newton Ave	Sheppard Ave	2489	E	3.81	0.83	6.35	No	Yes	111.08
Shaw St	Newton Ave	Sheppard Ave	2490	W	3.27	0.81	4.8	No	Yes	102.32
Shaw St	Nelson St	Newton Ave	2501	W	4.00	0.53	5.48	No	Yes	118.75

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Shaw St	Wellington St	Nelson St	2514	W	1.84	0.74	5.73	Yes	Yes	305.83
Sumner Ave	Hollingsworth Ave N.	Ray Ln	1699	E	0.48	0.58	5.42	Yes	Yes	311.18
Helen Rd	Norfolk Rd	Hazel Ct	1689	W	0.56	0.74	5.57	Yes	Yes	270.86
Elm St	Drinkwater Ave	Jay St	2507	S	1.59	0.92	5.49	Yes	Yes	622.64
Strathmore Cir	3 Strathmore Circle	25 Strathmore Circle	1720	W	1.88	0.48	5.67	Yes	Yes	333.87
Strathmore Cir	33 Strathmore Circle	57 Strathmore Circle	1721	E	1.87	0.45	4.08	Yes	Yes	355.03
Orchard St	Hobart St	Upland Rd	2525	S	1.93	1.21	5.9	Yes	Yes	476.46
Messina Woods Drive	Jensen Farm Road	Liberty Street	604	N	1.35	0.31	5.51	Yes	Yes	1043.12
Louise Rd	Lisle St	Liberty St	1703	E	0.77	0.40	4.71	Yes	Yes	1076.03
Elliot St	Stetson St	Sterling St	1722	E	1.04	0.53	5.15	Yes	Yes	309.36
Plain Street	Prentiss Road	John W. Mahar Highway	611	N	1.94	0.92	6.09	Yes	Yes	445.31
Franklin Street	209 Franklin Street	249 Franklin Street	1701	E	3.17	0.85	5.86	No	Yes	572.90
Plain Street	John W. Mahar Highway	Plain Street	613	N	1.30	0.93	5.23	Yes	Yes	224.66
Grove St	John W. Mahar Hwy	Grove Cir	606	S	1.92	0.88	4.66	Yes	Yes	859.47
Norfolk Rd	Middle St	Helen Rd	1697	S	0.96	0.44	5.9	Yes	Yes	975.84
Trefton Rd	Quincy Ave	Argyle Rd	1968	N	2.80	0.60	4.59	No	Yes	885.00
Front St	Willow St	Oak St E	1822	N	2.48	0.49	5.65	No	Yes	279.25
Ledgewood Rd	Walnut Rd	Walnut Rd	1705	N/A	2.05	0.68	5.33	No	Yes	1282.15
Jay St	Elm St	Elm St	2530	N/A	1.25	0.73	3.97	Yes	No	751.29
Plain Street	Grove Street	Unnamed Road	615	S	1.28	1.06	5.62	Yes	Yes	925.49
Kendall Avenue	Plain Street	Congress Street	702	E	2.02	1.10	5.31	No	Yes	274.65
Union St	Winslow Rd	Middle St	1714	N	0.45	0.44	6.12	Yes	Yes	358.76
Hobart St	Deborah Ln	Orchard St	2531	E	0.64	0.55	5.53	Yes	Yes	212.06
Elm St	Bower Rd	RR Crossing	2532	N	2.01	1.10	5.49	No	Yes	302.40
Old Carriage Lane	Old Country Way	Old Country Way	1602	N/A	1.66	0.76	5.69	Yes	Yes	965.92
Old Country Way	Bayberry Lane	Leehaven Terrace	1609	N	2.82	0.66	5.77	No	Yes	621.54
Quincy Ave	Gordon Rd	Wright Connector	1232	E	2.43	0.73	5.34	No	Yes	1238.31
Pilgrim Rd	Mayflower Rd	Stetson St	1728	E	1.37	0.97	5.37	Yes	Yes	1761.50
Quincy Ave	Allen St	Wright Connector	1233	W	2.56	0.74	5.35	No	Yes	1037.08
Blake Road	1 Blake Road	25 Blake Road	1744	N	1.31	0.85	5.44	Yes	Yes	416.53
Parkside Cir	Gale Ave	Parkside Ave	1732	N	1.88	0.87	4.65	Yes	Yes	671.37
Rita Rd	Gila Ave	Hollis Ave	1726	S	1.44	1.12	5.65	Yes	Yes	913.87
Gale Ave/Rita Rd	Parkside Cir	Walnut Street	1725	N/A	1.99	0.92	5.08	Yes	Yes	1309.47
Faxon St	Commercial St	Stetson St	1737	W	3.50	0.91	5.13	No	Yes	991.34
Shaw St/Somerville Ave	Wellington St	51 Somerville Ave	2560	E	3.86	0.67	5.9	No	Yes	317.88
Brickford Rd	35 Bickford St	Newton Ave	1760	N	3.19	0.71	5.86	No	Yes	169.99
Tower Hill Road	9 Tower Hill Road	67 Tower Hill Road	1773	E	1.87	0.72	5.1	Yes	Yes	795.18
Common Street	363 Common Street	343 Common Street	1752	N	2.50	0.72	5.37	No	Yes	285.67
Common Street	258 Common Street	248 Common Street	1754	S	1.78	0.61	4.81	Yes	Yes	238.54
Quincy Ave	Cedarcliff Rd	Allen St	1291	W	2.61	0.78	7.18	No	Yes	500.95
Quincy Ave	beechwood Rd	Edgehill Rd	1316	E	2.09	0.78	4.76	No	Yes	191.03
Allen St	Shaw St	Quincy Ave	1750	S	3.62	1.11	5.49	No	Yes	1365.74
Wildwood Ave	Drake St	193 Wildwood Ave	1766	S	2.82	0.46	5.33	No	Yes	147.50
Somerville Ave	Fairmount Ave	Shaw St	2561	N	2.46	0.63	5.79	No	Yes	171.24
Bradley Rd Ext	Winslow Rd	End	1757	N	1.85	0.93	5.68	Yes	Yes	353.92
Geraldine Ln	74 Geraldine Lane	79 Geraldine Ln	1764	N/A	3.15	0.95	4.49	No	Yes	269.82
Quincy Ave	Beechwood Rd	Cedarcliff Rd	1318	W	1.65	0.85	7.43	Yes	Yes	289.75
Quincy Ave	Edgemont Rd	Beechwood Rd	1338	W	3.19	1.10	7.46	No	Yes	344.17
Bower Rd	Elm St	Perry Rd	2563	W	2.28	0.92	5.38	No	Yes	928.07
Bower Rd	Elm St	Perry Rd	2564	E	2.01	0.94	6.21	No	Yes	904.86
Elm St	RR Crossing	Commercial St	2569	N	1.45	0.84	5.97	Yes	Yes	694.42
Hayward St	Donald E. Ross School Entrance Road	Connell St	2573	N	0.81	0.64	5.85	Yes	Yes	377.60
Shaw St	Hayward St	Somerville Ave	2575	W	2.69	0.66	6.2	No	Yes	612.44
Shaw St	Belmont St	Somerville Ave	2576	E	2.17	0.64	4.78	No	Yes	152.34
JFK Memorial Dr	Washington St	Washington St	1780	E	2.43	0.63	6.08	No	Yes	601.49
Comm. St/Front St	Nickerson Rd	Willow St	1848	N	1.53	0.54	5.1	Yes	Yes	779.94
Erickson St	Commercial St	End	2629	S	1.54	0.62	4.97	Yes	Yes	419.42
Burroughs Rd	Perry Rd	Elm St	2593	W	1.69	0.58	5.91	Yes	Yes	912.77
Elmlawn Rd	Perry Rd	Elm St	2580	W	0.84	0.50	5.29	Yes	Yes	878.25
Perry Rd	Elmlawn Rd	Burrough Rd	2598	N	1.75	0.58	5.85	Yes	Yes	162.16

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Perry Rd	Burrough Rd	Bower Rd	2609	S	1.19	0.55	4.69	Yes	Yes	205.30
Commercial St	382 Commercial St	McCusker Dr	1847	W	2.29	0.65	5.46	No	Yes	546.54
Union St	Baker Ave	Alexander Rd	1852	E	0.58	0.54	5.17	Yes	Yes	609.56
Elm St	Railroad St	Middle St	1853	S	0.72	0.55	5.7	Yes	Yes	1914.84
Willow St	End	26 Willow St	1855	W	1.79	0.58	5.18	Yes	Yes	329.25
Church St	Service Road	Elm Street	1856	W	0.76	0.54	5.83	Yes	Yes	353.77
Coolidge Ave	Cleveland Ave	Raleigh Rd	1857	N	1.65	0.42	5.34	Yes	Yes	414.77
Hillside Rd	Driveway of 56 Hillside Rd	Union St	1823	S	2.13	0.58	4.56	No	Yes	629.72
Hillside Rd	East Middle School Lot	Driveway of 56 Hillside Rd	1824	N/A	1.13	0.57	4.94	Yes	Yes	1933.94
Elm St	8 Elm St	40ft to Stedman Ave	1825	N	1.11	0.74	4.8	Yes	Yes	195.32
River St	Middle St	Lemoyne St	1826	N	1.07	0.46	4.85	Yes	Yes	493.02
Myrtle St	Vine St	7 Myrtle St	1840	S	1.74	0.60	5.6	Yes	Yes	142.77
Shaw St	Hayward St	Belmont St	2632	E	3.19	0.93	5.73	No	Yes	429.20
Erickson St	Commercial St	Pantano St	2633	N	0.40	0.64	5.54	Yes	Yes	262.39
Hayward St	Connell St	Highland Ave E.	2635	N	0.94	0.75	5.4	Yes	Yes	470.68
Middle St	Elm St	Myrtle St	1860	W	0.74	0.60	5.45	Yes	Yes	933.12
Union St	Robbie Rd	Baker Ave	1862	E	0.85	0.47	5.09	Yes	Yes	537.31
River St	Arnold St	East Middle School Lot Entrance (West)	1863	N	1.04	0.52	5.86	Yes	Yes	828.05
Oak St E.	End	Front St	1869	W	2.38	0.57	5.56	No	Yes	524.20
Jordan Cir	Sheppard Ave	Sheppard Ave	1870	N/A	1.78	0.92	5.58	Yes	Yes	768.77
Cleveland Ave	Chestnut Ave	Coolidge Ave	1873	E	1.12	0.40	6.07	Yes	Yes	153.45
Cleveland Ave	Chestnut Ave	Harrison Ave	1875	E	1.81	0.39	4.68	Yes	Yes	288.96
Allen St	105ft SE from Hobart St	168 Allen St	1878	S	2.48	0.59	5.18	No	Yes	236.01
Holmes St	Independence Ave	Fairfield St	2671	E	1.94	0.99	5.13	Yes	Yes	512.24
Orchard St	Hobart St	Upland Rd	2757	N	1.90	1.11	4.51	Yes	Yes	475.10
Shaw St	Dewey Rd	Berwick St	1913	E	2.04	1.42	5.48	No	Yes	284.79
Trefton Rd	Spencer St	Argyle Rd	1896	S	3.00	0.57	5.36	No	Yes	397.61
Connell St	Avon Pl	Hayward St	1901	E	0.83	0.55	5.45	Yes	Yes	710.63
Rogers Cir	Bower Rd	Bower Rd	1926	N/A	1.96	0.59	6.05	Yes	Yes	1132.98
Hillside Ave	32 Hillside Ave	46 Hillside Ave	1922	N	2.62	0.83	5.83	No	Yes	212.57
Cleveland Ave	Union St	Harrison Ave	1966	W	1.68	0.46	5.01	Yes	Yes	1515.96
Coolidge Ave	Cleveland Ave	37 Coolidge Ave	1927	S	1.35	0.39	4.66	Yes	Yes	423.63
Townsend Ave	Cleveland Ave	Middle St	2786	S	1.77	0.54	5.11	Yes	Yes	870.18
Talbot Rd	Hollingsworth Ave S	End	2790	W	2.42	1.07	4.21	No	Yes	411.29
Belmont St	Shaw St	End	2803	N	2.48	0.80	5.32	No	Yes	400.15
Academy St	58 Academy St	Brow Ave	2793	S	2.86	0.42	5.8	No	Yes	102.29
Cleveland Ave	Hunt Ave	Merritt Ave	2787	W	1.66	0.58	5.1	Yes	Yes	187.42
Audubon Ave	Quincy Ave	Arthur St	1941	S	2.91	1.09	5.34	No	Yes	223.10
Quincy Ave	Trefton Dr	Audobon Ave	1784	E	1.69	0.79	5.07	Yes	Yes	128.37
Hayward St	Heritage Ln	Quincy Ave	2801	S	3.12	0.59	5.76	No	Yes	934.96
Central Ave	Old Thayer Public Library Entrance Road	50ft SE from John F. Kennedy Memorial Dr	1942	S	2.97	0.40	5.61	No	Yes	62.82
Harrison Ave	Cleveland Ave	62 Harrison Ave	1979	N	1.98	0.42	5.91	Yes	Yes	793.71
Tremont St	Taylor St	Summer St	2056	W	1.14	0.31	5.44	Yes	Yes	424.18
Parkside Cir	N/A - Loop	N/A - Loop	1122	N/A	2.94	0.90	6.11	No	Yes	1245.26
Parkside Cir	Gale Ave	Storrs Ave	1686	E	3.08	0.77	3.97	No	No	743.41
John Paul Cir	Commercial St	Chickadee Ln	2706	E	2.72	1.09	4.06	No	Yes	125.72
St. Claire St	175 St Claire St	End	288	S	2.10	0.75	4.15	No	Yes	189.81
Robert St	Elmlawn Rd	Conrad St	2703	S	1.35	0.63	4.76	Yes	Yes	201.94
Cleveland Ave	Bradley Rd	Coolidge Ave	1974	E	0.99	0.40	5.18	Yes	Yes	200.01
Primrose St	17 Primrose St	Arborway Dr	2006	E	2.46	0.74	5.4	No	Yes	253.64
Cleveland Ave	Harrison Ave	Townsend Ave	1977	E	1.67	0.48	4.87	Yes	Yes	338.74
Cleveland Ave	Merritt Ave	Harding Ave	1978	W	0.96	0.48	6.06	Yes	Yes	196.21
Arborway Dr	Argyle Rd	Autumn St	1995	S	1.28	0.85	5.12	Yes	Yes	209.10
Shaw St	Howard St	Dewey Rd	2049	W	3.55	1.02	5.06	No	Yes	1371.02
St. Claire St	N/A - Loop	N/A - Loop	306	N/A	1.28	0.99	5.14	Yes	Yes	1062.08
Grace Road	Alida Road	Richard Rd	477	S	2.28	0.88	4.99	No	Yes	810.87
Bregoli Ln	321 Plain St	36 Bregoli St	2050	E	2.84	1.87	3.89	No	No	289.04
Haven Rd	Cedar St	End	2047	N	2.95	0.57	4.97	No	Yes	348.11
Holmes St	Fairfield St	94 Holmes St	2048	W	2.58	0.51	5.09	No	Yes	115.86
Quincy Ave	Warren Ave	Cotton Ave	1786	W	3.08	1.05	5.56	No	Yes	191.30

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Arborway Dr	Arthur St	Spencer St	2023	N	4.45	1.04	4.54	No	Yes	179.70
Washington Street	660 Washington Street	640 Washington Street	2045	E	0.71	0.61	5.96	Yes	Yes	259.45
Summer St	Central St	Washington St	2054	N	2.21	0.45	5.8	No	Yes	178.23
Argyle Rd	Arborway Dr	Ardmore St	2024	W	1.84	0.96	4.81	Yes	Yes	163.19
Arborway Dr	Quincy Ave	Arthur St	2028	S	3.30	0.83	5.19	No	Yes	287.29
Azel Rd	Franklin St	Azel Rd	2033	N	1.32	0.49	5.74	Yes	Yes	238.42
Argyle Rd	Edgehill Rd	Gordon Rd	2012	W	3.10	0.89	5.45	No	Yes	214.68
Edgehill Rd	Quincy Ave	30ft S on Arthur St	2014	N	2.88	1.11	5.6	No	Yes	543.05
Tremont St	Taylor St	Summer St	2057	E	2.68	0.45	6.05	No	Yes	429.18
Taylor St	Tremont St	Central St	2059	S	1.68	0.42	5.99	Yes	Yes	394.19
Central St	Taylor St	Summer St	2061	E	0.78	0.44	6.05	Yes	Yes	428.63
Taylor St	Central St	Washington St	2062	S	1.68	0.48	6.16	Yes	Yes	291.23
Lakeview Ave	Azel Rd	Tremont St	2071	S	2.00	0.51	5.18	No	Yes	388.26
Fallon Circle	Davis Rd	Eleanor Dr	1049	E	1.60	0.89	5.88	Yes	Yes	689.97
Washington Street	Summer St	198ft N of Summer St	2058	W	1.42	0.64	6.75	Yes	Yes	198.03
Washington Street	Central Ave	Union St	2067	W	1.64	0.66	7.04	Yes	Yes	270.46
Washington Street	726 Washington Street	714 Washington Street	2068	E	1.08	0.79	5.28	Yes	Yes	341.82
Howie Rd/Worthington Cir	Acorn St	Common St	1240	S	2.88	0.68	5.12	No	Yes	1190.82
Central Ave	Tremont St	27 Central Ave	2066	S	3.07	0.63	5.73	No	Yes	898.10
Liberty St	Whites Hill Dr	Louise Rd	1021	E	1.53	0.51	6.14	Yes	Yes	729.52
Hobart Ave	35 Hobart Ave	19 Hobart Ave	2074	S	2.50	0.65	7.32	No	Yes	272.85
Robbie Road	Powder Hill Drive	Lisle Road	1055	W	1.36	0.54	6.08	Yes	Yes	1051.60
Robbie Road	Sun Valley Drive	191 Lisle Street	1057	E	1.00	0.60	5.49	Yes	Yes	652.79
Powder Hill Drive	437 Union Street	Robbie Road	1061	W	0.56	0.41	6.13	Yes	Yes	1192.93
Robbie Road	Hatch Avenue	Sun Valley Drive	1065	E	0.84	0.46	5.33	Yes	Yes	311.79
Robbie Road	Union Street	4 Hatch Avenue	1086	E	0.57	0.58	5.4	Yes	Yes	272.93
Quincy Ave	Cotton Ave	Bickford Rd	1810	W	2.87	0.70	4.83	No	Yes	534.18
Quincy Ave	Hayward St	Warren Ave	1830	S	2.20	0.65	5.38	No	Yes	603.44
Quincy Ave	Bickford St	Edgemont Rd	1846	W	3.61	0.70	5.85	No	Yes	260.64
Quincy Ave	Pleasant View Ave	Trefton Dr	1871	N	1.36	0.98	5.12	Yes	Yes	320.82
Quincy Ave	Hill Avenue	Patten Ave	1872	N	1.21	0.71	4.67	Yes	Yes	557.59
Quincy Ave	Quincy/Braintree Town Line	Hill Ave	1894	N	1.29	0.87	5.14	Yes	Yes	132.04
Quincy Ave	Potter Rd	Harbor Villa Ave	1900	N	1.59	0.56	5.39	Yes	Yes	127.15
Brow Ave	Tremont St	Academy St	2095	S	1.48	0.46	4.13	Yes	Yes	1306.27
Evergreen Ave	Evergreen Ave	Fern Rd	1643	E	1.66	0.59	5.16	Yes	Yes	2253.49
Adams St	Morrison Rd	RR Crossing	2383	S	2.65	0.76	5.38	No	Yes	1147.31
Quincy Ave	Arborway Dr	Beechwood Rd	1761	E	3.10	0.85	5.8	No	Yes	535.52
Quincy Ave	513 Quincy Ave	Dewey Rd	1949	W	1.30	0.95	5.14	Yes	Yes	1868.22
Franklin Street	350 Franklin Street	276 Franklin Street	2096	S	0.68	0.47	4.7	Yes	Yes	1234.15
Norton St/Hollingsworth Ave	Weston Ave	Academy St	2116	N/A	1.61	0.76	4.62	Yes	Yes	773.12
Franklin Street	323 Franklin Street	367 Franklin Street	2098	N	2.31	0.81	6.02	No	Yes	600.69
Washington Street	Weston Ave	659 Washington St	2100	W	1.64	0.56	5.23	Yes	Yes	521.23
Quincy Ave	Audobon Ave	Arborway Dr	2031	E	1.82	0.74	5.36	Yes	Yes	336.22
Washington Street	626 Washington Street	620 Washington Street	2102	E	1.61	0.53	5.28	Yes	Yes	126.27
Washington Street	614 Washington Street	610 Washington Street	2120	E	1.77	0.52	6.12	Yes	Yes	98.20
Quincy Ave	Patten Ave	Potter Road	1946	E	1.34	0.92	5.65	Yes	Yes	1782.56
Quincy Ave	Harbor Villa Ave	Pleasant View Ave	1958	N	1.69	0.98	5.36	Yes	Yes	467.10
Hobart Ave	Thayer Academy Middle School Lot Exit	Thayer Academy Middle School Lot Entrance	2103	N	3.39	0.75	4.68	No	Yes	88.39
Judson St	Oak St	End	2130	S	1.76	0.60	5.94	Yes	Yes	583.85
Sherbrook Ave	Washington St	79 Sherbrook Ave	2146	N	1.88	0.49	5.4	Yes	Yes	1051.45
Washington Street	Faulkner Pl	Elm St	2342	W	1.33	0.53	4.75	Yes	Yes	750.63
Stedman Ave	School St W	Elm St	2350	E	3.62	0.84	6.2	No	Yes	658.89
President Rd	Washington St	School St W	2381	E	3.19	0.63	5.78	No	Yes	709.27
Washington Street	Fairfield St	Holmes St	2691	W	1.37	0.81	5.43	Yes	Yes	593.99
Burroughs Rd	Perry Rd	Bower Rd	2771	S	2.65	0.62	5.87	No	Yes	1782.55
Elm St	Charles St	Lowell St	2353	N	3.30	0.94	5.54	No	Yes	252.98
Morrison Rd	Drinkwater Ave	Morrison Rd	2440	S	1.78	0.56	4.72	Yes	Yes	328.02
Morrison Rd	Morrison Rd	Adams St	2445	W	0.61	0.46	4.75	Yes	Yes	363.69
Washington Street	594 Washington Street	588 Washington Street	2133	E	1.27	0.74	6.55	Yes	Yes	138.60
Washington Street	578 Washington Street	1 Wynot Road	2144	E	1.18	0.42	5.79	Yes	Yes	325.99

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Mt. Vernon St	19 Mt. Vernon St	41 Mt. Vernon St	2143	W	1.42	0.61	4.58	Yes	Yes	294.11
Sampson Ave	Washington St	End	2128	S	1.21	0.53	4.74	Yes	Yes	582.62
Sampson Ave	Washington St	End	2134	N	1.75	0.51	5.18	Yes	Yes	561.65
Hollingsworth Ave	West St	Weston Ave	2167	W	2.78	1.03	5.18	No	Yes	913.77
Nickerson Rd	Commercial St	Tingley Rd	1849	S	3.65	0.64	5.23	No	Yes	761.13
Burroughs Rd	Perry Rd	176 Burroughs Rd	2772	W	1.81	0.65	4.76	Yes	Yes	1305.77
Monatiquot Ave	Walnut St	Oak St	2186	N	1.74	0.52	4.48	Yes	Yes	751.46
Monatiquot Ave	Oak St	Ash St	2188	S	2.31	0.55	5.93	No	Yes	801.26
Parkside Avenue	3 Parkside Circle	152 Walnut Street	1153	N	1.49	0.70	5.83	Yes	Yes	502.53
Proctor Rd	Portland Rd	Liberty School Lot	1378	W	2.15	1.71	3.29	No	No	141.99
Plain St	661 Liberty St	Liberty St	1428	N	1.85	1.37	4.09	Yes	Yes	77.05
West Street	Tremont St	Hollingsworth Ave	2166	S	0.90	0.40	4.79	Yes	Yes	244.99
Proctor Rd	Liberty St	99 Proctor Rd	1377	E	0.39	0.41	5.21	Yes	Yes	97.81
O'Toole Terr	31 O'Toole Terrace	30 O'Toole Terrace	1763	N/A	2.68	0.73	5.69	No	Yes	299.35
Washington Street	552 Washington Street	550 Washington Street	2176	E	1.03	0.39	5.32	Yes	Yes	345.74
Nickerson Rd	Commercial St	Tingley Rd	1850	N	3.53	0.64	6.02	No	Yes	691.07
Washington Street	550 Washington Street	506 Washington Street	2187	E	1.05	0.54	5.5	Yes	Yes	449.01
Plain St	Grove St	Plain St	1767	N	1.35	1.19	5.63	Yes	Yes	136.06
Washington St	550 Washington Street	550 Washington Street	2179	E	0.88	0.54	5.44	Yes	Yes	106.95
Commercial St	Peregrine Rd	Commercial St Exit Road	1177	S	1.44	0.60	5.65	Yes	Yes	242.45
Commercial St	Tompson Rd	Shaw St	1179	N	1.73	0.55	5.62	Yes	Yes	567.90
Commercial St	Liberty St	Faxon St	1172	S	1.68	0.61	5.15	Yes	Yes	417.36
Middle St	Townsend Ave	Harrison Ave	2199	W	1.38	0.63	5.53	Yes	Yes	295.11
Townsend Ave	Cleveland Ave	Middle St	2205	N	1.73	0.47	5.35	Yes	Yes	851.73
Elem. School Lot	Washington St	482 Washington St	2197	W	1.19	0.42	4.74	Yes	Yes	179.27
Oak St	Monatiquot Ave	West St	2184	W	1.70	0.43	4.59	Yes	Yes	426.83
Bramblewood Lane	Maplewood Terrace	Mann Street	205	E	2.70	0.65	5.64	No	Yes	819.80
Angela Road	Forest Street	Birch Street	338	W	1.38	0.70	4.95	Yes	Yes	1548.77
Alida Road	Grace Road	Richard Road	494	E	1.95	0.70	5.63	Yes	Yes	835.74
Alida Road	70 Alida Road	142 Alida Road	495	N	1.80	0.68	4.06	Yes	Yes	900.54
Green House Way	Harvest Ln	End	2204	N	1.26	0.65	5.76	Yes	Yes	137.26
Marshall St	Middle St	Penniman Ter	2206	S	3.80	0.51	4.67	No	Yes	296.68
Maple St	Hollis Ave	Monatiquot Ave	2219	W	1.96	0.55	5.14	Yes	Yes	606.23
Oak St	Monatiquot Ave	West St	2185	E	1.36	0.56	4.42	Yes	Yes	408.71
Oak St	Hollis Ave	Monatiquot Ave	2201	E	2.35	0.48	3.52	No	No	345.20
Putnam Ave	14 Putnam Ave	20 Putnam Ave	2214	N	2.63	0.53	6.06	No	Yes	134.83
Webster Rd	Washington Street	Parking Lot	2203	S	1.45	0.54	5.24	Yes	Yes	241.34
Commercial St	Faxon St	Elm Knoll Rd	1180	S	2.09	0.62	5.59	No	Yes	372.75
Alida Road	Fern Road	Evergreen Avenue	516	E	3.91	0.66	6.21	No	Yes	1619.31
Commercial St	191 Commercial St	Mill Ln	1183	N	1.38	0.65	5.23	Yes	Yes	266.26
Middle St	Whittier Rd	Arnold St	2244	N	1.71	0.59	5.15	Yes	Yes	270.93
Oak St	Storrs Ave	Judson St	2259	W	1.64	0.63	4.43	Yes	Yes	723.80
Braintree Hill Park	50 Braintree Hill Park	45 Braintree Hill Office Park	1334	N	2.59	0.89	5.22	No	Yes	81.13
Middle St	Greenhouse Way	Arnold St	2240	E	2.10	0.52	5.59	No	Yes	19.82
Middle St	Middle St	Townsend Ave	2239	S	1.21	0.64	5.95	Yes	Yes	1142.18
Arthur St	Ardmore St	Beechwood Rd	1340	E	2.57	0.78	4.2	No	Yes	232.64
Green House Way	Arnold St	Harvest Ln	2243	N	1.16	0.64	4.54	Yes	Yes	252.50
Windemere Cir	Storrs Ave	3 Windemere Cir	2254	W	2.08	0.47	5.51	No	Yes	128.67
Wyman Rd	Clark St	23 Wyman Rd	2250	W	1.70	0.60	4.78	Yes	Yes	507.75
Wyman Rd	23 Wyman Rd	Shaw Ave	2251	W	0.98	0.51	6.18	Yes	Yes	103.49
Commercial St	Mill Ln	161 Commercial St	1187	N	3.73	0.69	5.26	No	Yes	120.33
Farm Rd	Arnold St	Cindy Ln	2285	S	1.50	0.97	4.74	Yes	Yes	219.01
Cochato Rd	Storrs Ave	Dean St	2274	W	2.30	0.67	5.92	No	Yes	766.24
River St	Washington St	Shaw Ave	2276	N	1.62	0.81	5.95	Yes	Yes	367.40
River St	Shaw Ave	End	2275	S	4.29	0.55	5.93	No	Yes	228.76
Prospect St N.	Abbot St	End	2310	S	2.37	0.74	6.13	No	Yes	316.62
Jersey Ave	River St	End	2289	W	2.03	0.50	5.88	No	Yes	826.85
Prospect St N.	Abbot St	End	2313	N	2.62	0.79	6.06	No	Yes	312.71
Arborway Dr	Aurthur St	Argyle Rd	1350	S	3.60	1.01	5.09	No	Yes	604.92
Arborway Dr	Primrose St	Argyle Rd	1352	N	4.94	0.97	4.71	No	Yes	182.47

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Abbott St	Prospect St N	Storrs Ave	2312	E	1.64	0.86	5.21	Yes	Yes	294.58
Audubon Ave	25 Primrose St	56 Audubon Ave	1359	S	3.85	0.73	5.21	No	Yes	72.92
Bramblewood Ln	Summit Ridge Dr	Mann St	1606	W	1.72	0.68	5.12	Yes	Yes	1322.00
Washington St	Storrs Ave	Elm St	2302	E	1.61	0.47	6.05	Yes	Yes	73.47
Railroad St	Hooker St	Shaw Ave	2281	N/A	2.73	0.89	4.83	No	Yes	427.71
Abbott St	Prospect St N	Storrs Ave	2311	W	1.68	0.46	4.42	Yes	Yes	286.42
Bestick Rd	51 Bestick Rd	End	2328	E	1.87	0.58	4.04	Yes	Yes	344.76
Staten Rd	Abbot St	Bestick Rd	2341	N	2.64	0.47	3.71	No	No	186.11
Prospect St N.	Abbot St	Bestick Rd	2318	N	2.35	0.45	4.49	No	Yes	202.85
School St. W	Washington St	Stedman Ave	2348	S	1.03	0.73	5.43	Yes	Yes	284.26
Stedman Ave	School St W	Elm St	2349	W	2.70	0.87	5.61	No	Yes	667.20
Bestick Rd	Staten Rd	59 Bestick Rd	2340	E	2.19	0.76	4.31	No	Yes	211.11
Bestick Rd	Dickerman Ln	Staten Rd	2352	W	2.88	0.76	3.87	No	No	251.84
Canavan Drive	Liberty Street	50 Canavan Drive	127	N	2.45	0.73	5.53	No	Yes	827.69
Cain Avenue	Bradford Road	Summit Ridge Drive	148	E	2.49	0.94	6.17	No	Yes	1766.21
Court Road	Milton Road	Selwyn Road	172	S	1.41	0.70	6.01	Yes	Yes	256.88
Middle St	Myrtle St	River St	2326	W	1.22	0.55	5.35	Yes	Yes	492.42
Abbott St	Dickerman Lane	Staten Road	2346	E	3.32	0.95	3.75	No	No	265.44
Hillside Rd	River St	Union St	1837	N	2.01	0.54	5.59	No	Yes	1579.71
Trainer Dr	60 Trainer Drive	Proctor Rd	1380	W	2.59	0.64	5.29	No	Yes	664.86
Trainer Dr	53 Trainer Drive	60 Trainer Drive	1381	N/A	1.54	0.49	5.62	Yes	Yes	267.24
Abbott St	Parkside Ave	Prospect St N	2334	W	1.48	0.40	5.62	Yes	Yes	513.20
Commercial St	Bellevue Rd	Peregrine Rd	1189	S	2.26	0.87	6.13	No	Yes	494.31
Commercial St	Taber Ct	Bridge	1190	S	3.95	0.56	6.04	No	Yes	73.38
Elm St	Lowell St	Cedar St	2360	N	2.36	0.67	5.61	No	Yes	455.86
Charles St	Park St	Elm St	2362	W	2.59	0.42	5.78	No	Yes	471.12
Charles St	19 Charles St	19 Charles St	2367	E	3.64	0.57	6	No	Yes	67.80
Elm St	Church St	Elm Ter	2366	N/A	2.05	0.67	5.19	No	Yes	21.22
Adams St	231 Adams St	241 Adams St	2364	S	3.36	0.77	5.59	No	Yes	248.85
Washington Street	276 Washington Street	250 Washington Street	2363	E	1.00	0.61	5.24	Yes	Yes	367.95
Adams St	Fore River Railroad	231 Adams St	2372	S	2.57	0.69	5.82	No	Yes	157.70
Oak St	Dean St	Hollis Ave	2217	E	1.54	0.41	5.69	Yes	Yes	397.62
Hobart St	Prospect st	Hobart Terrace	2374	E	3.20	0.86	5.75	No	Yes	117.15
Elm St	Cedar St	Middle St	2380	N	2.58	0.40	5.96	No	Yes	167.78
Railroad St	69 Railroad St	Hooker St	2320	W	1.54	0.94	6.17	Yes	Yes	415.11
Parkside Ave	Sheffield Dr	Abbot St	2331	N	2.60	0.45	4.74	No	Yes	408.41
Robert St	Elmlawn Rd	Conrad St	2705	N	1.16	0.59	5.46	Yes	Yes	220.47
Court Road	Milton Road	Alden Road	183	N	1.33	0.72	5.84	Yes	Yes	1017.61
Common St	Staten Rd	Washington St	2369	S	1.52	0.45	6.03	Yes	Yes	111.87
Linden St/Tingley Rd	3 Linden St	Tingley Cir	2375	N	1.97	0.70	5.26	Yes	Yes	607.82
Duckerman Ln	Bestick Rd	22 Dickerman Ln	2376	S	3.67	0.71	4.14	No	Yes	332.32
Commercial St	Allen St	Taber Ct	1198	S	1.91	0.47	5.96	Yes	Yes	187.96
Commercial St	Elm Knoll Rd	Prescott Ln	1192	N	3.18	0.82	4.75	No	Yes	275.77
Commercial St	Prescott Ln	Bellevue Rd	1195	S	2.71	0.61	5.63	No	Yes	218.62
Park St	Charles St	Lowell St	2400	N	1.81	0.49	5.22	Yes	Yes	240.59
Commercial St	161 Commercial St	Prescott Ln	1196	N	1.50	0.60	5.64	Yes	Yes	292.27
Church St	Pleasant St	School St	2427	E	1.50	0.68	5.56	Yes	Yes	335.19
Commercial St	Prescott Ln	Tompson Rd	1197	N	1.37	0.55	5.11	Yes	Yes	253.76
Adams St	Arnold St	Morrison Rd	2399	S	2.78	0.83	4.81	No	Yes	620.22
Elm St	Middle St	Hawthorn Rd	2404	E	3.54	0.71	5.13	No	Yes	192.38
Adams St	Elm St	Arnold St	2403	S	1.97	1.09	5.57	Yes	Yes	799.34
Old Elm St	Hawthorn Rd	Blanchard Blvd	2408	N	1.67	0.67	5.93	Yes	Yes	573.37
Adams St	301 Elm St	76 Adams St	2407	N	2.60	1.06	5.67	No	Yes	701.04
Cedar St	Park St	Elm St	2420	E	2.80	0.55	5.1	No	Yes	615.01
Elm St	Middle St	Adams St	2406	E	1.61	0.68	6.01	Yes	Yes	214.97
School St	81 School St	87 School St	2425	S	1.56	1.38	4.08	Yes	Yes	93.62
Magnolia St	Commercial St	Linden St	2410	S	1.89	0.75	3.84	Yes	No	240.65
Linden St	8 Linden St	2A Linden St	2411	W	2.50	0.62	5.11	No	Yes	295.37
Park St	Lowell St	Cedar St	2438	N	2.33	0.48	5.47	No	Yes	481.42
Elm St	Elm St NB	Elm St SB	2417	N	1.19	0.43	5.67	Yes	Yes	34.33

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Magnolia St	Commercial St	Linden St	2419	N	1.19	0.67	5.4	Yes	Yes	221.54
Ellis Ln	end	90 Sheppard Ave	2442	N	3.74	0.76	5.96	No	Yes	174.50
Hobart St	Hobart st	Prospect St	2473	S	2.73	0.75	4.8	No	Yes	82.03
Beech St	12 Beech St	14 Beech St	2453	N	5.56	0.78	4.65	No	Yes	43.62
Poplar St	Cypress St	End	2455	S	1.88	0.85	5.67	Yes	Yes	238.09
Wynot Rd	33 Wynot Rd	33 Wynot Rd	2471	S	2.17	1.27	5.22	No	Yes	86.91
Elm St	Old Elm St	Old Em St	2458	N	1.24	0.76	5.99	Yes	Yes	630.35
Sheppard Ave	31 Sheppard Ave	31 Sheppard Ave	2456	E	1.63	1.17	5.48	Yes	Yes	33.12
Cypress St	Popar St	Tingley Rd	2443	W	3.35	0.58	4.84	No	Yes	202.00
Park St	Cedar St	Hawthorne Rd	2475	N	0.77	0.53	4.86	Yes	Yes	328.93
Church St	Bushnell Ter	Pleasant St	2463	E	1.65	0.55	4.67	Yes	Yes	199.99
Cypress St	Magnolia St	Poplar St	2457	E	2.13	0.75	5.78	No	Yes	193.00
Commercial St	510 Commercial St	494 Commercial St	2470	W	1.93	0.74	5.31	Yes	Yes	686.96
Cedar St	School St	Park St	2478	E	1.17	0.45	5.06	Yes	Yes	306.59
Magnolia St	Cypress St	End	2492	S	2.51	0.66	4.73	No	Yes	528.84
Beech St	95 Beech St	101 Beech St	2502	N	1.39	1.06	5.3	Yes	Yes	69.76
Commercial St	Allen St	Taber Ct	1201	N	2.40	0.61	4.77	No	Yes	196.86
Commercial St	Commercial Ct	Commercial Ct	1202	S	1.25	0.64	5.01	Yes	Yes	338.22
Commercial St	Commercial Ct	Allen St	1203	S	0.94	0.50	5.19	Yes	Yes	440.21
Pleasant St	Church St	Cedar St	2486	N	1.55	0.59	5.2	Yes	Yes	779.53
Church St	On-Ramp	Bushnell Ter	2488	E	2.30	0.74	5.15	No	Yes	381.34
Cedar St	Thorndike St	School St	2503	E	0.60	0.53	5.84	Yes	Yes	204.28
Hobart St	Ochard St	Hobart St	2497	E	1.64	0.53	6.01	Yes	Yes	121.50
Wilkins Rd	25 Wilkins Rd	29 Wilkins Rd	2517	S	2.65	0.54	4.66	No	Yes	106.43
Wilkins Rd/N Bowditch St	90 Wilkins Rd	Dobson Rd	2519	N	2.28	0.55	5.08	No	Yes	535.15
Wilkins Rd	30 Wilkins Rd	46 Wilkins Rd	2520	N	1.65	0.57	5.54	Yes	Yes	174.22
Old Elm St	Blanchard Blvd	364 Elm St	2482	N	1.84	0.62	5.66	Yes	Yes	180.89
Elm St	372 Elm St	Lawview Dr	2481	N	0.66	0.44	5.25	Yes	Yes	120.89
Hobart St	Orchard St	Oakland St	2485	N	1.75	0.60	6.05	Yes	Yes	214.88
Commercial St	340 Commercial St	Commercial Ct	1204	S	1.43	0.52	5.78	Yes	Yes	125.15
Commercial St	Liberty St	Faxon St	1738	N	1.46	0.53	5.44	Yes	Yes	448.93
Heritage Ln	50 Heritage Ln	Heritage Ln	2550	S	1.67	0.48	5.71	Yes	Yes	135.83
Heritage Ln	35 Heritage Ln	End	2551	S	2.34	0.58	5.16	No	Yes	903.03
Elm St	Jay St	RR Crossing	2528	S	1.84	0.82	5.56	Yes	Yes	158.90
Washington Street	Sidewalk Island	Sidewalk Island	2537	E	1.23	0.61	6.83	Yes	Yes	51.07
Commercial St	Beech St	Magnolia St	2431	E	1.38	0.57	6.06	Yes	Yes	313.35
Commercial St	Liberty St	229 Commercial St	1739	N	2.03	0.51	5.92	No	Yes	303.87
Cedar St	Home Park Rd	Thorndike	2539	E	0.67	0.45	5.3	Yes	Yes	299.49
Hawthorn Rd	Thorndike St	Park St	2535	W	1.58	1.07	6.19	Yes	Yes	501.40
Hawthorn Rd	Home Park Rd	Thorndike St	2556	W	0.82	0.87	5.53	Yes	Yes	298.22
Longwood Rd	Home Park Rd	End	2558	W	2.22	1.10	4.65	No	Yes	499.17
Home Park Rd	Cedar St	Hawthorn Rd	2559	W	1.55	0.56	4.97	Yes	Yes	336.27
Independence Ave	Sidewalk Island	Sidewalk Island	2529	W	1.92	0.77	5.09	Yes	Yes	56.97
Commercial St	341 Commercial St	Allen St	1854	N	0.91	0.53	6	Yes	Yes	921.40
Elm St	RR Crossing	Commercial St	2566	S	1.61	0.87	4.65	Yes	Yes	774.45
Hawthorn Rd	White Rd	Home Park Rd	2585	W	2.27	1.37	5.07	No	Yes	309.52
Commercial St	494 Commercial St	Adams St	2435	W	1.39	0.57	5.37	Yes	Yes	255.23
Commercial St	Holden Rd	510 Commercial St	2541	W	2.30	0.73	5.54	No	Yes	303.80
Centre St	Independence Ave	53 Independence Ave Lot Entrance	2570	N	2.31	0.59	5.99	No	Yes	246.28
Cedar St	Washington St	Home Park Rd	2596	E	1.53	0.51	5.67	Yes	Yes	785.63
Independence Ave	80 Independence Dr	Washington St	2568	E	1.44	0.63	6.21	Yes	Yes	391.52
Hawthorn Rd	White Rd	Home Park Rd	2584	E	1.13	1.07	5.8	Yes	Yes	300.00
Hawthorn Rd	181 Hawthorn Rd	White Rd	2589	E	1.55	1.28	6.19	Yes	Yes	293.28
School St	Church St	Pleasant St	2588	N	1.71	0.68	4.8	Yes	Yes	77.92
Wilkins Rd	99 Wilkins Rd	111 Wilkins Rd	2583	S	1.99	0.98	5.66	Yes	Yes	120.74
Hayward St	Commercial St	Connell St	2605	S	2.74	0.70	5.26	No	Yes	818.70
Hayward St	Connell St	Huntley Rd	2613	S	2.15	0.74	5.78	No	Yes	212.37
Pine Crest Rd/Lawnview Dr	4 Pine Crest Rd	Elm St	2604	W	1.33	1.23	5.18	Yes	Yes	1403.74
Cleveland Ave	Merritt Ave	Putnam Ave	2740	E	1.25	0.57	5.1	Yes	Yes	163.73
Lawnview Dr	Elm St	End	2608	E	2.42	1.46	5.7	No	Yes	1420.94

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Old Elm St	364 Elm St	Lawview Dr	2607	N	1.73	0.57	5.11	Yes	Yes	229.04
Liberty St	Norfolk Rd	Zana Park Dr	1690	E	1.15	0.41	6.09	Yes	Yes	1873.52
Huntley Rd	Hayward St	End	2614	W	1.27	0.76	5.63	Yes	Yes	413.34
Huntley Rd/Hayward St	10 Huntley Rd	Highland Ave E	2627	N	2.27	0.75	4.86	No	Yes	347.22
Heritage Ln	20 Heritage Ln	20 Heritage Ln	2621	N	1.82	0.59	5.11	Yes	Yes	347.65
Commercial St	Holden Rd	Wilkins Rd	2543	E	2.90	0.72	6.15	No	Yes	532.69
Commercial St	Elm St	Holden Rd	2571	W	2.31	0.68	5.79	No	Yes	366.22
Pine Crest Rd/Lawnview Dr	9 Pine Crest Rd	122 Lawnview Dr	2606	W	2.33	0.82	3.47	No	No	231.02
Lincoln St	Liberty St	Claremont St	1724	N	1.66	0.58	5.87	Yes	Yes	651.64
N. Bowditch St	18 N Bowditch St	May St	2644	E	2.51	0.51	5.83	No	Yes	169.77
Howard St	Hayward St	Highland Ave E.	2658	W	1.61	1.06	5.45	Yes	Yes	293.63
Robert St	Loretta Ave	Holmes St	2669	E	2.02	1.06	5.6	No	Yes	900.07
Bower Rd	Rogers Cir	Commercial St	2663	S	2.69	0.67	5.66	No	Yes	206.89
Bower Rd	Burroughs Rd	Commercial St	2664	N	2.97	0.75	5.28	No	Yes	351.20
Robert St	Holmes St	Edwards Rd	2670	S	2.68	1.11	4.71	No	Yes	209.85
Conrad St	Blanchard Blvd	Elmlawn Rd	2653	N	2.99	0.97	4.59	No	Yes	233.08
Conrad St	Blanchard Blvd	Elmlawn Rd	2660	S	1.96	0.83	4.81	Yes	Yes	494.71
Lisle St	Sun Valley Dr	Liberty St	1733	W	0.91	0.54	4.75	Yes	Yes	1693.04
Hobart Ave	19 Hobart Ave	Washington St	2075	S	2.32	0.47	5.54	No	Yes	153.62
Conrad St	Edwards Rd	Elmlawn Rd	2668	N	1.64	0.85	4.21	Yes	Yes	199.62
Commercial St	Elm St	Holden Rd	2574	E	3.04	0.67	6.2	No	Yes	355.78
Pantano St/Erickson St	Erickson St	30 Erickson St	2656	N/A	0.72	0.64	6.12	Yes	Yes	964.34
Hollingsworth Ave S.	Franklin St	Oak Hill Rd	2076	N	3.76	1.03	4.63	No	Yes	234.10
Hobart Ave	Tremont St	Middle School Lot	2080	N	2.45	0.57	5.22	No	Yes	627.28
Robert St	Holmes St	Edwards Rd	2686	N	1.44	0.40	5.46	Yes	Yes	231.92
Maple St	Hollis Ave	Washington St	2221	E	1.25	0.55	5	Yes	Yes	701.43
Commercial St	RR Crossing	Elm St	2601	S	2.14	1.14	5.19	No	Yes	1080.04
John Paul Cir	Chickadee Ln	Commercial St	2684	W	4.13	0.92	5.92	No	Yes	354.06
John Paul Cir	70 John Paul Cir	Commercial St	2685	N	3.38	0.95	4.83	No	Yes	966.28
Hollis Ave	Maple St	May Ave	2228	S	2.52	0.56	4.82	No	Yes	342.22
Hollis Ave	Cochato Rd	Dearing Ave	2234	N	1.41	0.56	5.37	Yes	Yes	921.97
Robert St	Edwards Rd	Elmlawn Rd	2692	S	1.84	0.64	5.48	Yes	Yes	204.26
Commercial St	Erickson St	Hayward St	2602	N	1.08	0.60	5.81	Yes	Yes	458.16
Burroughs Rd	176 Burroughs Rd	Bower Rd	2679	E	0.97	0.65	5.19	Yes	Yes	633.51
Edwards Rd	Robert St	Conrad St	2680	W	1.83	1.04	4.96	Yes	Yes	382.93
Edwards Rd	Robert St	Conrad St	2683	E	1.23	1.19	5.48	Yes	Yes	372.18
Conrad St	Elmlawn Rd	Conrad St	2704	W	1.47	0.49	4.64	Yes	Yes	545.58
Hollis Ave	May Ave	Washington St	2237	S	2.40	0.56	5.04	No	Yes	301.76
Hollis Ave	May Ave	Washington St	2238	N	1.03	0.46	5.75	Yes	Yes	273.41
Howard St	Highland Ave E	Howard Ct	2682	W	2.63	1.07	6.17	No	Yes	331.47
Cindy Ln	Farm Rd	End	2743	W	1.04	0.83	6.16	Yes	Yes	290.38
Skyline Dr	42 Skyline Dr	30 Skyline Dr	2716	W	0.61	0.90	4.82	Yes	Yes	96.44
Middle St	Townsend Ave	Harrison Ave	2738	E	1.82	0.56	4.75	Yes	Yes	329.94
Tremont St	Academy St	Hobart Ave	2733	E	1.10	0.58	6.55	Yes	Yes	294.16
Reed Hill Road	26 Reed Hill Road	323 Franklin Street	2729	N	1.99	0.74	5.32	Yes	Yes	344.67
Washington Street	Sidewalk Island	Sidewalk Island	2727	E	2.01	0.58	5.48	No	Yes	16.51
Marshall St	Middle St	Penniman Ter	2739	N	3.36	0.56	4.65	No	Yes	332.94
Norton Street	Weston Ave	Hollingsworth Ave S	2734	W	1.88	0.81	5.57	Yes	Yes	679.44
Oak St	Hollis Ave	Monatiquot Ave	2737	E	0.94	0.48	5.94	Yes	Yes	346.51
Central Ave	87 Central Ave	27 Central Ave	2730	N	2.77	0.60	5.66	No	Yes	917.08
Academy St	Brow Ave	Washington St	2732	N	1.16	0.46	4.82	Yes	Yes	541.41
Central Ave	27 Central Ave	Washington St	2728	N	2.12	0.58	6.74	No	Yes	267.33
Lenox Dr	Liberty St	End	804	N	0.98	1.15	5.12	Yes	Yes	2412.41
Harvest Ln	10 Harvest Ln	Green House Way	2241	N	1.21	0.62	6.11	Yes	Yes	369.31
Commercial St	John Paul Cir	Bower Rd	2773	W	3.35	1.05	5.06	No	Yes	718.74
Tingley Rd	Cypress St	End	2751	S	1.22	0.57	5.7	Yes	Yes	178.20
Beech St	51 Beech St	Cypress St	2754	S	1.02	0.64	5.85	Yes	Yes	273.08
Hollingsworth Ave N.	Hobart Ave	174 Hobart Ave	2090	E	1.78	1.36	5.31	Yes	Yes	148.43
Church St	School St	Elm St	2749	E	2.74	0.71	5.15	No	Yes	706.32
Church St	Independence Ave	Bushnell Ter	2755	W	1.01	0.49	6.05	Yes	Yes	338.18

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Hollingsworth Ave S.	Oak Hill Rd	Talbot Rd	2082	N	3.26	1.07	4.3	No	Yes	310.40
Wilkins Rd	7 Wilkins Rd	19 Wilkins Rd	2756	S	2.41	0.49	5.72	No	Yes	117.56
Hollingsworth Ave S.	Talbot St	Norton St	2092	W	2.61	0.85	5.45	No	Yes	189.90
May Ave	12 May Ave	Washington st	2229	W	3.38	0.55	4.74	No	Yes	370.72
Hunt Ave	Jersey Ave	Cleveland Ave	2245	S	3.17	0.63	5.81	No	Yes	620.37
Bower Rd	Perry Rd	Burroughs Rd	2769	W	3.05	0.80	6.18	No	Yes	313.62
Middle St	Hunt Ave	Middle St	2246	E	0.91	0.43	5.02	Yes	Yes	108.78
Lisle St	Middle St	Rosewood Dr	1004	S	0.93	0.57	5.73	Yes	Yes	694.89
Lisle St	Connelly Cir	Louise Rd	1010	N	1.43	0.61	5.31	Yes	Yes	618.75
Elm St	Service Rd	Vinton Ave	2781	S	1.24	0.60	5.48	Yes	Yes	110.28
Bower Rd	Perry Rd	Rogers Cir	2783	E	1.51	0.77	4.94	Yes	Yes	425.03
Shaw St	Wellington St	Cotton Ave	2775	E	5.24	0.72	6.18	No	Yes	253.28
Shaw St	Cotton Ave	Newton Ave	2779	E	3.72	1.04	5.03	No	Yes	198.34
Hollingsworth Ave N.	Summer Ave	162 Hollingsworth Ave	2791	S	1.54	0.68	3.76	Yes	No	91.00
President Rd	100 President Rd	54 President Rd	2823	W	1.19	0.56	4.54	Yes	Yes	240.36
Independence Avenue	20ft from Quincy Town Line	Holmes Street	2811	E	0.52	0.83	5.51	Yes	Yes	101.81
Hobart Street	2 Hobart Street	128 Front Street	2813	W	4.70	0.62	5.19	No	Yes	70.35
Washington Street	4 Holmest Street	Quincy Town Line	2808	E	0.96	0.48	5.28	Yes	Yes	84.63
Quincy Ave	Dewey Rd	Hayward St	2784	W	2.92	1.02	5.31	No	Yes	698.57
Chickadee Ln	John Paul Cir	John Paul Cir	2774	N	4.20	1.10	6.01	No	Yes	687.37
Washington Street	198ft N of Summer St	Taylor St	2788	W	2.17	0.49	6.11	No	Yes	196.77
Commercial St	Adams St	Nickerson Rd	2776	W	3.84	0.60	6.08	No	Yes	631.49
Washington Street	594 Washington Street	594 Washington Street	2797	E	1.21	0.37	6.73	Yes	Yes	71.48
Hunt Ave	Jersey Ave	Cleveland Ave	2247	N	2.40	0.61	5.67	No	Yes	632.10
Middle St	Bv French St	Hunt Ave	2267	E	1.25	0.62	5.29	Yes	Yes	550.17
Middle St	River St	Hunt Ave	2269	W	1.30	0.57	5.6	Yes	Yes	753.31
Haven Rd	Cedar St	End	2799	S	2.74	0.47	5.21	No	Yes	285.86
Spruce St	Myrtle Street	16 Spruce St	2798	E	2.42	0.73	4.73	No	Yes	201.79
Howard St	Quincy/Braintree Town Line	Skyline Dr	2804	W	3.82	0.98	5.61	No	Yes	72.66
Conrad St	Quincy/Braintree Town Line	Robert St	2805	W	0.84	0.47	5.72	Yes	Yes	264.45
Centre St	53 Independence Ave Lot Entrance	End	2812	E	1.67	0.62	5.4	Yes	Yes	197.23
Lisle St	Middle St	Connelly Cir	1691	N	1.06	0.67	4.29	Yes	Yes	647.12
Commercial Street	Bower Rd	RR Crossing	2842	S	2.40	1.14	5.86	No	Yes	340.17
Adams Street	Elm Street	12 Adams Street	2841	N	2.32	0.96	6.01	No	Yes	172.25
Commercial Street	Quincy Town Line	25ft past 384 Franklin Street	2844	E	2.46	0.88	6.13	No	Yes	106.11
Farm Rd	Arnold St	End	2294	N	1.33	0.74	6.06	Yes	Yes	385.96
Middle St	River St	BV French St	2299	E	1.21	0.69	4.74	Yes	Yes	198.39
Middle St	Wilson Ave	River St	2315	E	1.09	0.59	5.48	Yes	Yes	214.65
Elm St	Washington St	69 Railroad St	2316	S	1.10	0.58	6.42	Yes	Yes	382.01
Elm St/Elm Terrace	Elm St	195 Elm St	2821	N	1.29	0.52	6.12	Yes	Yes	96.60
Granite Street	536 Granite Street	536 Granite Street	62	E	1.75	0.49	5	Yes	Yes	183.89
Wilkins Road	53 Wilkins Road	81 Wilkins Road	2848	S	2.26	0.62	6.1	No	Yes	419.84
Wilkins Road	81 Wilkins Road	99 Wilkins Road	2849	S	1.98	0.85	5.68	Yes	Yes	184.29
Bowditch Street	66 Bowditch Street	Front Street	2818	W	2.28	0.56	5.49	No	Yes	817.72
Dickerman Lane	83 Abbott Street	Bestick Road	2836	S	2.19	0.69	4.52	No	Yes	177.40
Windemere Circle	Storrs Avenue	49 Windemere Circle	2835	E	2.66	0.51	5.19	No	Yes	438.44
West Street	Herbert Road	Hollingsworth Avenue	2833	S	0.84	0.36	6.03	Yes	Yes	596.28
Windemere Circle	Storrs Avenue	66 Windemere Circle	2834	W	2.63	0.74	5.55	No	Yes	223.56
Dearing Avenue	15 Dearing Avenue	17 Hollis Avenue	2832	E	2.91	0.51	4.77	No	Yes	210.40
Washington Street	May Avenue	469 Washington Street	2831	W	1.33	0.40	4.76	Yes	Yes	109.68
Washington Street	469 Washington Street	Hollis Avenue	2830	W	1.06	0.49	5.8	Yes	Yes	436.84
Hollis Avenue	Ash Street	Maple Street	2829	S	1.91	0.51	5.65	Yes	Yes	211.00
Washington Street	West Street	Monatiquot Avenue	2828	W	1.30	0.58	6.17	Yes	Yes	250.63
Cochato Road	90ft from 17 Cochato Road	Hollis Avenue	2827	E	1.38	0.58	4.69	Yes	Yes	106.77
Wilmarth Road	55 Wilmarth Road	49 Wilmarth Road	2826	E	1.69	0.51	5.9	Yes	Yes	132.62
Union St	645 Union Street	Commercial St	1563	N	0.44	0.52	5.78	Yes	Yes	1050.53
Union St	Middle St	Strathmore Rd	1028	N	0.57	0.62	5.38	Yes	Yes	292.55
Union St	Washington St	Union St @ Braintree Station	911	S	1.59	0.57	5.3	Yes	Yes	1144.67
Union St	Entrance to 259 Union St	Williams Ct	979	S	0.79	0.50	5.37	Yes	Yes	422.52
Pilgrim Rd	Mayflower Rd	Mayflower Rd	1710	N/A	2.65	0.94	5.35	No	Yes	2060.22

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Edgehill Rd	Arthur St	Argyle Rd	2009	N	4.97	1.03	5.75	No	Yes	630.44
Edgehill Rd	Arthur St	Argyle Rd	2011	S	3.29	0.92	5.64	No	Yes	608.18
Union St	Pilgrim Highway Entrance	Cleveland Ave	1976	N	1.65	0.59	5.69	Yes	Yes	553.72
Union St	Hillside Rd	McCusker Dr	1864	W	1.18	0.49	6.25	Yes	Yes	623.29
Union St	70ft to Union St Exit Ramp	MA-3 On Ramp	1696	N	1.53	0.70	5.09	Yes	Yes	754.60
Lisle St	Louise Rd	Sun Valley Dr	1712	E	1.49	0.59	5.83	Yes	Yes	1571.72
Granite Street	540 Granite Street	540 Granite Street	1002	E	2.20	0.80	6.2	No	Yes	179.70
Middle St	Morrison St	Wilson Ave	2327	E	0.96	0.53	6.09	Yes	Yes	383.74
Front St	Bowditch St	Hobart St	2333	N	2.71	0.58	5.85	No	Yes	334.15
Elm St	Vinton Ave	10 Elm Terrace	2337	S	1.21	0.51	5.57	Yes	Yes	347.68
Elm St	School St	Charles St	2343	N	2.94	0.66	5.17	No	Yes	158.93
Morrison Rd	Morrison Rd	Adams St	2439	W	1.95	0.68	6.01	Yes	Yes	352.79
Elm St	Elmlawn Rd	Burrough Rd	2513	N	2.99	0.65	4.8	No	Yes	152.44
Elm St	Burrough Rd	Bower Rd	2527	N	2.91	0.92	6.15	No	Yes	218.88
River St	100 River St	106 River St	2290	N	3.18	0.70	5.34	No	Yes	80.73
River St	100 River St	Jersey Ave	2293	S	4.48	0.73	5.16	No	Yes	371.70
Storrs Ave	Oak St	Highland Rd	2266	S	1.56	0.45	6.1	Yes	Yes	223.97
Storrs Ave	Cochato Rd	Highland Rd	2273	S	1.53	0.50	5.68	Yes	Yes	214.93
Granite Street	250 Granite Street	250 Granite Street	1199	E	1.85	0.49	5.29	Yes	Yes	371.56
Robinson Ave	Mt. Vernon St	Washington St	2127	S	2.33	0.82	5.21	No	Yes	940.42
Hayward St	Donald E. Ross School Exit Road	Donald E. Ross School Entrance Road	2846	N	0.50	0.80	6.57	Yes	Yes	354.90
River St	Wine St	Spruce St	2297	N	2.23	0.76	5.86	No	Yes	314.76
River St	Spruce St	Middle St	2298	S	1.71	0.52	4.69	Yes	Yes	283.10
Hollis Ave	Walnut St	Oak St	2200	S	2.87	0.52	5.46	No	Yes	750.57
Hollis Ave	Walnut St	Oak St	2207	N	1.66	0.50	5.49	Yes	Yes	749.28
Hobart St	Hayward St	Deborah Ln	2579	E	1.61	0.61	5.95	Yes	Yes	933.92
Home Park Rd	Hawthorn Rd	Longwood Rd	2595	E	1.48	0.55	5.25	Yes	Yes	519.91
Hobart St	Mary St	Orchard St	2600	W	0.70	0.53	5.83	Yes	Yes	952.53
Home Park Rd	Longwood Rd	Blanchard Blvd	2612	E	1.48	0.54	5.81	Yes	Yes	210.56
Hayward St	Fairmount Ave	Shaw St	2630	S	0.71	0.80	5.8	Yes	Yes	253.59
Home Park Rd	Cedar St	Hawthorn Rd	2759	E	0.87	0.62	5.54	Yes	Yes	340.42
Hayward St	Hillcrest Rd	Fairmount Ave	2634	S	0.79	0.67	5.84	Yes	Yes	227.07
Hayward St	Highland Ave E	Howard St	2636	N	0.71	0.75	5.27	Yes	Yes	244.26
Hayward St	Hobart St	Shaw St	2638	N	2.36	0.66	5.77	No	Yes	663.64
Hayward St	Hobart St	Hillcrest Rd	2639	S	0.97	0.61	5.45	Yes	Yes	258.02
Hobart St	Hayward St	Mary St	2640	W	2.04	0.57	5.36	No	Yes	242.50
Hayward St	Highland Ave E.	N. Bowditch St	2641	S	1.45	0.74	5.25	Yes	Yes	250.89
Hayward St	Shaw St	Heritage Ln	2645	S	2.64	0.69	5.97	No	Yes	231.34
River St	Spruce St	Middle St	2300	N	2.09	1.02	5.54	No	Yes	283.51
Storrs Ave	40 Storrs Ave	Cochato Rd	2304	S	1.11	0.37	4.79	Yes	Yes	655.77
Storrs Ave	Washington St	40 Storrs Ave	2306	S	1.96	0.43	5.6	Yes	Yes	486.69
Sagamore St	Fountain St	73 Sagamore St	717	S	3.40	0.90	4.07	No	Yes	598.63
Middle St	Kew Rd	Union St	1032	E	1.33	0.61	5.51	Yes	Yes	373.69
Pearl St	Randall Ave	French Ave	786	N	2.14	0.40	5.39	No	Yes	177.11
Wood Road	400 Wood Road	400 Wood Road	11	W	2.21	0.95	4.64	No	Yes	68.03
Westin Ave	Mount Vernon Street	Weston Court	2101	N	2.32	0.93	5.77	No	Yes	624.80
Sagamore St	Fountain St	76 Sagamore St	726	N	4.35	1.09	4.61	No	Yes	584.72
Storrs Ave	Abbot St	Washington St	2307	N	1.48	0.39	4.97	Yes	Yes	905.01
Pearl St	Ivory St	Crawford Rd	1671	N	1.88	0.77	6.24	Yes	Yes	511.09
River St	Middle St	Arnold St	2301	S	1.95	0.44	5.07	Yes	Yes	770.57
Middle St	Logan Dr	515 Middle St	1642	W	1.49	0.76	5.08	Yes	Yes	919.88
Middle St	Elm St	Morrison St	2378	E	1.00	0.72	5.98	Yes	Yes	813.52
Heritage Ln	Hayward St	20 Heritage Ln	2648	E	2.49	0.54	5.51	No	Yes	180.59
Highland Ave E.	23 Highland Ave E	43 Highland Ave E	2649	E	0.96	0.89	4.26	Yes	Yes	371.57
Independence Ave	41 Independence Dr	80 Independence Dr	2654	E	0.92	0.58	5.81	Yes	Yes	584.69
Independence Ave	41 Independence Dr	80 Independence Dr	2657	W	1.58	0.69	5.32	Yes	Yes	602.84
Independence Ave	41 Independence Ave	41 Independence Ave	2659	W	1.51	0.74	5.72	Yes	Yes	84.82
Howard St	Hayward St	21 Howard St	2661	E	3.31	1.34	5.13	No	Yes	273.62
Middle St	Middle St	Whittier Rd	2742	N	1.76	0.52	5.97	Yes	Yes	234.44
Pearl St	Crescent Ave	96 Pearl St	788	S	1.96	0.53	5.96	Yes	Yes	625.74

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Pearl St	555 Liberty St	Liberty St	810	N	1.31	0.89	4.29	Yes	Yes	264.46
River St	Jersey Ave	Spruce St	2744	S	2.09	0.80	5.14	No	Yes	281.66
Fountain St	Columbus Ave	Victoria Ave	771	W	2.75	0.79	4.98	No	Yes	453.43
Stevens Ave	End	Pearl St	792	N	1.68	1.21	4.52	Yes	Yes	590.23
Weston Ave	Tremont St	Mt. Vernon St	2112	N	2.06	0.89	4.49	No	Yes	457.24
Columbus Ave	Fountain St	77 Columbus Ave	745	S	2.62	0.74	3.63	No	No	577.42
Columbus Ave	Fountain St	76 Columbus Ave	750	N	5.38	0.81	4.15	No	Yes	577.22
Liberty St	Albee Dr	1661 Liberty St	1595	W	1.30	0.62	5.81	Yes	Yes	518.28
Liberty St	1661 Liberty St	1608 Liberty St	1597	W	1.50	0.72	5.31	Yes	Yes	754.74
Evergreen Ave	Alida Rd	Fern Rd	1636	S	1.82	0.76	4.72	Yes	Yes	1407.83
Harness Ln	55 Harness Ln	40 Harness Ln	1770	N/A	2.72	0.87	5.3	No	Yes	773.13
Hobart St	Hobart Terrace	Front St	2356	E	3.63	0.59	4.81	No	Yes	610.34
Wood Road	355 Wood Road	400 Wood Road	12	W	1.54	0.72	4.86	Yes	Yes	121.83
Brooks Drive	48 Brooks Drive	48 Brooks Drive	13	S	2.62	0.67	5.65	No	Yes	148.07
Brooks Drive	60 Brooks Dr	48 Brooks Dr	14	W	2.95	0.70	5.03	No	Yes	197.30
Brooks Drive	41 Brooks Drive	Cemetery Entrance	15	E	0.95	0.65	5.95	Yes	Yes	1256.69
Forbes Road	Cemetery Rd	Cemetery Rd	16	E	0.94	0.59	5.62	Yes	Yes	200.13
Pond Street	578 Pond Street	570 Pond Street	529	E	1.91	0.61	5.45	Yes	Yes	248.82
Pond Street	439 Pond Street	473 Pond Street	622	W	2.35	0.92	5.05	No	Yes	265.90
Oak Hill Rd	Hollingsworth Ave	Hollingsworth Ave	973	N/A	1.62	0.76	5.11	Yes	Yes	1650.41
John Paul Cir	Chickadee Ln	Chickadee Ln	2712	N	3.94	1.33	6.16	No	Yes	987.78
Connell St	Avon Pl	Hayward St	1902	W	0.99	0.50	6.05	Yes	Yes	703.99
Talbot Rd	Hollingsworth Ave S	End	2083	E	3.00	1.06	4.53	No	Yes	400.88
Pond Street	614 Pond Street	578 Pond Street	528	E	1.22	0.48	5.95	Yes	Yes	281.20
Granite Street	935 Granite Street	951 Granite Street	688	W	3.09	0.71	4.62	No	Yes	361.77
Nicholas Rd	Francine Rd	Common St	1278	S	1.39	0.96	3.43	Yes	No	893.97
Robert St	Loretta Ave	Holmes St	2770	W	1.47	1.16	5.05	Yes	Yes	983.88
Holmes St	Washington St	Robert St	2702	N	1.09	0.57	5.59	Yes	Yes	930.04
Bushnell Terr	Church St	15 Bushnell Terrace	2506	S	3.58	0.84	4.55	No	Yes	174.72
Conrad St	Elmlawn Rd	Robert St	2709	E	1.88	0.59	4.66	Yes	Yes	587.29
Loretta Ave	Washington St	Robert St	2678	S	1.76	0.97	4.87	Yes	Yes	213.08
Loretta Ave	Washington St	Holmes St	2681	N	1.80	1.14	5.82	Yes	Yes	585.47
Loretta Ave	Robert St	Holmes St	2687	S	1.81	0.97	5.17	Yes	Yes	322.27
Holmes St	Loretta Ave	Robert St	2688	W	2.25	0.47	5.32	No	Yes	192.92
Holmes St	Washington St	Loretta Ave	2700	S	1.10	0.54	6	Yes	Yes	655.28
Hawthorn Rd	Home Park Rd	Old Elm St	2557	E	1.49	1.14	5.58	Yes	Yes	1468.27
Howard St	Highland Ave E	Shaw St	2662	E	3.87	1.14	4.64	No	Yes	989.26
Independence Ave	Townline	41 Independence Ave	2665	W	1.85	0.65	5.34	Yes	Yes	186.48
Pond Street	531 Pond Street	500 Pond Street	565	W	1.64	0.39	5.4	Yes	Yes	524.15
Armstrong Circle	76 Armstrong Circle	44 Armstrong Circle	569	E	2.20	1.05	5.21	No	Yes	475.05
Armstrong Circle	61 Armstrong Circle	512 Pond Street	574	N	1.50	0.85	6.28	Yes	Yes	556.07
Pond Street	512 Pond Street	500 Pond Street	587	E	1.75	0.39	5.49	Yes	Yes	226.70
Pond Street	483 Pond Street	495 Pond Street	608	W	2.41	1.89	3.35	No	No	265.35
Pond Street	6 Ida Road	522 Pond Street	1647	E	1.84	0.80	5.73	Yes	Yes	544.75
Spring St	Congress St	Congress St	776	E	0.93	0.72	5.46	Yes	Yes	1126.31
Spring St	E. Boscobel St	Congress St	777	N	1.77	0.81	4.11	Yes	Yes	824.72
Congress St	Kendall Ave	Spring St	703	S	2.30	0.87	4.49	No	Yes	481.18
Elmlawn Rd	Conrad St	Perry Rd	2666	W	1.94	0.60	5.12	Yes	Yes	1112.61
Barstow Dr	111 Barstow Road	5 McCue Drive	530	N/A	1.68	0.88	6.13	Yes	Yes	1149.03
Amherst Rd	Portland Rd	Portland Rd	1630	E	2.70	0.56	5.94	No	Yes	821.04
Amherst Rd	Portland Rd	Portland Rd	1631	W	2.07	0.52	5.35	No	Yes	727.95
Bushnell Terr	27 Bushnell Terrace	Capen Rd	2508	S	2.94	0.70	4.14	No	Yes	56.26
Bushnell Terr	Church St	Capen Rd	2512	N	2.80	0.56	5.36	No	Yes	327.80
Hayward St	Hayward St	Shaw St	2673	W	1.47	0.96	5.38	Yes	Yes	142.05
Elmlawn Rd	Robert St	Conrad St	2693	W	1.50	0.46	5.1	Yes	Yes	376.83
Elmlawn Rd	Robert St	Conrad St	2694	E	1.52	0.59	4.03	Yes	Yes	375.69
Elmlawn Rd	210 Elmlawn Rd	Robert St	2701	N/A	1.35	0.64	6.12	Yes	Yes	770.52
Forbes Road	Cemetery Rd	262 Forbes Road	17	E	2.00	0.89	6.04	No	Yes	847.24
Pond Street	348 Pond Street	3 Lake Street	646	S	2.61	0.87	4.74	No	Yes	205.19
Armstrong Circle	39 Armstrong Circle	61 Armstrong Circle	583	W	2.63	1.13	5.44	No	Yes	227.96

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Pond Street	364 Pond Street	354 Pond Street	609	S	3.38	0.66	5.09	No	Yes	217.91
Pond Street	490 Pond Street	364 Pond Street	610	E	2.28	0.67	5.09	No	Yes	1630.80
Pond Street	6 King Hill Road	453 Pond Street	623	W	3.20	0.59	6.06	No	Yes	646.85
Pond Street	333 Pond Street	359 Pond Street	650	N	2.70	0.74	5.85	No	Yes	290.02
Pond Street	369 Pond Street	409 Pond Street	661	N	2.32	1.01	6.19	No	Yes	226.86
Pond Street	411 Pond Street	426 Pond Street	662	W	1.93	0.71	4.32	Yes	Yes	359.96
Pond Street	426 Pond Street	411 Pond Street	669	E	1.91	0.76	3.9	Yes	No	270.26
Pond Street	411 Pond Street	411 Pond Street	670	S	2.71	0.69	5.26	No	Yes	201.13
Rome Drive	6 Rome Drive	6 Rome Drive	684	E	1.12	0.44	5.31	Yes	Yes	205.51
Liberty St	Liberty St Rotary Entrance	Zana Park Dr	872	N	1.01	0.48	6.06	Yes	Yes	705.66
King Hill Road	6 Rome Drive	6 King Hill Road	673	S	1.76	0.49	5.01	Yes	Yes	1193.78
Calvin Street	75 Addison Street	35 Fallon Circle	1047	S	2.56	0.84	4.47	No	Yes	1020.40
Pond Street	225 Pond Street	9 Tower Hill Road	683	N	3.07	0.91	5	No	Yes	403.66
Pond Street	8 Tower Hill Road	301 Pond Street	660	N	3.47	0.74	5.86	No	Yes	525.25
Granite Street	Bay State Dr	409 Pond Street	686	E	3.20	0.83	4.65	No	Yes	468.90
Miller Ave	Liberty St	End	1779	N	1.49	0.52	5.36	Yes	Yes	402.47
Granite Street	Campanelli Dr	5 Emerald Avenue	775	E	2.22	0.69	5.31	No	Yes	271.53
Granite Street	Campanelli Dr	Lundquist Dr	811	W	1.61	0.72	5.01	Yes	Yes	372.04
Granite Street	903 Granite Street	917 Granite Street	731	W	1.44	0.66	5.87	Yes	Yes	367.33
King Hill Road	105 King Hill Road	157 King Hill Road	734	N	1.35	0.46	5.02	Yes	Yes	886.04
Granite Street	891 Granite Street	891 Granite Street	740	W	1.81	0.74	5.3	Yes	Yes	74.15
Granite Street	875 Granite Street	883 Granite Street	760	W	0.83	0.80	6.15	Yes	Yes	163.13
Granite Street	869 Granite Street	869 Granite Street	774	W	1.55	0.69	5.33	Yes	Yes	100.64
Granite Street	6 Emerald Avenue	732 Granite Street	869	E	1.86	0.92	6.12	Yes	Yes	1365.28
Granite Street	773 Granite Street	Lundquist Drive	870	W	1.19	0.72	6.08	Yes	Yes	950.88
Granite Street	4 Anderson Road	598 Granite Street	961	E	1.32	0.60	6.06	Yes	Yes	991.83
Granite Street	565 Granite Street	639 Granite Street	981	W	2.81	0.71	5.26	No	Yes	344.45
West Street	539 Granite Street	7 Burton Road	991	N	1.30	0.62	5.56	Yes	Yes	1605.74
West Street	8 Burton Road	7 Addison Street	995	N	0.95	0.51	6.06	Yes	Yes	287.29
Granite Street	467 Granite Street	539 Granite Street	1001	W	2.12	0.73	5.15	No	Yes	1069.48
Eleanor Drive	47 Addison Street	48 Burton Road	1017	S	2.25	0.73	5.22	No	Yes	309.91
Burton Road	48 Burton Road	8 Burton Road	1018	W	1.91	0.83	5.22	Yes	Yes	702.20
Burton Road	7 Burton Road	50 Eleanor Drive	1019	E	2.14	0.83	4.57	No	Yes	696.78
Eleanor Drive	50 Eleanor Road	6 Eleanor Road	1022	S	2.16	0.75	4.32	No	Yes	686.82
Eleanor Drive	47 Fallon Circle	61 Addison Street	1023	N	2.28	0.89	5.37	No	Yes	1020.20
Addison Street	61 Addison Street	75 Addison Street	1045	E	1.80	0.76	4.49	Yes	Yes	338.69
Pond Street	8 Royal Lake Drive	215 Pond Street	708	N	3.06	0.91	5.05	No	Yes	631.02
Fallon Circle	47 Fallon Circle	35 Fallon Circle	1048	W	2.27	0.82	4.96	No	Yes	325.14
Calvin Street	19 Fallon Circle	91 Addison Street	1050	N	1.64	0.92	4.8	Yes	Yes	1021.67
Davis Road	91 Addison Street	16 Davis Road	1064	S	2.07	1.07	6.11	No	Yes	1339.92
Fallon Circle	16 Davis Road	19 Fallon Circle	1070	W	2.35	0.88	5.08	No	Yes	324.40
Blossom Road	87 Brierwood Road	87 Blossom Road	1089	W	2.25	0.69	5.18	No	Yes	338.62
Brierwood Road	57 Blossom Road	46 Partridge Road	1094	E	1.83	0.55	5.91	Yes	Yes	1061.51
Partridge Hill Road	46 Partridge Hill Road	32 Partridge Hill Road	1135	S	2.76	0.95	4.8	No	Yes	297.33
Blossom Road	32 Partridge Hill Road	57 Blossom Road	1136	W	1.83	0.42	5.36	Yes	Yes	834.11
Forbes Road	222 Forbes Road	222 Forbes Road	1142	S	1.35	0.53	5.24	Yes	Yes	55.41
Partridge Hill Road	20 Partridge Hill Road	287 Granite Street	1145	S	2.91	1.15	4.65	No	Yes	321.51
Forbes Road	220 Forbes Road	220 Forbes Road	1146	S	1.81	0.55	5.83	Yes	Yes	216.73
Granite Street	265 Granite Street	265 Granite Street	1152	W	3.53	0.69	5.77	No	Yes	86.45
Granite Street	10 Forbes Road	265 Granite Street	1157	W	2.84	0.95	6.03	No	Yes	199.16
Forbes Road	20 Forbes Road	20 Forbes Road	1166	S	2.51	0.38	5.79	No	Yes	189.99
Forbes Road	30 Forbes Road	30 Forbes Road	1171	E	1.73	0.47	5.74	Yes	Yes	70.77
Granite Street	On-Ramp	Off-Ramp	1216	W	1.54	0.63	5.86	Yes	Yes	114.19
Wood Road	165 Wood Road	115 Wood Road	1219	W	1.60	0.64	5.79	Yes	Yes	697.12
Granite Street	Off-Ramp	North St	1244	W	1.75	0.88	3.4	Yes	No	72.32
Wood Road	2 Adams Place	14 Wood Road	1283	E	1.41	0.73	5.29	Yes	Yes	1568.65
Rockdale Street	20 Rockdale St	35 Braintree Hill Office Park	1302	S	2.05	0.98	6.25	No	Yes	379.94
Rockdale Street	35 Braintree Hill Office Park	35 Braintree Hill Office Park	1305	S	1.77	0.71	6.75	Yes	Yes	227.84
Braintree Hill Park	35 Braintree Hill Park	35 Braintree Hill Park	1295	S	0.85	0.96	5.32	Yes	Yes	46.69
Davis Road	7 Davis Road	86 Blossom Road	1077	N	1.75	0.91	4.63	Yes	Yes	651.33

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Forbes Road	Grandview Rd	30 Forbes Road	1170	S	1.99	0.60	5.87	Yes	Yes	177.31
Partridge Hill Road	49 Partridge Hill Road	62 Partidge Hill Road	1128	N/A	2.78	0.57	5.11	No	Yes	756.01
Granite Street	Chickatawbut Road	75 Granite Street	1309	W	2.54	1.14	5.44	No	Yes	95.34
Granite Street	20 Granite Street	44 Granite Street	1311	E	0.90	0.44	4.67	Yes	Yes	328.02
Granite Street	20 Granite Street	20 Granite Street	1335	E	1.47	0.71	5.95	Yes	Yes	156.26
Granite Street	4 Granite Street	20 Granite Street	1342	E	1.68	0.72	5.36	Yes	Yes	45.58
West Street	388 West Street	565 Granite Street	1502	S	2.59	0.63	6.21	No	Yes	513.50
Granite Street	Off-Ramp	On-Ramp	1530	W	1.47	0.58	5.34	Yes	Yes	709.26
North Street	150 Granite Street	150 Granite Street	1532	S	2.20	0.80	4.98	No	Yes	41.59
Rockdale Street	Granite St	1 Rockdale Street	1538	S	1.85	0.94	5.79	Yes	Yes	74.34
Rockdale Street	1 Rockdale Street	1 Rockdale Street	1539	S	1.50	0.81	7.5	Yes	Yes	79.26
Rockdale Street	1 Rockdale Street	15 Braintree Hill Park	1540	S	2.01	1.04	5.65	No	Yes	154.31
Rockdale Street	15 Braintree Hill Park	20 Rockdale St	1541	S	1.10	1.07	7.13	Yes	Yes	195.85
Braintree Hill Park	45 Braintree Hill Park	35 Braintree Hill Park	1542	E	1.63	0.83	5.45	Yes	Yes	32.98
Braintree Hill Park	50 Braintree Hill Park	50 Braintree Hill Park	1543	W	2.12	0.96	6.07	No	Yes	190.60
Blueberry Drive	45 Braintree Hill Park	30 Braintree Hill Park	1544	E	0.53	1.01	6.58	Yes	Yes	403.45
Granite Street	Chickatawbut Road	2 Adams Place	1546	W	1.54	0.61	6.8	Yes	Yes	115.68
Granite Street	4 Granite Street	4 Granite Street	1548	E	4.03	1.12	5.29	No	Yes	50.25
Wood Road	14 Wood Road	75 Granite Street	1549	S	1.49	0.56	7.21	Yes	Yes	220.95
Forbes Road	10 Forbes Road	10 Forbes Road	1550	S	2.89	0.54	5.13	No	Yes	104.94
Forbes Road	170 Forbes Rd	161 Forbes Rd	1552	S	1.44	0.70	5.85	Yes	Yes	11.36
Forbes Road	222 Forbes Road	220 Forbes Road	1553	S	1.52	0.46	6.14	Yes	Yes	87.11
Forbes Road	161 Forbes Road	161 Forbes Road	1554	N	2.53	0.38	5.35	No	Yes	21.84
Forbes Road	161 Forbes Road	161 Forbes Road	1555	N	2.05	0.73	5.91	No	Yes	152.05
Rome Drive	62 Rome Drive	5 Fabiano Drive	1590	S	0.85	0.42	5.07	Yes	Yes	681.62
King Hill Road	75 King Hill Road	95 King Hill Road	1591	N	1.41	0.60	5.1	Yes	Yes	150.56
Granite Street	Davis Rd	467 Granite St	1501	W	1.50	0.82	5.98	Yes	Yes	475.05
Partridge Hill Road	275 Granite Street	49 Partridge Hill Road	1537	N	3.59	0.77	5.49	No	Yes	759.00
Armstrong Circle	40 Armstrong Circle	490 Pond Street	1650	N	2.20	0.67	5.51	No	Yes	580.12
Blossom Road	86 Blossom Road	20 Partridge Hill Road	1731	E	0.80	0.63	4.77	Yes	Yes	1243.77
Granite Street	721 Granite Street	5 Andersen Road	1682	E	1.18	0.59	5.42	Yes	Yes	884.41
Brierwood Road	62 Partridge Hill Road	87 Brierwood Road	1707	W	1.80	0.48	6.16	Yes	Yes	1876.30
Addison Street	104 Addison Street	62 Addison Street	1718	W	2.47	0.71	4.5	No	Yes	716.49
Granite Street	333 Granite Street	7 Davis Road	1729	W	2.50	0.68	5.71	No	Yes	1051.78
Granite Street	287 Granite Street	321 Granite Street	1734	W	2.40	0.95	5.59	No	Yes	560.98
Forbes Road	220 Forbes Road	170 Forbes Road	1736	S	1.81	0.47	5.46	Yes	Yes	593.92
Braintree Hill Park	25 Braintree Hill Park	35 Braintree Hill Park	1758	S	1.40	1.19	6.86	Yes	Yes	245.12
Delta Road	359 Pond Street	369 Pond Street	1656	N/A	2.30	0.75	5.45	No	Yes	1187.44
Danielle Ln	Danielle Ln	End	1438	S	1.71	0.94	3.57	Yes	No	74.78
Webster Rd/Wilmarth Rd	104 Wyman Rd	54 Wilmarth Rd	2194	N/A	3.40	0.54	6.15	No	Yes	962.61
Davis Road	87 Blossom Road	89 Davis Road	1719	N	2.49	0.82	5.46	No	Yes	445.89
Granite Street	Granite St NB	Granite St SB	1777	S	1.15	0.78	5.6	Yes	Yes	33.84
Fallon Circle	6 Eleanor Drive	58 Fallon Circle	1715	N/A	2.14	0.83	6.04	No	Yes	786.12
Holmes St	Independence Ave	Fairfield St	2675	N	2.17	0.83	4.33	No	Yes	488.53
Braintree Hill Park	35 Braintree Hill Park	35 Braintree Hill Park	1759	S	1.97	1.19	6.15	Yes	Yes	232.46
Pond Street	305 Pond Street	333 Pond Street	649	N	2.51	0.68	5.52	No	Yes	385.46
Pond Street	4 Lake Street	320 Pond Street	651	S	2.56	0.97	4.71	No	Yes	255.11
Pond Street	306 Pond Street	268 Pond Street	656	S	2.38	0.74	5.16	No	Yes	600.50
Pond Street	266 Pond Street	250 Pond Street	663	S	2.16	0.60	5.21	No	Yes	154.92
Pond Street	250 Pond Street	250 Pond Street	671	S	2.67	0.84	5.05	No	Yes	104.34
Pond Street	244 Pond Street	244 Pond Street	678	S	2.03	0.72	6.05	No	Yes	132.27
Pond Street	244 Pond Street	244 Pond Street	689	S	2.77	0.96	5.59	No	Yes	201.17
Pond Street	74 Pond Street	20 Pond Street	699	S	2.19	0.70	6.27	No	Yes	1463.95
Pond Street	216 Pond Street	178 Pond Street	704	S	3.64	0.88	4.75	No	Yes	545.76
Pond Street	164 Pond Street	132 Pond Street	709	S	2.25	0.86	6.17	No	Yes	516.35
Pond Street	165 Pond Street	165 Pond Street	713	N	3.74	0.89	6.09	No	Yes	165.80
Pond Street	2 Sunset Road	7 Canal Street	718	N	1.96	0.48	5.89	Yes	Yes	153.35
Pond Street	122 Pond Street	3 Fairview Avenue	723	S	2.78	0.76	4.83	No	Yes	117.49
Pond Street	9 Pond Street	143 Pond Street	724	N	2.85	0.72	6.19	No	Yes	1671.69
Royal Lake Drive	165 Pond Street	18 Royal Lake Drive	753	E	0.77	0.47	5.21	Yes	Yes	876.37

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Sunset Road	6 Sunset Road	2 Sunset Road	1462	W	3.66	1.06	4.94	No	Yes	283.29
John W. Mahar Hwy	Plain St	Unnamed Exit Road	722	W	1.42	0.84	5.32	Yes	Yes	1373.93
Tremont St	Brow Ave	Academy St	2094	E	1.14	0.52	3.93	Yes	No	257.06
Tremont St	Lakeview Ave	Central Ave	2069	W	2.79	0.57	5.7	No	Yes	1036.72
Summer St	Tremont St	Central St	2055	N	1.85	1.06	3.99	Yes	No	289.38
Tremont St	Central Ave	Taylor St	2064	W	2.86	0.42	5.65	No	Yes	367.33
Tremont St	Central Ave	Taylor St	2065	E	2.13	0.40	5.83	No	Yes	376.18
Elm St	Adams St	Drinkwater Ave	2752	S	1.71	0.98	5.96	Yes	Yes	1017.70
Hawthorn Rd	Park St	Elm St	2753	W	4.09	0.91	4.78	No	Yes	627.32
Town Street	6 Cameo Road	305 Pond Street	805	W	0.82	0.40	4.79	Yes	Yes	1703.00
Town Street	301 Pond Street	128 Town Street	808	E	1.03	0.41	6.04	Yes	Yes	1713.83
Cameo Road	28 Emerald Avenue	6 Cameo Road	817	S	0.99	0.52	5.2	Yes	Yes	500.59
Town Street	128 Town Street	128 Town Street	866	E	0.98	0.35	4.69	Yes	Yes	636.93
Town Street	128 Town Street	128 Town Street	891	E	1.26	0.46	5.86	Yes	Yes	263.11
Parkside Avenue	Storrs Avenue	142 Walnut Street	1149	S	2.03	0.62	5.27	No	Yes	467.41
Emerald Avenue	51 Emerald Avenue	28 Emerald Avenue	794	N	1.44	0.64	5.09	Yes	Yes	195.64
Lake Street	55 Lake Street	55 Lake Street	1489	W	3.46	0.81	4.2	No	Yes	23.95
Lake Street	80 Lake Street	50 Lake Street	1491	E	2.98	1.15	4.84	No	Yes	466.04
Lunar Avenue	70 Solar Avenue	39 Lunar Avenue	596	W	2.20	0.76	5.32	No	Yes	726.44
Lunar Avenue	8 Altair Avenue	6 Lunar Avenue	598	E	3.23	0.67	5.22	No	Yes	541.86
Lunar Avenue	12 Stellar Road	50 Solar Avenue	599	N	4.26	1.04	5.14	No	Yes	214.58
Sherman Road	178 Pond Street	25 Sherman Road	1470	N	3.78	0.90	5.87	No	Yes	364.81
Common Street	Ledge Rd	Ledge Rd	1247	N	1.43	0.58	5.28	Yes	Yes	137.20
Common Street	Ledge Rd	250 Granite St	1249	N	1.67	0.56	5.9	Yes	Yes	667.99
Common Street	363 Common Street	387 Common Street	1250	N	1.49	0.63	5.56	Yes	Yes	225.04
Common Street	368 Common Street	364 Common Street	1251	S	2.08	0.73	4.72	No	Yes	240.45
Common Street	348 Common Street	346 Common Street	1254	S	2.00	0.82	6.21	No	Yes	204.92
Common Street	231 Common Street	321 Common Street	1259	N	1.92	0.67	5.38	Yes	Yes	1308.18
Common Street	228 Common Street	194 Common Street	1276	S	1.79	0.67	3.74	Yes	No	497.66
Common Street	184 Common Street	172 Common Street	1285	S	2.39	0.49	4.29	No	Yes	218.02
Common Street	162 Common Street	154 Common Street	1293	S	2.64	0.52	4.62	No	Yes	259.70
Common Street	6 Hedlund Avenue	219 Common Street	1279	N	1.61	0.58	5.02	Yes	Yes	622.95
Howard Ct	11 Howard Court	Howard Street	2816	N	1.86	0.71	5.23	Yes	Yes	141.73
Common Street	32 Peak Street	264 Common Street	1753	S	1.80	0.69	4.02	Yes	Yes	709.49
Common Street	60 Common Street	34 Common Street	2421	S	2.78	0.66	5.61	No	Yes	422.47
Common Street	61 Common Street	167 Common Street	1300	N	2.39	0.63	5.8	No	Yes	1339.61
Common Street	5 Cavanaugh Road	5 Cavanaugh Road	2382	N	4.15	0.88	5.51	No	Yes	237.51
Common Street	18 Common Street	10 Common Street	2393	S	2.20	0.68	6.11	No	Yes	239.02
Common Street	2 Cavanaugh Road	41 Common Street	2422	N	2.69	0.64	4.67	No	Yes	309.52
Common Street	59 Common Street	57 Common Street	2429	N	2.62	0.61	4.7	No	Yes	179.56
Walnut Street	50 Walnut Street	175 West Street	2182	W	1.15	0.49	5.69	Yes	Yes	580.07
Liberty Street	1748 Liberty Street	1776 Liberty Street	18	E	2.05	1.04	5.31	No	Yes	428.70
Old Country Way	Old Carriage Lane	Leehaven Terrace	151	E	2.60	0.66	5.24	No	Yes	1098.98
Penniman Terrace	21 Marshall Street	3 Strathmore Circle	1090	W	1.47	0.45	5.76	Yes	Yes	471.47
Tremont St	Brow Ave	Academy St	2099	W	1.64	0.58	4.69	Yes	Yes	296.91
Milton Road	112 Milton Road	Cain Avenue	79	N	2.00	0.68	5.74	No	Yes	586.71
Albee Drive	Liberty Street	Gray Terrace	78	S	3.25	0.61	5.19	No	Yes	1378.73
Tremont St	Brow Ave	Weston Ave	2108	E	1.19	0.42	4.5	Yes	Yes	316.67
Tremont St	Weston Ave	280 Termont St	2110	W	1.75	0.51	4.73	Yes	Yes	321.81
Holmes Street	72 Holmes Street	Washington Street	2809	N	1.13	0.63	4.71	Yes	Yes	87.19
Old Country Way	Bayberry Lane	38 Old Country Way	152	W	2.23	0.69	4.76	No	Yes	1174.32
Liberty Street	1718 Liberty Street	Albee Drive	21	E	3.68	0.08	4.04	No	Yes	56.41
Washington Street	Foster Road	Catherine Drive	22	W	2.44	0.44	4.82	No	Yes	330.63
Washington Street	Catherine Drive	South Street	23	W	1.51	0.52	3.95	Yes	No	262.07
South Street	Old Country Way	30ft from Washington Street	24	W	1.28	0.69	5.53	Yes	Yes	52.43
Faxon Street	66 Faxon Street	Stetson Street	32	E	1.62	0.66	5.7	Yes	Yes	131.10
Hancock Street	Washington Street	Hall Avenue	33	W	1.28	0.56	5.31	Yes	Yes	513.25
Webster Road	25ft from Washington Street	10 Webster Road	35	N	1.24	0.47	5.01	Yes	Yes	72.92
Woodedge Avenue	25 Woodedge Avenue	South Street	38	N	2.13	0.57	4.67	No	Yes	388.73
Washington Street	Water Street	2140 Washington Street	39	E	0.91	0.54	5.25	Yes	Yes	742.33

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Mann Street	Drake Street	46 Ashworth Ave	48	N	1.51	0.63	4.29	Yes	Yes	111.35
Devon Wood Drive	20ft from Devon Club Lane	Tilden Commons Lane	52	N	1.67	0.35	4.15	Yes	Yes	500.94
Richard Road	46 Richard Road	72 Richard Road	55	E	2.51	0.88	5.16	No	Yes	290.92
East Division Street	Livoli Avenue	Liberty Street	64	N	2.30	0.64	4.81	No	Yes	403.06
Atherton Street	Liberty Street	Willard Street	1121	S	1.68	0.53	5.74	Yes	Yes	420.60
Woodedge Avenue	4 Woodedge Circle	South Street	42	S	2.29	0.62	5.13	No	Yes	372.79
Forest Street	11 Birch Street	6 Winter Street	53	E	1.51	0.83	6.04	Yes	Yes	435.92
Daniel Road	46 Winter Street	69 Birch Street	54	W	0.85	0.73	6.06	Yes	Yes	222.21
Storrs Avenue	162 Parkside Avenue	114 Walnut Street	61	S	1.84	0.58	5.56	Yes	Yes	166.77
Stetson Street	98 Stetson Street	109 Bellevue Road	1115	N	1.39	0.49	5.16	Yes	Yes	199.68
Willard Street	21 Atherton Street	Claremont Street	1117	W	1.25	0.43	5.97	Yes	Yes	223.90
Willard Street	Claremont Street	20ft from Stetson Street	1118	E	1.18	0.50	4.85	Yes	Yes	424.82
Liberty Street	Claremont Street	Atherton Street	1120	E	1.20	0.48	5.95	Yes	Yes	215.33
Richard Road	Marjorie Road	Grace Road	2855	W	2.44	0.70	4.59	No	Yes	289.00
Hobart Street	60 Hobart Street	60 Hobart Street	2814	W	2.63	0.43	6.19	No	Yes	31.15
Skyline Drive	75 Skyline Drive	55 Skyline Drive	2815	E	1.65	0.65	5.25	Yes	Yes	247.23
Hickory Road	Holly Road	Liberty Street	57	W	2.87	0.70	5.2	No	Yes	571.49
Cain Avenue	38 Cain Avenue	20 Cain Avenue	93	W	2.44	0.93	5.92	No	Yes	251.50
Deigan Avenue	Cain Avenue	Paul Street	94	S	2.21	1.00	5.67	No	Yes	384.74
Paul Street	Deigan Avenue	Lawson Lane	95	W	1.30	1.39	4.72	Yes	Yes	232.25
Paul Street	19 Paul Street	43 Paul Street	96	E	2.79	0.76	4.49	No	Yes	262.07
Albee Drive	Gray Terrace	Canavan Drive	115	E	2.32	0.75	5.11	No	Yes	722.56
Cain Avenue	Selwyn Road	Milton Road	118	W	2.06	0.78	5.1	No	Yes	287.14
South Street	Old Country Way	Woodedge Avenue	121	N	1.90	0.98	5.2	Yes	Yes	805.63
Canavan Drive	Liberty Street	Albee Drive	129	S	2.45	0.70	4.67	No	Yes	809.44
Summit Ridge Drive	Cain Avenue	Bramblewood Lane	134	N	1.24	0.69	4.66	Yes	Yes	247.40
Hayward St	N. Bowditch St	Hobart St	2766	S	1.69	0.91	5.34	Yes	Yes	436.25
Woodedge Avenue	Woodedge Lane	Woodedge Circle	139	S	2.06	0.65	4.77	No	Yes	170.30
Washington Street	Virginia Road	Boylston St	99	E	0.40	0.40	5.23	Yes	Yes	229.28
South Street	Unnamed Road	Washington Street	128	E	1.99	0.70	6.1	Yes	Yes	759.34
Deigan Avenue	Cain Avenue	Paul Street	97	N	1.93	1.03	5.11	Yes	Yes	385.56
Canavan Dr	70 Canavan Drive	79 Canavan Drive	117	N/A	3.72	0.81	6.11	No	Yes	371.71
Heritage Ln	15 Heritage Ln	17 Heritage Ln	2767	W	2.61	0.54	5.12	No	Yes	79.81
Hayward St	Howard St	Hobart St	2768	N	3.83	0.83	5.48	No	Yes	409.91
Hayward St	Heritage Ln	Marietta Ave	2780	N	2.68	0.88	5.54	No	Yes	710.50
Woodside Avenue	Woodedge Avenue	Old Country Way	141	E	2.23	0.71	5.19	No	Yes	533.18
Woodedge Avenue	Woodside Avenue	Woodedge Lane	142	S	1.75	0.69	5.26	Yes	Yes	195.11
Woodedge Avenue	43 Woodedge Avenue	25 Woodedge Avenue	145	N	2.29	0.62	4.01	No	Yes	202.79
Woodedge Avenue	Woodside Avenue	43 Woodedge Avenue	146	N	2.62	0.61	4.4	No	Yes	208.80
Cain Avenue	Belknap Road	Selwyn Road	147	W	3.66	0.83	5.28	No	Yes	285.82
Bramblewood Lane	Summit Ridge Drive	Maplewood Terrace	159	E	2.22	0.61	5.01	No	Yes	424.60
Belknap Road	Cranmore Road	Cain Avenue	163	S	1.68	0.35	5.33	Yes	Yes	516.61
Spring Glen Circle	23 Spring Glen Circle	Old Country Way	166	W	1.59	0.57	5.56	Yes	Yes	272.00
Belknap Road	Cranmore Road	Cain Avenue	165	N	1.30	0.57	6.05	Yes	Yes	488.80
South Street	Woodedge Avenue	Old Country Way	169	W	1.91	0.91	5.75	Yes	Yes	483.39
Cranmore Road	Selwyn Road	Court Road	143	N	1.21	0.68	5.65	Yes	Yes	1087.16
Cain Avenue	Bradford Road	Court Road	249	W	2.78	0.73	5.21	No	Yes	246.55
Cranmore Road	Selwyn Road	Belknap Road	162	S	1.35	0.71	5.82	Yes	Yes	254.98
Maplewood Terrace	Bramblewood Lane	72 Maplewood Avenue	144	N	1.47	0.67	5.21	Yes	Yes	1091.59
Milton Road	Court Road	112 Milton Road	160	E	1.43	0.68	5.64	Yes	Yes	1018.13
Milton Road	Bradford Road	Court Road	170	E	2.26	0.68	4.51	No	Yes	160.40
Selwyn Road	Court Road	Cain Avenue	149	S	1.66	0.77	5.03	Yes	Yes	1248.76
Liberty Street	1565 Liberty Street	Ashworth Avenue	171	W	1.89	0.86	5.45	Yes	Yes	339.83
Woodside Avenue	44 Woodside Avenue	Old Country Way	173	W	1.51	0.60	5.34	Yes	Yes	463.49
Woodside Avenue	Woodedge Avenue	Old Country Way	174	E	2.06	0.60	5.68	No	Yes	449.05
Old Country Way	Woodside Avenue	Spring Glen Circle	176	S	2.47	0.67	6.13	No	Yes	409.30
Leehaven Terrace	Old Country Way	Old Country Way	177	E	1.77	0.68	5.15	Yes	Yes	968.01
Old Country Way	Leehaven Terrace	Woodside Avenue	178	S	1.93	0.66	6.11	Yes	Yes	229.68
Leehaven Terrace	Old Country Way	Old Country Way	180	W	1.54	0.66	5.11	Yes	Yes	961.07
Washington Street	Brewster Avenue	Milton Road	186	E	1.92	0.58	5.66	Yes	Yes	399.99

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Washington Street	Arbutus Avenue	Brewster Avenue	192	E	2.16	0.53	5.39	No	Yes	879.14
Drake Street	Mann Street	Wildwood Avenue	215	E	0.83	0.61	4.69	Yes	Yes	402.10
Foster Road	23 Foster Road	1843 Washington Street	194	N	1.98	0.71	5.18	Yes	Yes	370.58
Washington St	South St SB	South St NB	187	W	1.72	0.55	5.36	Yes	Yes	25.33
Milton Road	Washington Street	Bradford Road	175	N	2.18	0.63	5.97	No	Yes	221.95
Mann St	Olofson Street	Drake Street	190	N	0.65	0.46	5.39	Yes	Yes	235.49
Old Country Way	Old Carriage Lane	Leehaven Terrace	179	S	2.50	0.74	5.49	No	Yes	574.62
Franklin Street	42 Franklin Street	1021 Washington Street	825	W	1.73	0.75	5.35	Yes	Yes	583.71
Franklin Street	189 Franklin Street	199 Franklin Street	910	E	1.89	0.49	6.36	Yes	Yes	283.60
Harness Lane	45 Harness Lane	Plain Street	1434	W	2.79	0.88	5.88	No	Yes	666.24
Selwyn Road	Court Road	Cranmore Road	181	N	1.42	0.60	5.51	Yes	Yes	277.56
Old Country Way	272 Old Country Way	South Street	182	N	1.49	0.62	5.81	Yes	Yes	401.89
Old Country Way	228 Old Country Way	242 Old Country Way	184	N	2.64	0.70	4.39	No	Yes	260.00
West Street	53 Ellsmore Terrace	250 West Street	2148	S	1.85	0.71	4.83	Yes	Yes	637.01
West Street	232 West Street	232 West Street	2152	S	0.87	0.46	5.44	Yes	Yes	191.12
West Street	365 Tremont Street	94 West Street	2154	S	1.60	0.63	6.06	Yes	Yes	196.39
West Street	86 West Street	68 West Street	2157	S	1.55	0.45	5.24	Yes	Yes	319.95
West Street	6 Oak Street	7 Walnut Street	2168	N	2.00	0.55	5.77	Yes	Yes	762.22
West Street	45 West Street	99 West Street	2169	N	3.02	0.51	5.09	No	Yes	806.14
West Street	210 West Street	192 West Street	2170	S	1.50	0.63	5.24	Yes	Yes	402.07
West Street	519 Washington Street	37 West Street	2173	N	1.42	0.62	5.04	Yes	Yes	414.00
West Street	60 West Street	533 Washington Street	2175	S	0.88	0.59	4.84	Yes	Yes	732.00
Walnut Street	7 Walnut Street	7 Walnut Street	2180	E	1.10	0.51	5.66	Yes	Yes	231.61
Franklin Street	76 Franklin Street	52 Franklin Street	854	W	2.48	0.90	5.48	No	Yes	413.64
Franklin Street	86 Frankln Street	82 Franklin Street	855	W	1.87	0.49	6.54	Yes	Yes	166.35
Franklin Street	252 Franklin Street	210 Franklin Street	2073	W	1.25	0.55	6.52	Yes	Yes	709.25
Franklin Street	10 Tremont Street	37 Franklin Street	827	E	1.92	0.71	4.68	Yes	Yes	491.55
Franklin Street	53 Franklin Street	72 Taylor Street	856	E	1.69	0.79	5.69	Yes	Yes	407.28
Franklin Street	137 Franklin Street	149 Franklin Street	2035	E	1.17	0.89	5.15	Yes	Yes	275.04
Franklin Street	261 Franklin Street	315 Franklin Street	2091	N	4.42	1.17	5.08	No	Yes	718.79
Washington Street	884 Washington Street	856 Washington Street	847	E	1.12	0.38	5.42	Yes	Yes	179.45
Washington Street	962 Washington Street	944 Washington Street	1666	S	1.19	0.38	5.42	Yes	Yes	195.50
Washington Street	786 Washington Street	766 Washington Street	1940	E	0.92	0.53	5.29	Yes	Yes	403.07
Washington Street	Robinson Ave	601 Washington St	2046	W	1.33	0.72	5.12	Yes	Yes	156.88
Washington Street	700 Washington Street	700 Washington Street	2077	E	1.58	0.62	5.2	Yes	Yes	145.46
Washington Street	8 Elm Street	286 Washington Street	1861	E	1.31	0.65	5.87	Yes	Yes	659.99
Packard Dr	20 Packard Drive	215 West Street	2172	W	0.84	0.43	4.54	Yes	Yes	267.23
Unnamed Lot	Franklin Street	End	2081	N	2.18	0.63	6.18	No	Yes	526.97
Washington Street	Tremont St	Washington St	779	N	0.86	0.54	6.81	Yes	Yes	334.00
Georganna Street	36 Georganna Street	692 Washington Street	2079	N	2.20	1.12	5.17	No	Yes	417.86
Washington Street	692 Washington Street	660 Washington Street	2084	E	1.37	0.56	5.64	Yes	Yes	457.71
Washington Street	Academy St	Hobart Ave	2085	W	1.58	0.46	5.97	Yes	Yes	378.99
Washington Street	Maple St	May Ave	2196	W	1.10	0.61	5.79	Yes	Yes	234.51
Town St	128 Town Street	128 Town Street	1676	E	1.17	0.40	4.11	Yes	Yes	42.76
Washington Street	West St	Mt. Vernon Ave	2147	W	1.22	0.55	5.22	Yes	Yes	428.10
Washington Street	Off-Ramp	On-Ramp	2487	W	0.70	0.67	5.62	Yes	Yes	518.47
Washington Street	Independence Ave	80 Independence Ave	2553	W	1.91	0.65	5.27	Yes	Yes	177.48
Washington Street	80 Independence Ave	Cedar St	2594	W	0.87	0.66	5.28	Yes	Yes	437.83
Washington Street	85 Washington St	Cedar St	2610	W	1.31	0.86	5.71	Yes	Yes	136.06
Washington Street	85 Washington St	Fairfield St	2631	W	1.25	0.72	5.37	Yes	Yes	420.13
Washington Street	Holmes St	5 Washington St	2698	W	1.44	0.69	4.95	Yes	Yes	150.04
Washington Street	Common St	Faulkner Pl	2747	W	1.07	0.55	5.24	Yes	Yes	288.86
Washington Street	659 Washington St	Academy St	2789	W	1.42	0.47	6.2	Yes	Yes	202.73
Washington Street	482 Washington Street	482 Washington Street	2198	E	1.89	0.49	5.64	Yes	Yes	87.85
Washington Street	250 Washington Street	246 Washington Street	2748	E	0.83	0.55	6.12	Yes	Yes	116.08
Washington Street	218 Washington Street	President Rd	2494	E	1.41	0.71	5.21	Yes	Yes	798.48
Washington Street	80 Independence Ave	On-Ramp	2545	E	2.24	0.87	5.1	No	Yes	203.44
Washington Street	Capen Rd	80 Independence Ave	2552	E	4.32	0.62	5.98	No	Yes	107.04
Washington Street	116 Washing Street	166 Cedar Street	2590	E	2.21	0.77	5.45	No	Yes	355.86
Washington Street	104 Washington Street	1 Russell Road	2622	E	1.52	0.38	6.13	Yes	Yes	241.76

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Washington Street	8 Russell Road	196 Hawthorn Road	2651	E	1.72	0.64	6.13	Yes	Yes	246.36
Washington Street	50 Washington Street	30 Washington Street	2677	E	0.97	0.48	5.48	Yes	Yes	440.43
Washington Street	20 Washington Street	16 Washington Street	2697	E	0.44	0.56	5.11	Yes	Yes	174.33
Washington Street	Storrs Ave	Parkingway	2268	W	1.09	0.64	6.77	Yes	Yes	430.15
Washington Street	Elm St	Storrs Ave	2314	W	1.16	0.55	5.59	Yes	Yes	140.20
Washington Street	482 Washington Street	482 Washington Street	2202	E	1.45	0.56	5.18	Yes	Yes	102.59
Washington Street	460 Washington Street	442 Washington Street	2226	E	1.29	0.65	5.36	Yes	Yes	360.39
Washington Street	432 Washington Street	384 Washington Street	2249	E	1.97	0.64	6.43	Yes	Yes	688.49
Washington Street	374 Washington Street	15 Elm Street	2309	E	0.71	0.55	5.64	Yes	Yes	310.51
Washington Street	Sidewalk Island	Sidewalk Island	2837	S	1.02	0.93	6.58	Yes	Yes	46.63
Crawford Street	238 Pearl Street	15 Crawford Street	1422	W	2.44	0.90	4.26	No	Yes	111.85
Zana Park Drive	10 Zana Park Drive	457 Liberty Street	1512	N/A	2.72	0.68	5.13	No	Yes	1314.70
Congress Street	42 Congress Street	End	1429	E	2.38	0.71	4.2	No	Yes	183.16
Hayward St	Marietta Ave	Quincy Ave	2782	N	2.49	1.09	5.88	No	Yes	246.80
Claremont St	Lincoln St	43 Claremont St	1517	E	1.93	0.83	5.03	Yes	Yes	152.31
Hayward St	Shaw St	Heritage Ln	2785	N	2.51	0.93	6.46	No	Yes	296.87
Grove Street	Liberty Street	365 Grove Street	1436	S	1.70	0.93	5.52	Yes	Yes	246.02
Azel Rd	Lakeview Ave	Marshfield Rd	909	W	0.88	0.48	5.26	Yes	Yes	314.98
Sunnyside Lane	31 Sunnyside Lane	Grove Street	1440	W	1.93	0.63	5.78	Yes	Yes	319.78
Stone Crest Drive	Grove Street	Grove Street	1441	N/A	1.74	0.63	5.65	Yes	Yes	882.33
Shopping Lot	End	John W. Mahar Highway	1442	S	0.78	0.56	4.73	Yes	Yes	182.72
Gray Terr	29 Gray Terrace	50 Gray Terrace	1373	N/A	3.17	0.73	6.17	No	Yes	302.03
Lowell St	Park St	Elm St	2388	W	2.77	0.56	4.99	No	Yes	513.17
Grove St	125 Plain St	Grove Cir	1439	N	2.39	0.44	5.76	No	Yes	71.73
Beechwood Rd	Quincy Ave	Arthur St	1333	S	2.66	1.16	6.06	No	Yes	401.19
Bestick Rd	Dickerman Ln	Staten Rd	2354	E	2.23	0.91	5.19	No	Yes	241.14
Brickford Rd	40 Bickford Rd	Quincy Ave	1314	S	3.79	0.82	5.18	No	Yes	475.86
Danielle Ln	Liberty Street	894 Liberty Street	1437	S	1.98	0.95	4.11	Yes	Yes	599.62
Dobson Rd	Dobson Rd	Wilkins Rd	2521	E	2.59	0.58	6.11	No	Yes	166.66
Lowell St	27 Lowell St	Elm St	2396	E	3.44	1.05	5	No	Yes	372.78
Farm Rd	Cindy Ln	End	2800	S	1.86	0.81	6.18	Yes	Yes	118.40
Heritage Ln	20 Heritage Ln	62 Heritage Ln	2802	E	2.45	0.51	5.22	No	Yes	569.43
Home Park Road	119 Blanchard Boulevard	118 Home Park Road	2806	W	2.25	0.57	5.17	No	Yes	290.32
Longwood Road	Home Park Rd	End	2807	E	2.05	1.08	5.19	No	Yes	522.77
Shopping Lot	End	John W. Mahar Highway	1443	N	0.92	0.53	5.85	Yes	Yes	319.87
St. Claire St	175 St Claire St	265 St Claire St	1621	E	1.64	0.90	4.75	Yes	Yes	944.28
Hollingsworth Ave	Weston Ave	West St	2165	E	2.43	0.81	3.47	No	No	916.22
Hobart Ave	59 Hobart Ave	39 Hobart Ave	2796	S	2.45	0.74	6.12	No	Yes	294.56
Highland Avenue East	28 Highland Avenue East	64 Highland Avenue East	2817	W	1.35	0.78	5.18	Yes	Yes	422.84
Tingley Rd	Tingley Cir	Cypress St	2418	N	1.74	0.54	5.43	Yes	Yes	220.59
Tingley Rd	Cypress St	End	2426	N	2.33	0.59	5.55	No	Yes	176.53
Hawthorn Road	Washington Street	187 Hawthorn Road	2839	E	2.16	0.96	5.59	No	Yes	161.17
St. Lawrence St	St. Claire St	Forest St	1627	S	2.16	1.07	5.04	No	Yes	1240.06
Devon Wood Dr	Liberty St	Devon Wood Dr	210	N	1.98	0.29	5.55	Yes	Yes	272.01
Cypress St	Tingley Rd	End	2413	W	1.62	0.39	4.69	Yes	Yes	85.22
Cypress St	Tingley Rd	End	2414	E	2.00	0.50	4.77	No	Yes	78.33
Cypress St	Popar St	Tingley Rd	2432	E	2.47	0.68	5.26	No	Yes	154.63
Hobart St	Hobart St	Prospect St	2469	E	3.43	0.76	5.48	No	Yes	678.75
Hobart Ave	19 Hobart Ave	Washington St	2794	N	3.10	0.65	5.81	No	Yes	204.45
Hobart Ave	59 Hobart Ave	19 Hobart Ave	2795	N	3.12	0.73	4.72	No	Yes	621.11
Hawthorn Road	160 Hawthorn Road	152 Hawthorn Road	2840	W	1.56	1.12	5.16	Yes	Yes	163.22
Magnolia Street	50 Magnolia Street	62 Magnolia Street	2845	N	1.24	0.65	5.85	Yes	Yes	157.96
Shaw St	Somerville St	Wellington St	2515	W	1.48	0.87	5.21	Yes	Yes	194.16
Abby Rd	Old Valley Rd	Plain St	672	W	3.21	1.39	4.71	No	Yes	281.97
Abby Rd	Cherry Ln	Cherry Ln	748	N/A	3.45	1.28	5.36	No	Yes	857.64
Weston Ave	Hollingsworth Ave	Tremont St	2114	S	5.06	0.92	5.46	No	Yes	265.51
Shaw St	50ft NE Berwick St	Hayward St	1950	E	1.48	0.75	5.58	Yes	Yes	382.22
Cleveland Ave	Circuit Rd	Bradley Rd	1954	E	1.01	0.36	4.22	Yes	Yes	180.49
Cabot Ave	End	Cleveland Ave	1961	S	1.24	0.48	4.47	Yes	Yes	364.95
Merritt Ave	End	Cleveland Ave	1963	N	1.26	0.59	5.38	Yes	Yes	625.32

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Cleveland Ave	Harrison Ave	Cabot Ave	1964	S	0.79	0.45	5.14	Yes	Yes	333.98
Hobart Ave	Thayer Academy Bus Road Entrance	Thayer Academy Bus Road Exit	2104	S	1.75	0.76	5.74	Yes	Yes	243.72
Hobart Ave	Thayer Academy Bus Road Exit	Thayer Academy Access Road	2105	S	2.48	0.60	7.27	No	Yes	145.80
Middle School Lot	Hobart Ave	End	2106	W	2.01	0.54	7.25	No	Yes	228.72
Weston Ave	50 Weston Ave	Washington St	2107	S	3.11	0.88	5.39	No	Yes	650.53
Weston Ave	Tremont St	50 Weston Ave	2109	S	3.02	0.85	5.27	No	Yes	817.10
Weston Ave	Weston Ct	Washington St	2111	N	1.82	0.75	5.88	Yes	Yes	254.30
Hollingsworth Ave	Academy St	Weston Ave	2113	E	3.31	1.21	3.74	No	No	452.00
Hollingsworth Ave	Academy St	Weston Ave	2115	W	1.34	0.71	6.03	Yes	Yes	406.54
Weston Ave	Norton St	Hollingsworth Ave	2117	S	1.11	0.81	5.82	Yes	Yes	251.42
Mt. Vernon St	Robinson Ave	Weston Ave	2121	E	1.29	0.60	4.81	Yes	Yes	135.78
Weston Ave	173 Weston Ave	Hollingsworth Ave	2122	N	2.43	1.04	4.78	No	Yes	360.72
Mt. Vernon St	Robinson Ave	Weston Ave	2123	W	1.19	0.49	3.86	Yes	No	145.57
Washington Street	601 Washington St	Weston Ave	2124	W	1.50	0.59	6.18	Yes	Yes	173.75
Robinson Ave	65ft W Robinson Ave	Washington St	2136	N	1.49	0.95	5.65	Yes	Yes	72.07
Mt. Vernon St	41 Mt. Vernon St	Robinson Ave	2137	W	1.23	0.51	5.45	Yes	Yes	274.77
Mt. Vernon Ave	Mt. Vernon St	Washington St	2140	S	1.07	0.53	5.43	Yes	Yes	966.08
Washington Street	Mt. Vernon St	Robinson Ave	2141	W	1.02	0.55	5.57	Yes	Yes	221.05
Mt. Vernon Ave	Mt. Vernon St	Washington St	2145	N	1.07	0.50	4.19	Yes	Yes	970.12
Mt. Vernon St	West St	19 Mt. Vernon St	2150	W	1.18	0.57	5.47	Yes	Yes	239.44
Herbert Rd	West St	63 Herbert Rd	2153	W	1.59	0.39	3.66	Yes	No	849.13
Selwyn Road	Cranmore Road	Cain Avenue	131	N	1.58	0.67	4.79	Yes	Yes	899.82
Ellsworth St	Mt. Vernon St	West St	2158	S	1.42	0.53	4.3	Yes	Yes	496.56
Herbert Rd	West St	171 Herbert Rd	2160	N/A	1.37	0.37	4	Yes	No	2112.44
Herbert Rd	63 Herbert Rd	West St	2163	E	0.84	0.40	3.99	Yes	No	1546.43
Devon Wood Dr	Devon Wood Dr	Bradford Commons Ln	209	N	1.69	0.46	5.67	Yes	Yes	3752.91
Court Road	Selwyn Road	Cranmore Road	217	E	1.06	0.61	5.98	Yes	Yes	845.08
Cross Road	82 Cross Road	Linda Road	472	N	0.46	0.93	4.1	Yes	Yes	310.52
Eleanor Drive	62 Addison Street	44 Addison Street	1014	N/A	1.66	0.87	4.44	Yes	Yes	1927.12
Common Street	405 Common St	457 Common St	1175	W	1.03	0.75	5.61	Yes	Yes	441.47
Commercial St	Shaw St	Wright Connector	1182	N	2.18	0.60	6.46	No	Yes	226.20
Common Street	457 Common St	250 Granite Street	1241	N	1.18	0.67	5.87	Yes	Yes	1130.86
Brickford Rd	60 Bickford Rd	40 Bickford Rd	1313	S	2.06	0.72	4.84	No	Yes	306.07
Edgemont Rd	101 Edgemont Rd	51 Edgemont Rd	1315	N	2.78	0.89	4.81	No	Yes	633.72
Edgehill Rd	Wuincy Ave	Arthur St	1321	N	3.64	1.29	4.56	No	Yes	502.14
Edgemont Rd	52 Edgemont Rd	Quincy Ave	1337	S	2.58	1.30	6.08	No	Yes	652.62
Common Street	250 Granite Street	457 Common St	1534	W	1.55	0.64	4.7	Yes	Yes	427.43
Crawford Rd	Crawford St	Pearl St	1672	S	4.13	0.91	5.66	No	Yes	698.76
Plymouth Avenue	Arbutus Avenue	Brewster Avenue	260	W	0.75	0.60	5.07	Yes	Yes	844.26
Avon Pl	Connell St	Connell St	1914	N/A	1.02	0.59	5.73	Yes	Yes	564.52
Argyle Rd/Trefton Dr	67 Trefton Dr	69 Trefton Dr	1925	S	2.10	0.57	4.05	No	Yes	151.57
Bradley Rd	Cleveland Ave	33 Bradley Road Ext	1928	S	2.06	0.48	5.43	No	Yes	448.29
Bradley Rd	Cleveland Ave	32 Bradley Rd Ext	1933	N	2.14	0.45	4.44	No	Yes	447.83
Arthur St	Beechwood Rd	Edgehill Rd	2015	E	3.58	0.64	3.48	No	No	228.08
Quincy Ave	Edgehill Rd	Gordon Rd	2016	E	2.78	0.74	5.14	No	Yes	257.50
Arthur St	Audobon Ave	Arborway Dr	2018	W	3.75	0.71	5.78	No	Yes	330.34
Gordon Rd	Quincy Ave	Gordon Rd	2020	N	5.44	0.81	5.93	No	Yes	653.19
Azel Rd	15 Azel Rd	19 Azel Rd	2034	S	0.66	0.52	5.66	Yes	Yes	141.12
Hobart Ave	Hollingsworth Ave	Tremont St	2036	N	3.03	0.96	5.58	No	Yes	689.22
Commercial St	365 Commercial St	341 Commercial St	1788	E	1.73	0.51	5.09	Yes	Yes	300.70
Brickford Rd	Newton Ave	Quincy Ave	1789	N	2.44	0.65	5.94	No	Yes	296.73
Lemoyne St	River St	35-45 Lemoyne St	1790	W	2.10	0.97	4.81	No	Yes	84.70
Myrtle St	22 Myrtle St	30 Myrtle St	1792	N	3.04	0.46	5.42	No	Yes	202.54
Vine St	Myrtle St	River St	1794	E	3.31	0.70	4.77	No	Yes	488.75
Arborway Dr	Quincy Ave	Arthur St	1800	N	4.70	0.87	4.74	No	Yes	218.59
Hillside Ave	50 Hillside Ave	Marietta Ave	1809	N	2.99	0.55	5.97	No	Yes	104.51
River St	Lemoyne St	Arnold St	1819	N	0.98	0.43	6.42	Yes	Yes	265.18
Willow St	55 Willow St	Front St	1820	E	1.88	0.44	4.73	Yes	Yes	719.84
Baker Ave	Union Ave	48 Baker Ave	1821	E	0.44	0.39	4.72	Yes	Yes	573.09
Cleveland Ave	Circuit Rd	Union St	1834	E	1.49	0.55	4.27	Yes	Yes	501.76

**Braintree, MA - Cross Slope + Width Assessment  
2018**

Front St	Oak St E	Bowditch St	1835	N	2.06	0.52	5.27	No	Yes	257.72
Alexander Rd	Union St	58 Alexander Rd	1836	W	2.94	0.74	4.81	No	Yes	936.76
Elm St	Service Road	Elm Terrace	1838	W	1.22	0.62	6.18	Yes	Yes	315.82
River St	Arnold St	East Middle School Lot	1879	S	2.77	0.59	6.2	No	Yes	1373.53
Union St	Miller St	Hillside Rd	1882	W	0.82	0.54	4.99	Yes	Yes	924.94
Elm St	Washington St	8 Elm St	1886	N	1.07	0.57	6.14	Yes	Yes	121.16
Elm St	Stedman Ave	Church St	1887	N	0.57	0.53	5.46	Yes	Yes	680.66
Service Rd	Church St	Elm St	1888	E	1.45	0.58	6.19	Yes	Yes	587.02
Connell St	Avon Place	Avon Place	1889	N/A	0.92	0.61	4.77	Yes	Yes	643.36
Merritt Ave	End	Cleveland Ave	1980	S	1.91	0.86	5.13	Yes	Yes	634.67
Cleveland Ave	Harding Ave	Cabot Ave	1981	W	1.61	0.50	5.71	Yes	Yes	281.14
Gordon Rd	Quincy Ave	Arthur St	1986	S	2.99	1.05	5.34	No	Yes	684.45
Edgehill Rd	60ft SE Argyle Rd	80ft SW from Toland Walkway	1989	S	3.43	0.90	5.5	No	Yes	968.95
Edgehill Rd	65ft from Argyle Rd	186 Edgehill Rd	1993	N	4.56	1.11	5.04	No	Yes	1097.32
Arborway Dr	Autumn St	97 Arborway Dr	1999	S	1.72	0.93	5.18	Yes	Yes	114.86
Edgehill Rd/Vinedale Rd	161 Edgehill Rd	39 Vinedale Rd	2002	E	1.58	0.74	5.52	Yes	Yes	723.07
Gordon Rd	Arthur St	Argyle Rd	2004	N	5.02	1.07	5.28	No	Yes	650.47
Gordon Rd	Arthur St	Argyle Rd	2005	S	2.68	1.21	5.66	No	Yes	646.11
Arborway Dr	Spencer St	Primrose St	2029	N	5.18	1.00	4.67	No	Yes	160.88
Elm St	Elm Terrace	Elm Street	2822	N/A	0.41	0.57	5.25	Yes	Yes	81.78
Sherbrook Ave	Washington St	79 Sherbrook Ave	2824	S	1.09	0.50	5.94	Yes	Yes	1063.46
Webster Rd	24 Webster Rd	Wyman Rd	2825	N	1.26	0.45	4.79	Yes	Yes	135.44
Independence Ave	30ft NE on Holmes St	Opp 41 Independence Ave Bus Stop	2838	E	2.15	0.61	5.28	No	Yes	251.68
John W. Mahar Hwy	Plain St	Pearl St	645	E	1.40	0.60	6.14	Yes	Yes	2568.43
Jefferson St	Shepard Rd	Washington St	655	N	2.75	0.95	5.56	No	Yes	606.12
Liberty St	Plain St	Pearl St	737	W	1.75	1.31	3.96	Yes	No	1195.68
Hancock St	Thayer Ave	Myrtle Ave	754	E	1.71	0.45	5.46	Yes	Yes	561.12
Baker Ave	Union St	56 Baker Ave	1890	W	0.52	0.35	5.64	Yes	Yes	649.26
Crawford Rd	Crawford St	Pearl St	1674	N	3.43	1.03	5.42	No	Yes	819.22
Dearing Ave	End	Hollis Ave	2236	W	3.11	0.61	4.78	No	Yes	140.05
Cleveland Ave	Merritt Ave	Middle St	2242	E	1.52	0.61	5.22	Yes	Yes	165.52
Cindy Ln	Farm Rd	End	2286	E	1.36	0.93	5.75	Yes	Yes	342.87
Duckerman Ln	End	35 Dickerman Ln	2347	N	3.59	0.82	4.67	No	Yes	585.93
Church St	Bushnell Terr	Service Rd	2379	W	0.47	0.55	5.72	Yes	Yes	894.14
Commercial St	Wilkins Rd	Beech St	2468	E	2.41	0.58	6.13	No	Yes	231.34
Chickadee Ln	John Paul Cir	John Paul Cir	2707	S	4.36	1.30	4.66	No	Yes	698.01
Clark St	Washington St	Wyman Rd	2741	N	2.07	0.46	5.34	No	Yes	335.43
Packard Drive	39 Packard Drive	20 Packard Drive	2736	N/A	1.48	0.48	5.21	Yes	Yes	1068.27