



Braintree Town Council

ORDER NO: 20 023

DATE FILED: FEBRUARY 25, 2020

REQUEST OF: NATIONAL GRID

National Grid hereby respectfully requests your consent to the locations of mains as hereinafter described for the transmission and distribution of gas in and under the following public streets, lanes, highways, and places of the Town of Braintree and of the pipes, valves, governors, manholes and other structures, fixtures and appurtenances designed or intended to protect or operate said mains and accomplish the objects of said Company; and the digging up and opening the ground to lay or place same:

Install and maintain approximately 3145 feet of 6 inch 60 psig plastic gas main in Liberty Street from the existing 6 inch 60 psig plastic service at 1024 Liberty Street to the existing 6 inch 60 psig main at Christina Drive and including a 4 inch 60 psig connection at Peach Street, a 3 inch 60 psig connection at Forest Street and a 2 inch 60 psig connection plus test station and anodes at Sycamore Road, and also to install and maintain 1420 feet of 2 inch 60 psig plastic gas main in Proctor Road, all to replace older mains and service the users along the route with staff recommendations:

BELD: There are no underground electric utility conflicts or special requirements within the proposed scope of work.

DPW: Neither Liberty Street nor Proctor Road is under the moratorium, these sections of Liberty Street having been reconstructed in 2003 and 2005 and Proctor Road having been reconstructed in 2003, but both are in fairly good condition. Both of these sections are on the draft Roadway and Infrastructure Program for pavement preservation, Proctor Road in 2021 and Liberty Street in 2023. Since neither street is under the moratorium, I recommend that the petition be granted under the normal conditions with emphasis on the following:

1. That the work be done expeditiously so not to interfere with the planned Town work;
2. That the new mains not occupy any part of the trenches now occupied by the existing water or sewer mains;
3. that after maintaining the 4" minimum* pavement depth temporary trenches from both the installations and the removals through one winter, but within one year of placement of the temporary trench repair, that the permanent repair be a grind and inlay with a minimum 1 foot overlap of the adjacent pavement 1 ½ inches deep of both trenches and of each service trench within the limits of the gas work;
4. That any curbs or sidewalks or other features disturbed shall be repaired to the satisfaction of the DPW;



Braintree Town Council

ORDER NO: 20 023

PAGE 2 OF 2

"Neither National Grid nor any contractor is authorized to close any street or to close a direction of travel to facilitate their work without authorization from the Director of the Department of Public Works or the Highway Superintendent. The Chief of Police can also authorize a closure for a police or fire emergency. Construction zone traffic safety issues are to be addressed by using appropriate traffic control signs and devices and the use of trained traffic control personnel to safely guide traffic through the work zone. If a closure is authorized by the DPW, it shall not be implemented until signs and traffic control officers (where needed) are properly in place in conformity with the written plan prepared by the contractor's engineer and approved by the DPW and the Police Department."

*4" depth is to be constructed at all locations where the existing pavement depth is 4" or less. At all other locations the thickness of the pavement depth placed shall match the existing pavement thickness. Pavement shall be placed and compacted in courses not to exceed 2 ½ inches.

YEAS: Boericke, Connors, Flaherty, Hume, Mackin, O'Brien, Ringius, Ryan, Sciascia

NAYS: NONE

ABSENT: NONE

PASSED IN COUNCIL: APRIL 28, 2020

A True Record, Attest:

May 4, 2020
Date Approved

James M. Casey
James M. Casey, Town Clerk

PETITION OF NATIONAL GRID FOR GAS MAIN LOCATIONS

2 0 - 0 2 3

Town of Braintree / Town Council:

The Nationalgrid hereby respectfully requests your consent to the locations of mains as hereinafter described for the transmission and distribution of gas in and under the following public streets, lanes, highways and places of the **Town of Braintree** and of the pipes, valves, governors, manholes and other structures, fixtures and appurtenances designed or intended to protect or operate said mains and accomplish the objects of said Company; and the digging up and opening the ground to lay or place same:

To install and maintain approximately 3195 feet more or less of 6 inch 60 psig plastic gas main in Liberty St., Braintree. From the existing 6 inch 60 psig plastic gas main (2004) near house #1024 southwesterly to the existing 6 inch 60 psig gas main (1993) just past Peach St. at pole #163 on Liberty St. and approximately 1420 feet more or less of 2 inch 60 psig plastic gas main in Proctor Rd. from the new 6 inch 60 psig plastic gas main in Liberty St. near #1114 to the new 6 inch 60 psig plastic gas main near #1244 Liberty St. To replace the existing 4 inch and 2 inch 60 psig bare steel gas main (1954) in Liberty St. and the 2 inch 60 psig coated steel gas main (1949) in Proctor Rd.

January 29, 2020

By: Barbara H. Kelleher
Barbara H. Kelleher
Permit Representative

Town of Braintree / Town Council:

IT IS HEREBY ORDERED that the locations of the mains of the Nationalgrid for the transmission and distribution of gas in and under the public streets, lanes, highways and places of the **Town of Braintree** substantially as described in the petition date January 29, 2020 attached hereto and hereby made a part hereof, and of the pipes, valves, governors, manholes and other structures, fixtures and appurtenances designed or intended to protect or operate said mains and/or accomplish the objects of said Company, and the digging up and opening the ground to lay or place same, are hereby consented to and approved.

The said Nationalgrid shall comply with all applicable provisions of law and ordinances of the **Town of Braintree** applicable to the enjoyment of said locations and rights.

Date this 30th day of April, 2020.

I hereby certify that the foregoing order was duly adopted by the Town Council of the Town of Braintree, MA on the 28th day of April, 2020.

By: James M. Casey
James M. Casey
Town Clerk
Title

WO# 1252734

**Return Original to Permit Section
National Grid
40 Sylvan Rd, Waltham, MA 02451
Retain Duplicate for your Records**

2020 FEB 12 AM 9:32

RECEIVED TOWN CLERK
BRAINTREE, MA